

Rec'd 9/26/22

2021 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Carrollton

PRINT Public Water System Name

0080002

List PWS ID #s for all Community Water Systems included in this CCR

CCR DISTRIBUTION (Check all boxes that apply)	
INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Advertisement in local paper (Attach copy of advertisement)	
<input checked="" type="checkbox"/> On water bill (Attach copy of bill)	
<input type="checkbox"/> Email message (Email the message to the address below)	
<input type="checkbox"/> Other (Describe: _____)	
DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)	DATE ISSUED
<input type="checkbox"/> Distributed via U.S. Postal Service	
<input type="checkbox"/> Distributed via E-mail as a URL (Provide direct URL): _____	
<input type="checkbox"/> Distributed via Email as an attachment	
<input type="checkbox"/> Distributed via Email as text within the body of email message	
<input type="checkbox"/> Published in local newspaper (attach copy of published CCR or proof of publication)	
<input type="checkbox"/> Posted in public places (attach list of locations or list here) _____	
<input checked="" type="checkbox"/> Posted online at the following address (Provide direct URL): <u>CarrolltonMs.net</u>	

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been prepared and distributed to its customers in accordance with the appropriate distribution method(s) based on population served. Furthermore, I certify that the information contained in the report is correct and consistent with the water quality monitoring data for sampling performed and fulfills all CCR requirements of the Code of Federal Regulations (CFR) Title 40, Part 141.151 – 155.

Pamela R Lee
Name

Mayor
Title

9/26/22
Date

SUBMISSION OPTIONS (Select one method ONLY)

You must email or mail a copy of the CCR, Certification, and associated proof of delivery method(s) to the MSDH, Bureau of Public Water Supply.

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Rec'd 6/6/22

*2021 Annual Drinking Water Quality Report
Town of Carrollton
PWS ID # 0080002
May 2022*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 3 wells that draw from the Middle Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of Carrollton received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Galen Shumaker at 662-674-5353. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday of each month at Carrollton Town Hall at 6:00 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
11. Arsenic	N	2020*	0.7	No Range	Ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
13. Barium	N	2020*	0.0424	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
20. Chromium	N	2020*	5.4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
21. Copper	N	1/1/17 to 12/31/19*	0.5	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
22. Cyanide	N	2021	57.10	None	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
23. Fluoride	N	2020*	0.23	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
24. Lead	N	1/1/17 to 12/31/19*	2.0	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2021	134000	33200 to 134000	ppb	0	250000	Road salt, water treatment chemicals, water softeners and sewage effluents
Disinfectants & Disinfectant By-Products								
83. Chlorine	N	2021	0.90	0.50 to 1.20	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

CHECKS PAYABLE TO:

TOWN WATER DEPT.

P.O. Box 181
Meridian, MS 38917-0181

Or

PERSON AT:

TOWN WATER DEPT.
Washington Street
Meridian, MS 38917

FOR YOUR CONVENIENCE-
CASH ON EXTERIOR
DEPOSIT OFFICE

NUMBER PER CREDIT-RECORD
SERIAL NO. ON CHECK.

BILLING INQUIRIES:

Call Water Office at (662) 237-4600

Payments not received by past due date subject to \$10.00 late fee.

If water is turned off for non-payment, there is a \$50.00 reconnect fee.

There will be a service charge \$25.00 for all returned checks.

662-237-4600
Phone or Fax Number

CCR available at Town Hall or
online at mississippiwatercompany.org



ACCOUNT NUM	SERVICE FROM	SERVICE TO	DAYS	FAST DUE AFTER
0010	07-23-22	08-26-22	35	10-15-22
METER READINGS		USAGE	CHARGE	AMOUNT
PREVIOUS	PRESENT			
2401230024180200	167900	Water	1013.40	
WATER BILL				
On/After 10-15-22 add \$10.00 penalty and pay \$1023.40				
Last Payment received was \$1013.40 on 09-15-22				
BILLING PERIOD	DAYS	USAGE		
THIS YEAR	35	167900		
LAST YEAR	39	125300		
BASE	RATES PER GALLONS		TOTAL DUE	1013.40
PLEASE PAY THIS AMOUNT --				

PRESORTED
FIRST CLASS MAIL
U. S. POSTAGE PAID
CARROLLTON, MS
PERMIT NO. 4

RETURN SERVICE REQUESTED

BILLING DATE	PAST DUE AFTER
09-26-22	10-15-22
ACCT. NUMBER	AMOUNT DUE
0010	1013.40
On/After 10-15-22 pay \$1023.40	
PLEASE RETURN THIS STUB WITH PAYMENT	

CARROLL ACADEMY BOOSTERS
P O BOX 226
CARROLLTON MS 38917

CCR available at Town Hall or on Town website at CarrolltonMs.net

ACCOUNT NUM	SERVICE FROM	SERVICE TO	DAYS	FAST DUE AFTER
0015	08-27-22	09-23-22	28	10-15-22
METER READINGS		USAGE	CHARGE	AMOUNT
PREVIOUS	PRESENT			
186600	191390	4790	Water	34.74
WATER BILL				
On/After 10-15-22 add \$10.00 penalty and pay \$65.74				
Last Payment received was \$59.46 on 09-15-22				
BILLING PERIOD	DAYS	USAGE		
THIS YEAR	28	4790		
LAST YEAR	34	6690		
BASE	RATES PER GALLONS		TOTAL DUE	55.74
PLEASE PAY THIS AMOUNT --				

PRESORTED
FIRST CLASS MAIL
U. S. POSTAGE PAID
CARROLLTON, MS
PERMIT NO. 4

RETURN SERVICE REQUESTED

BILLING DATE	PAST DUE AFTER
09-26-22	10-15-22
ACCT. NUMBER	AMOUNT DUE
0015	55.74
On/After 10-15-22 pay \$65.74	
PLEASE RETURN THIS STUB WITH PAYMENT	

MARGARET CAMPBELL (DRAFT)
219 Hafner St.
CARROLLTON MS 38917

CCR available at Town Hall or on Town website at CarrolltonMs.net

ACCOUNT NUM	SERVICE FROM	SERVICE TO	DAYS	FAST DUE AFTER
0020	08-27-22	09-23-22	28	10-15-22
METER READINGS		USAGE	CHARGE	AMOUNT
PREVIOUS	PRESENT			
264210	270290	6080	Water	42.48
WATER BILL				
On/After 10-15-22 add \$10.00 penalty and pay \$73.48				
Last Payment received was \$79.80 on 09-07-22				
BILLING PERIOD	DAYS	USAGE		
THIS YEAR	28	6080		
LAST YEAR	34	7880		
BASE	RATES PER GALLONS		TOTAL DUE	63.48
PLEASE PAY THIS AMOUNT --				

PRESORTED
FIRST CLASS MAIL
U. S. POSTAGE PAID
CARROLLTON, MS
PERMIT NO. 4

RETURN SERVICE REQUESTED

BILLING DATE	PAST DUE AFTER
09-26-22	10-15-22
ACCT. NUMBER	AMOUNT DUE
0020	63.48
On/After 10-15-22 pay \$73.48	
PLEASE RETURN THIS STUB WITH PAYMENT	

MIKE RAYBURN
P O BOX 517
CARROLLTON MS 38917

CCR available at Town Hall or on Town website at CarrolltonMs.net