
MSDH-WATER SUPPLY 2023 APR 26 AM 10: 28

Certification

Water systems serving 10,000 or more must use: Distribution Method I				
Water systems serving 500 - 9.999 must use: Distribution Method I OR Distribution Method II, III, and IV				
Water system serving less than 500 people must use: Distribution Method I OR Distribution Method II, III, and IV OR Distribution Method III and IV	OFFICE USE	ONLY		
Public Water Supply name(s):	7-digit Public Water	Supply ID #(s):		
CARNES UTILITY ASSOCIATION, INC.	0180003			
Distribution (Methods used to distribute CCR to ou	r customers)			
E I. CCR directly delivered using one or more method b	elow:			
*Provided direct Web address to customer Hand delivered	*Add direct Web address (URL) here: https://msrwa.org/2022CCR/CarnesUA.pdf			
□ Mail paper copy	Example: "The current CCR is available at www.waterworld.org/ccrMay2023/0830001.pdf.			
□ Email	call (000) 000-0000 f	ay2023/0830001.paj.		
☐ II. Published the complete CCR in the local newspaper.	Date(s) published:			
☐ III. Inform customers the CCR will not be mailed but is available upon request.	Date(s) notified:			
List method(s) used (examples – newspaper, water bills, newsletter, etc.).	Location distributed:			
□ IV. Post the complete CCR continuously at the	Date:			
local water office. "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)	Locations posted:			
Certification				
This Community public water system confirms it has distributed and the appropriate notices of availability have been given and to consistent with the compliance monitoring data previously submit Public Water Supply and the requirements of the CCR rule.	hat the information contained is	n its CCR is correct and		
Name: Kris Woodward	Title: WATER OPERATOR	Date: 04/25/2023		
Submittal				
Email the following required items to water reports@msdh.ms.go 1. CCR (Water Quality Report) 2. Certificat	v regardless of distribution meth ion 3. Proof of delivery m	ethod(s)		

2022 Annual Drinking Water Quality Report Carnes Utility Association PWS#: 0180003 April 2023



We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

About Our System

The Carnes Utility Association (CUA) has had a busy year, fixing leaks, buried pipes that have been exposed for years, changing out all the old metes and putting double check valves on each meter. CUA has been working very hard at getting ARPA monies for a new 400 GPM water well. We are also in the process of getting the plans drawn up to install a new waterline down Herwick Road with Forrest County ARPA District 5 monies. Please feel free to call the office if you have any questions or concerns.

Contact & Meeting Information

If you have any questions about this report or concerning your water utility, please contact Kris Woodward at 601.716.7239. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at 6:30 PM and the Annual Meeting will be held January 8, 2024 at the Water Tower Office located at 1084 Carnes Rd., Wiggins, MS 39577.

Source of Water

Our water source is from wells drawing from the Miocene Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Carnes Utility Association have received a lower to higher susceptibility ranking to contamination.

Period Covered by Report

We routinely monitor for contaminants in your drinking water according to federal and state laws. This report is based on results of our monitoring period of January 1st to December 31st, 2022. In cases where monitoring wasn't required in 2022, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

Terms and Abbreviations

In the table you may find unfamiliar terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

<u>Action Level (AL)</u>: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

<u>Maximum Contaminant Level Goal (MCLG)</u>: The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

<u>Maximum Residual Disinfectant Level (MRDL)</u>: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

				TEST RES	ULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Inorganic (Contam	inants						
10. Barium	N	2022	.0095	.00940095	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2021	.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2022	.286	.283286	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
20. Nitrite (as Nitrogen)	N	2022	.0236	.02070236	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium	N	2021	48.1	45.3 – 48.1	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection	on By-P	roducts						
81. HAA5	N	2022	3.17	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2022	3.16	No Range	ррь	0	80	By-product of drinking water chlorination.
Chlorine	N	2022	1.1	.9 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

^{*} Most recent sample. No sample required for 2022.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

LEAD INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

VIOLATIONS

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice

about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Carnes Utility Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



CCR & URL

Cecilia Garris <cgarris@msrwa.org>

Mon, Apr 24, 2023 at 8:51 AM

To: "carnesutility2016@gmail.com" <carnesutility2016@gmail.com>

Cc: Cecilia Garris <cgarris@msrwa.org>

Good Morning,

Attached is the CCR and the URL is below.

Please let me know if you need any additional information.

Thanks

Cecilia

https://msrwa.org/2022CCR/CarnesUA.pdf

Cecilia Garris

CFO/Office Manager

MsRWA

172 Country Place Parkway

Pearl, MS 39208

PH: 601.857.2433

Fax: 601.857.2434



**AUTO PAY IS NOW AVAILABLE AT www.mypaystar.net/carnes For your convenience payment boxes are located at THE LIL' STORE and THE COUNTY LINE STORE & DELI

OFFICE HOURS ARE: MONDAY & THURSDAY ONLY 9AM – 5PM

2022 CCR is online this year the URL is: https://msrwa.org/2022CCR/CarnesUA.pdf

**CARNES UTILITY ASSOCIATION BOARD MEETING is *Monday, May 8, 2023, at 6:30 pm* at the Water Tower office. Everyone is WELCOME, Please join us.

UPCOMING COMMUNITY EVENT:

Carnes Community Clean Up Day – May 13, 2023 – 7:00 am until 2:00 pm at Carnes Community Center – 1193 Carnes Rd.

Carnes Utility Association is an Equal Opportunity Service Provider

**AUTO PAY IS NOW AVAILABLE AT www.mypaystar.net/carnes

For your convenience payment boxes are located at THE LIL' STORE and THE COUNTY LINE STORE & DELI

OFFICE HOURS ARE: MONDAY & THURSDAY ONLY 9AM - 5PM

2022 CCR is online this year the URL is: https://msrwa.org/2022CCR/CarnesUA.pdf

**CARNES UTILITY ASSOCIATION BOARD MEETING is *Monday, May 8, 2023, at 6:30*pm at the Water Tower office. Everyone is WELCOME,
Please join us.

UPCOMING COMMUNITY EVENT:

Carnes Community Clean Up Day – May 13, 2023 – 7:00 am until 2:00 pm at Carnes Community Center – 1193 Carnes Rd.

Carnes Utility Association is an Equal Opportunity Service Provider

**AUTO PAY IS NOW AVAILABLE AT www.mypaystar.net/carnes For your convenience payment boxes are located at THE LIL' STORE and THE COUNTY LINE STORE & DELI

OFFICE HOURS ARE: MONDAY & THURSDAY ONLY 9AM - 5PM

2022 CCR is online this year the URL is: https://msrwa.org/2022CCR/CarnesUA.pdf

** CARNES UTILITY ASSOCIATION BOARD MEETING is *Monday, May 8, 2023, at* 6:30 pm at the Water Tower office. Everyone is WELCOME, Please join us.

UPCOMING COMMUNITY EVENT:

Carnes Community Clean Up Day – May 13, 2023 – 7:00 am until 2:00 pm at Carnes Community Center – 1193 Carnes Rd.

Carnes Utility Association is an Equal Opportunity Service Provider

**AUTO PAY IS NOW AVAILABLE AT www.mypaystar.net/carnes

For your convenience payment boxes are located at THE LIL'STORE & DELI

OFFICE HOURS ARE: MONDAY & THURSDAY ONLY 9AM - 5PM

2022 CCR is online this year the URL is: https://msrwa.org/2022CCR/CarnesUA.pdf

**CARNES UTILITY ASSOCIATION BOARD MEETING is *Monday, May 8, 2023, at 6:30 pm* at the Water Tower office. Everyone is WELCOME, Please join us.

UPCOMING COMMUNITY EVENT:

Carnes Community Clean Up Day – May 13, 2023 – 7:00 am until 2:00 pm at Carnes Community Center – 1193 Carnes Rd.

Carnes Utility Association is an Equal Opportunity Service Provider