

RECEIVED
MSDH-WATER SUPPLY
2023 MAY -9 AM 7:47

Certification

Water systems serving 10,000 or more must use:
Distribution Method I

Water systems serving 500 - 9,999 must use:
Distribution Method I OR
Distribution Method II, III, and IV

Water system serving less than 500 people must use:
Distribution Method I OR
Distribution Method II, III, and IV OR
Distribution Method III and IV

OFFICE USE ONLY

Public Water Supply name(s): CITY OF BILOXI, CITY OF BILOXI-NORTH, CITY OF BILOXI-FRENCH, CITY OF BILOXI-MAGNOLIA BEND	7-digit Public Water Supply ID #(s): MS0240001, MS0240084, MS0240036, MS0240255
--	---

Distribution (Methods used to distribute CCR to our customers)

I. CCR directly delivered using one or more method below:

<input checked="" type="checkbox"/> *Provided direct Web address to customer <input type="checkbox"/> Hand delivered <input checked="" type="checkbox"/> Mail paper copy <input type="checkbox"/> Email	*Add direct Web address (URL) here: HTTPS://BILOXI.MS.US/RESIDENTS/WATER-QUALITY/ Example: "The current CCR is available at www.waterworld.org/ccrMay2023/0830001.pdf call (000) 000-0000 for paper copy".
<input type="checkbox"/> II. Published the complete CCR in the local newspaper.	Date(s) published:
<input checked="" type="checkbox"/> III. Inform customers the CCR will not be mailed but is available upon request. List method(s) used (examples – newspaper, water bills, newsletter, etc.).	Date(s) notified: 4/10/23 4/20/23 4/30/23 Location distributed: WATERBILLS, WEBSITE, BNEWS (YEARLY POSTED)
<input type="checkbox"/> IV. Post the complete CCR continuously at the local water office. <input type="checkbox"/> "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)	Date: Locations posted:

Certification

This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.

Name: 	Title: MAYOR, CITY OF BILOXI	Date: 5/8/23
--	---------------------------------	-----------------

Submittal

Email the following required items to water.reports@msdh.ms.gov regardless of distribution methods used.
 1. CCR (Water Quality Report) 2. Certification 3. Proof of delivery method(s)

2022 Annual Drinking Water Quality Report
City of Biloxi
PWS#: 0240001, 0240036, 0240084 & 240255
May 2023

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Contact & Meeting Information

If you have any questions about this report or concerning your water utility, please contact Tracey Forehand at 228.518.1812. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first, third, and last Tuesdays of each month at 1:30 PM at the Biloxi City Hall located at 140 Lameuse Street, Biloxi, MS. Any Information can be found on the City of Biloxi's website (Biloxi.MS.US).

Source of Water

Our water source is from wells drawing from the Pascagoula Formation, Graham Ferry Formation and the Miocene Series Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Biloxi PWS have received lower to higher susceptibility rankings to contamination.

Period Covered by Report

We routinely monitor for contaminants in your drinking water according to federal and state laws. This report is based on results of our monitoring period of January 1st to December 31st, 2022. In cases where monitoring wasn't required in 2022, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

Terms and Abbreviations

In the table you may find unfamiliar terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

Picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

PWS ID#: 0240001									TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination									
Radioactive Contaminants																	
5. Gross Alpha	N	2019*	2	1.1 – 2	pCi/L	0	15	Erosion of natural deposits									
6. Radium 226 Radium 228	N	2019*	.64 1.2	.20 - .64 .90 – 1.2	pCi/L	0	5	Erosion of natural deposits									
Inorganic Contaminants																	
7. Antimony	N	2022	3.4	No Range	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder									
8. Arsenic	N	2022	11.3	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes									
10. Barium	N	2022	.099	.0021 - .099	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits									
13. Chromium	N	2022	12.1	.6 – 12.1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits									
14. Copper	N	2019/21*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives									
15. Cyanide	N	2020*	29	No Range	ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories									
16. Fluoride	N	2022	.435	.191 - .435	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories									
17. Lead	N	2019/21*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits									
Unregulated Contaminants																	
Sodium	N	2021*	164	60.8 – 164	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.									
Disinfection By-Products																	
81. HAA5	N	2022	16.5	10.1 – 16.5	ppb	0	60	By-Product of drinking water disinfection.									
82. TTHM [Total trihalomethanes]	N	2022	53.1	34.3 – 53.1	ppb	0	80	By-product of drinking water chlorination.									
Chlorine	N	2022	1.9	.2 – 4	mg/l	0	MDRL = 4	Water additive used to control microbes									

PWS ID#: 0240036**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2022	.0023	.001 - .0023	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2022	.356	.277 - .356	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Unregulated Contaminants								
Sodium	N	2021*	90.8	79 - 90.8	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2022	34.6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2022	21.3	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2022	1.8	.5 - 3.2	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 0240084**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Gross Alpha	N	2019*	3.6	1.9 – 3.6	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2019*	.43 1.03	.20 - .43 .45 – 1.03	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2022	.0064	.0032 - .0064	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2022	1.2	.6 – 1.2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2019/21*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2022	.358	.191 - .358	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2019/21*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems. erosion of natural deposits
Unregulated Contaminants								
Sodium	N	2021*	134	68.9 - 134	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2022	15.3	15 – 15.3	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2022	22.3	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2022	1.6	.33 – 2.6	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID#: 0240255		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018*	.0071	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018*	2.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018/20*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018*	.45	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018/20*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Unregulated Contaminants								
Sodium	N	2019*	140000	No Range	ppb	0	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2018*	19	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	45.3	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2020	2.1	1– 2.5	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2022.

Sodium. EPA recommends that drinking water sodium not exceed 20 milligrams per liter (mg/L). Excess sodium from salt in the diet increases the risk of high blood pressure and cardiovascular disease.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

LEAD INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

VIOLATIONS

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however the EPA has determined that your water IS SAFE at these levels.

UNREGULATED CONTAMINANTS

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Biloxi works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



Customer Service
228.435.6236
www.biloxi.ms.us

P.O. Box 349
Biloxi, MS 39533-0349

Turn your e-mail into Bmail. Sign up at biloxi.ms.us


Customer Number	39651	Bill No: 1527901
Account Number	86017000	
Date Due	May 10, 2023	
Service Address	987 BLUFF RIDGE	
Total Amount Due	187.54	

00006042023001527901100000187542

Bill Date : Apr 20, 2023

Service	From Date	To Date	Meter No.	Previous Reading	Current Reading	Usage	Amount
WATER	03/08/2023	04/10/2023	75222393	260430	268684	8254	13.05
SEWER							26.42
GARBAGE							17.00
HCUA							31.37
HCUA DEBT REDUCTION							-4.13

The current Annual Drinking Water Quality Report is available at <https://Biloxi.ms.us/residents/water->



Billing Summary

Previous Balance	100.81
Payments Received	< 0.00 >
Adjustments	3.02
Current Charges	83.71
Total Amount Due	187.54

Customer Service # 228-435-6236

Pay Online at: biloxi.ms.us (service fee applies). Click E-Services

PLEASE DETACH AND RETURN THIS PORTION WITH PAYMENT

City of Biloxi
PO Box 349
Biloxi, MS 39533-0349

Bill No	Account Number	Customer Number	Due Date
1527901	86017000	39651	May 10, 2023
Current Charges		Account Balance	Paid Late Amount
83.71		187.54	190.17

00006042023001527901100000187542

T13 P1 5477
AUSTIN COOPER
ASHLE COOPER
504 S Gladstone Dr
VIRGINIA BEACH, VA 23452



Make Checks Payable to:

City of Biloxi
PO Box 349
Biloxi, MS 39533-0349

Pay Online at: biloxi.ms.us.
Click E-Services.