

# Certification

<u>Water systems serving 10,000 or more must use:</u> Distribution Method I  <u>Water systems serving 500 - 9,999 must use:</u> Distribution Method I OR Distribution Method II, III, and IV  <u>Water system serving less than 500 people must use:</u> Distribution Method I OR Distribution Method II, III, and IV OR Distribution Method III and IV		OFFICE USE ONLY
Public Water Supply name(s):  <b>Brazil-Sumner Water Association</b>	7-digit Public Water Supply ID #(s):  <b>0680032</b>	
<b>Distribution (Methods used to distribute CCR to our customers)</b>		
<input type="checkbox"/> I. CCR directly delivered using one or more method below:		
<input type="checkbox"/> *Provided direct Web address to customer <input type="checkbox"/> Hand delivered <input type="checkbox"/> Mail paper copy <input type="checkbox"/> Email	*Add direct Web address (URL) here:  Example: "The current CCR is available at <a href="http://www.waterworld.org/ccrMay2023/0830001.pdf">www.waterworld.org/ccrMay2023/0830001.pdf</a> call (000) 000-0000 for paper copy".	
<input type="checkbox"/> II. Published the complete CCR in the local newspaper.	Date(s) published:	
<input checked="" type="checkbox"/> III. Inform customers the CCR will not be mailed but is available upon request. List method(s) used (examples – newspaper, water bills, newsletter, etc.).	Date(s) notified: <b>5/23/2023</b>  Location distributed: <b>Water bills</b>	
<input checked="" type="checkbox"/> IV. Post the complete CCR continuously at the local water office. <input checked="" type="checkbox"/> "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)	Date: <b>5/23/2023</b> Locations posted: <b>Town Hall   Regions   US Post Office</b> <b>Sumner MS   Bank   Sumner MS</b>	
<b>Certification</b>		
This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.		
Name: <b>Toni T Clark</b>	Title: <b>Bookkeeper</b>	Date: <b>5/23/2023</b>
<b>Submittal</b>		
Email the following required items to <a href="mailto:water.reports@msdh.ms.gov">water.reports@msdh.ms.gov</a> regardless of distribution methods used. 1. CCR (Water Quality Report)      2. Certification      3. Proof of delivery method(s)		

**2022 Annual Drinking Water Consumer Confidence Report**

**Brazil-Summer Water Association**

**PWS ID # 0680032**

*Report Completed on April 25, 2023*

RECEIVED  
MSD WATER SUPPLY  
2023 APR 26 AM 10:28

We're pleased to present to you your 2022 Annual Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

**Sources of Water**

Our water source is purchased from the Town of Sumner which has 2 wells that draw from the Meridian upper Wilcox Aquifer.

**Water System Information**

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. Our water supply received a lower to moderate susceptibility ranking to contamination.

We are a small system that has an operator that takes the required water samples to ensure our water is safe to drink. Some monthly expenses incurred by our association are purchased water, salaries, repairs, water operator, computer billing software lease, insurance and a meter reader.

If you have any questions about this report or concerning your water utility, please contact Toni Clark at 662-375-8773. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for Monday, October 16, 2023 at the Sumner Town Hall, located at 145 N Walnut Street at 6:00 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31, 2022. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

## CONTAMINANT TABLE

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	MCLG	MCL	Major Sources in Drinking Water
<b>Inorganic Contaminants</b>							
13. Barium	N	2019*	0.0048 ppm	No Range	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
20. Chromium	N	2019*	1.1 ppb	No Range	100	100	Discharge from steel and pulp mills; erosion of natural deposits
21. Copper	N	1/1/18 to 12/31/20*	0.3 ppm	None	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
23. Fluoride	N	2019*	0.223 ppm	None	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
24. Lead	N	1/1/18 to 12/31/20*	3.0 ppb	No Range	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfectants &amp; Disinfectant By-Products</b>							
83. Chlorine	N	2022	1.00 ppm	1.00 to 1.00	4	4	Water additive used to control microbes
84. Haloacetic Acids HAA5	N	2022	1.02 ppb	No Range	0	60	By-product of drinking water disinfection

\* Most recent sample results available

### Definitions

In the table above you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**ppb** - parts per billion = micrograms per liter (= 1 drop in 1 billion gallons)

**ppm** - parts per million = milligrams per liter (= 1 drop in 1 million gallons)

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize

the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

### **Additional Information**

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

EPA is reviewing the drinking water standard for arsenic because of special concerns that it may not be stringent enough. Arsenic is a naturally occurring mineral known to cause cancer in humans at high concentrations.

The average household uses approximately 400 gallons of water per day. There are many low cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- ▶ Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to 50 gallons for a bath.
- ▶ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- ▶ Use a water-efficient showerhead. They are inexpensive, easy to install and can save you up to 750 gallons a month.
- ▶ Run your clothes wash and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- ▶ Water plants only when necessary.
- ▶ Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- ▶ Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- ▶ Teach your children about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- ▶ Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

Please call our office if you have any questions.

662-375-8234 or 375-8773  
 BRAZIL-SUMNER WATER ASSN, INC.  
 PO BOX 444  
 SUMNER MS 38957-0444

183220	185070	1850
PREVIOUS	PRESENT	GAL USED
METER READING		
DESCRIPTION		AMOUNT
Water		24.00
<u>2022 Annual Drinking Water          Consumer Confidence Report          available at Sumner Town Hall:          145 N Walnut; Sumner, MS</u>		24.00

DUE DATE 6/10/23  
 METER READING DAY 5/15/23  
 IF NOT PAID BY 10th 26.40  
 ACCOUNT # 132

TOTAL DUE 24.00  
 DUE DATE 6/10/23  
 METER READING DAY 5/15/23  
 IF NOT PAID BY 10th 26.40  
 ACCOUNT # 132  
 Return Service Requested  
 FLAT GRASSY FARMS  
 MARLEY HOUSE  
 560 FRIARS POINT RD  
 CLARKSDALE MS 38614