

RECEIVED
MSDH-WATER SUPPLY
2023 JUN -5 AM 11: 20

Certification

Water systems serving 10,000 or more must use:
Distribution Method I

Water systems serving 500 - 9,999 must use:
Distribution Method I OR
Distribution Method II, III, and IV

Water system serving less than 500 people must use:
Distribution Method I OR
Distribution Method II, III, and IV OR
Distribution Method III and IV

OFFICE USE ONLY

Public Water Supply name(s):	7-digit Public Water Supply ID #(s): 0020007, 0020008
------------------------------	--

Distribution (Methods used to distribute CCR to our customers)

I. CCR directly delivered using one or more method below:

<input checked="" type="checkbox"/> *Provided direct Web address to customer <input type="checkbox"/> Hand delivered <input type="checkbox"/> Mail paper copy <input type="checkbox"/> Email	*Add direct Web address (URL) here: <u>www.kossuthwater.com</u> <u>https://msr.wa.org/2022/ccr/kossuth.pdf</u> Example: "The current CCR is available at <u>www.waterworld.org/ccrMay2023/0830001.pdf</u> . call (000) 000-0000 for paper copy".
<input type="checkbox"/> II. Published the complete CCR in the local newspaper.	Date(s) published:
<input checked="" type="checkbox"/> III. Inform customers the CCR will not be mailed but is available upon request. List method(s) used (examples – newspaper, <u>water bills</u> , newsletter, etc.).	Date(s) notified: <u>5/23/2023</u> Location distributed:
<input type="checkbox"/> IV. Post the complete CCR continuously at the local water office. <input type="checkbox"/> "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)	Date: Locations posted:

Certification

This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.

Name: <u>Curtis Henry</u>	Title: <u>GM</u>	Date: <u>6-2-23</u>
---------------------------	------------------	---------------------

Submittal

Email the following required items to water.reports@msdh.ms.gov regardless of distribution methods used.
 1. CCR (Water Quality Report) 2. Certification 3. Proof of delivery method(s)

2022 Annual Drinking Water Quality Report
Kossuth Water
PWS#: 0020007 & 0020008
May 2023

2023 MAY 23 PM12:47

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Contact & Meeting Information

If you have any questions about this report or concerning your water utility, please contact Aaron C. Henry at 662.808.9500. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for Monday, June 19, 2023 at 6:00 PM at the Kossuth Water Association Office.

Source of Water

Our water source is from wells drawing from the Coffee Sand Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kossuth Water have received a lower susceptibility ranking to contamination.

Period Covered by Report

We routinely monitor for contaminants in your drinking water according to federal and state laws. This report is based on results of our monitoring period of January 1st to December 31st, 2022. In cases where monitoring wasn't required in 2022, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

Terms and Abbreviations

In the table you may find unfamiliar terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) : The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

PWS ID# 0020007

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2022	.224	.187 - .224	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2022	.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2020/22	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2022	.113	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2020/22	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Unregulated Contaminants								
Sodium	N	2021*	7.82	6.6 – 7.82	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfection By-Products								
81. HAA5	N	2022	1.63	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2022	1.41	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2022	1.4	1.3- 1.5	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID# 0020008

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2020*	.1353	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2020*	2.4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2020/22	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2020/22	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Unregulated Contaminants								
Sodium	N	2021*	8.92	No Range	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Volatile Organic Contaminants								
56. Carbon tetrachloride	N	2022	.526	No Range	ppb	0	5	Discharge from chemical plants and other industrial activities
Disinfection By-Products								
81. HAA5	N	2022	1.57	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2022	1.4	1.3 – 1.5	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2022.*

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

LEAD INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

VIOLATIONS

This public water system received a recordkeeping violation for not submitting the Annual Report by December 31, 2022. The report has since been completed and this system was returned as compliant.

UNREGULATED CONTAMINANTS

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Kossuth Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Example 3-1- CCR Certification Form
(updated with electronic delivery methods)

(suggested format)

CWS Name: Kossuth Water Association, Inc.
PWSID No: 0020007, 0020068

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state/primacy agency.

Certified by:

Name: Curtis Henry
Title: General Manager
Phone #: 661-287-4310 Date: 5/24/2023

Please check all items that apply.

CCR was distributed by mail.

CCR was distributed by other direct delivery method. Specify direct delivery methods:

Mail – notification that CCR is available on Web site via a direct uniform resource locator (URL)

E-mail – direct URL to CCR

E-mail – CCR sent as an attachment to the e-mail

E-mail – CCR sent embedded in the e-mail

Other: _____

If the CCR was provided by a direct URL, please provide the direct URL Internet address:

www. https://msrwa.org/2022CCR/Kossuth.pdf

If the CCR was provided electronically, please describe how a customer requests paper CCR delivery:

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the state/primacy agency:

- posting the CCR on the Internet at [www. https://msrwa.org/2022_CCR/Kassutho.pdf](https://msrwa.org/2022_CCR/Kassutho.pdf)
- mailing the CCR to postal patrons within the service area (attach a list of zip codes used)
- advertising availability of the CCR in news media (attach copy of announcement)
- publication of CCR in local newspaper (attach copy of newspaper announcement)
- posting the CCR in public places (attach a list of locations)
- delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers
- delivery to community organizations (attach a list)
- electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)

(for systems serving at least 100,000 persons) Posted CCR on a publicly-accessible Internet site at the address: www._____

Delivered CCR to other agencies as required by the state/primacy agency (attach a list)



KOSSUTH WATER ASSOCIATION
 P.O. BOX 8080, CORINTH, MS 38835
 (662) 267-4310

**RETURN
 SERVICE
 REQUESTED**

FIRST-CLASS MAIL-AUTO
 U.S. POSTAGE
 PAID
 CORINTH, MS 38834
 PERMIT NO. 354

6820		5/23/2023		
SERVICES	Current	Meter Readings Previous	Usage	CHARGES
Total Due				\$0.00

CUSTOMER ACCOUNT	DUE DATE FIRST DUE AFTER THIS DATE
6820	6/15/2023

TOTAL DUE UPON RECEIPT
0.00

MAIL THIS STUB WITH YOUR PAYMENT

WALKER DONNIE JR(f11-19
 1532 Front Street
 Binghamton NY 13901-5505

For access to Consumer Confident report you will need to go to <https://msrwa.org/2022ccr/Kossuth.pdf>

From 10/14/2019 TO
 11/14/2019