


2023 MAY 32 AM 8:49

Certification

<u>Water systems serving 10,000 or more must use:</u> Distribution Method I <u>Water systems serving 500 - 9,999 must use:</u> Distribution Method I OR Distribution Method II, III, and IV <u>Water system serving less than 500 people must use:</u> Distribution Method I OR Distribution Method II, III, and IV OR Distribution Method III and IV		OFFICE USE ONLY
Public Water Supply name(s): Collinsville Water Association	7-digit Public Water Supply ID #(s): 0380002	
Distribution (Methods used to distribute CCR to our customers)		
<input type="checkbox"/> I. CCR directly delivered using one or more method below:		
<input checked="" type="checkbox"/> *Provided direct Web address to customer <input type="checkbox"/> Hand delivered <input type="checkbox"/> Mail paper copy <input type="checkbox"/> Email	*Add direct Web address (URL) here: www.ccr39325.com Example: "The current CCR is available at www.waterworld.org/ccrMay2023/0830001.pdf . call (000) 000-0000 for paper copy".	
<input type="checkbox"/> II. Published the complete CCR in the local newspaper.	Date(s) published:	
<input checked="" type="checkbox"/> III. Inform customers the CCR will not be mailed but is available upon request. List method(s) used (examples – newspaper, <u>water bills</u> , newsletter, etc.).	Date(s) notified: 5/30/23	
	Location distributed:	
<input type="checkbox"/> IV. Post the complete CCR continuously at the local water office. <input type="checkbox"/> "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)	Date:	
	Locations posted:	
Certification		
This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.		
Name: 	Title: Office Manager	Date: 5/30/2023
Submittal		
Email the following required items to water.reports@msdh.ms.gov regardless of distribution methods used. 1. CCR (Water Quality Report) 2. Certification 3. Proof of delivery method(s)		

2022 Annual Drinking Water Consumer Confidence Report
Collinsville Water Association
PWS ID # 0380002

Report Completed on May 9, 2023

We're pleased to present to you your 2022 Annual Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Sources of Water

Our water source consists of 4 wells that draw from the Lower Wilcox Aquifer.

Water System Information

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. Our water supply received a lower susceptibility ranking to contamination.

This past year we invested \$85,000 into rehabbing the well at the Martin Water Treatment Plant. We continued the meter change out program to replace aged residential meters. Our Board of Directors voted to move forward with a \$5 million project to build a new treatment plant and an elevated tank.

If you have any questions about this report or concerning your water utility, please contact Cody Anderson at 601-626-8138. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Thursday of each month at the Collinsville Water Association office at 11718 Nancy Drive at 2:30 pm.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31, 2022. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

CONTAMINANT TABLE

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	MCLG	MCL	Major Sources in Drinking Water
Inorganic Contaminants							
13. Barium	N	2020*	0.098 ppm	0.0903 to 0.098	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
20. Chromium	N	2020*	0.80 ppb	0.50 to 0.80	100	100	Discharge from steel and pulp mills; erosion of natural deposits
21. Copper	N	1/1/18 to 12/31/20*	0.1 ppm	None	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
23. Fluoride	N	2020*	0.747 ppm	0.211 to 0.747	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
26. Nitrate (as Nitrogen)	N	2022	0.119 ppm	0.08 to 0.119	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products							
83. Chlorine	N	2022	1.40 ppm	0.99 to 1.78	4	4	Water additive used to control microbes
84. Haloacetic Acids HAA5	N	2022	2.17 ppb	No Range	0	60	By-product of drinking water disinfection

* Most recent sample results available

UNREGULATED CONTAMINANTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	MCLG	MCL	Major Sources in Drinking Water
Sodium	N	2022	9330 ppb	No Range	0	250000	Road salt, water treatment chemicals, water softeners and sewage effluents

Explanation of Reasons for Monitoring Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Definitions

In the table above you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:
Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
ppb - parts per billion = micrograms per liter (= 1 drop in 1 billion gallons)
ppm - parts per million = milligrams per liter (= 1 drop in 1 million gallons)

Fluoride Information

To comply with the “Regulation Governing Fluoridation of Community Water Supplies”, Collinsville Water Association is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which the average fluoride sample results were within the optimal range of 0.6 - 1.2 ppm was 1. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 - 1.2 ppm was 50%. The number of months samples were collected and analyzed in the previous calendar year was 2.

Note: This system adds fluoride to your drinking water to help prevent and reduce cavities and improve overall oral health. Supply-chain issues have limited or prevented this water system’s ability to obtain fluoride on a regular basis. The date presented above only reflects the months when this water system added fluoride to your drinking water.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Additional Information

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

EPA is reviewing the drinking water standard for arsenic because of special concerns that it may not be stringent enough. Arsenic is a naturally occurring mineral known to cause cancer in humans at high concentrations.

The average household uses approximately 400 gallons of water per day. There are many low cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- ▶ Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to 50 gallons for a bath.
- ▶ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- ▶ Use a water-efficient showerhead. They are inexpensive, easy to install and can save you up to 750 gallons a month.
- ▶ Run your clothes wash and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- ▶ Water plants only when necessary.
- ▶ Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- ▶ Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- ▶ Teach your children about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- ▶ Visit www.epa.gov/watersense for more information.

Please call our office if you have any questions.

SEND PAYMENT TO:
COLLINSVILLE WATER ASSOC.
 P.O. BOX 67
 COLLINSVILLE, MS 39325
 (601) 626-8138

PRESORTED
 FIRST CLASS MAIL
 U.S. POSTAGE
 PAID
 COLLINSVILLE, MS
 PERMIT NO. 3

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
	Previous Balance			0.00
WATER	201543	194448	7095	68.31
SEWER	0	0	0	0.00

CUSTOMER		PAY GROSS AMOUNT AFTER THIS DATE
ROUTE	ACCOUNT	
1	4455	06/10/2023
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID
68.31		75.14

Important information about your drinking water is available in the 2022 CCR at www.CCR39325.com or you may contact the water office for a hard copy.

MAIL THIS STUB WITH YOUR PAYMENT
 Return Service Requested

Bank Draft -- Do Not Pay.
 9580 GIPSON ROAD

BRAD PARTEN
 9580 GIPSON ROAD
 COLLINSVILLE, MS 39325-

METER READ		CLASS	TOTAL DUE UPON RECEIPT	PAY GROSS AMOUNT AFTER THIS DATE	GROSS AMOUNT TO BE PAID
MONTH	DAY				
5	22		68.31	06/10/2023	75.14

Collinsville Water Association

Copy

P.O. Box 67 ~ 11718 Nancy Drive ~ Collinsville, MS 39325
COLLINSVILLEWATER.NET 601-626-8138

WAIDE & LINDA COOK
P.O. BOX 65
COLLINSVILLE, MS 39325-

Account Information

Account Number 7940
Location Number 9214WL
Service Address 9214 WEST LAUDERDALE ROAD
Statement Date 05/30/2023
Due Date 06/10/2023
Total Due 25.00

Special Message

Recurring Payment - Do Not Pay

Current Charges and Service Information

Service	Service Period	Prior & Current Read	Usage	Charge
Balance Forward				25.00
WATER	04/20/2023 05/22/2023	108590 110180	1590	25.00
SEWER				0.00
Payment				-25.00

Total Due By 06/10/2023 25.00
Total Due After 06/10/2023 27.50

Important information about your drinking water is available at www.CCR39325.com
or you may contact the water office for a hard copy.

Please return bottom portion along with your payment

Collinsville Water Association
11718 Nancy Drive, COLLINSVILLE, MS 39325

Account Information

Account Number 7940
Location Number 9214WL
Service Address 9214 WEST LAUDERDALE ROAD
Statement Date 05/30/2023
Due Date 06/10/2023
Total Due 25.00

WAIDE & LINDA COOK
P.O. BOX 65
COLLINSVILLE, MS 39325-

Remit To:

Collinsville Water Association
P.O. Box 67
Collinsville, MS 39325

Cockrell, Joan

From: Collinsville Water <collinsvillewater@comcast.net>
Sent: Wednesday, May 31, 2023 3:56 PM
To: reports, water
Subject: RE: Collinsville Water Association CCR 2022
Attachments: Collinsville WA - CCR.pdf; Collinsville WA - Certification Form.pdf; Postcard and ebill CCR notice 2022.pdf

Importance: High

See attached CCR, Certification and Proof of Delivery.
Previous Certification sent was saved incomplete, please disregard it.

Jana Mayatt

P.O. Box 67
11718 Nancy Dr.
Collinsville, MS 39325
601.626.8138 Office
601.626.7106 Fax
CollinsvilleWater.net
CollinsvilleWater@Comcast.net



From: Collinsville Water <collinsvillewater@comcast.net>
Sent: Wednesday, May 31, 2023 3:32 PM
To: 'water.reports@msdh.ms.gov' <water.reports@msdh.ms.gov>
Subject: Collinsville Water Association CCR 2022
Importance: High

See attached CCR, Certification and Proof of delivery.

Jana Mayatt

P.O. Box 67
11718 Nancy Dr.
Collinsville, MS 39325
601.626.8138 Office
601.626.7106 Fax
CollinsvilleWater.net
CollinsvilleWater@Comcast.net