

RECEIVED  
MSDH-WATER SUPPLY  
2023 JUN -6 AM 10: 57

# Certification

Water systems serving 10,000 or more must use:  
Distribution Method I

Water systems serving 500 - 9,999 must use:  
Distribution Method I OR  
Distribution Method II, III, and IV

Water system serving less than 500 people must use:  
Distribution Method I OR  
Distribution Method II, III, and IV OR  
Distribution Method III and IV

OFFICE USE ONLY

Public Water Supply name(s): Beat III Greene County Water System, Inc.	7-digit Public Water Supply ID #(s): 21-00001
---	--

**Distribution (Methods used to distribute CCR to our customers)**

**I. CCR directly delivered using one or more method below:**

<input checked="" type="checkbox"/> *Provided direct Web address to customer <input type="checkbox"/> Hand delivered <input type="checkbox"/> Mail paper copy <input type="checkbox"/> Email	*Add direct Web address (URL) here: <a href="http://ccrwater.net/beat3gcwater-147076">http://ccrwater.net/beat3gcwater-147076</a> Example: "The current CCR is available at <a href="http://www.waterworld.org/ccrMay2023/0830001.pdf">www.waterworld.org/ccrMay2023/0830001.pdf</a> . call (000) 000-0000 for paper copy".
---	---

**II. Published the complete CCR in the local newspaper.** Date(s) published:

**III. Inform customers the CCR will not be mailed but is available upon request.** Date(s) notified:  
5/30/2023  
List method(s) used (examples – newspaper, water bills, newsletter, etc.). Location distributed:  
Water Bills

**IV. Post the complete CCR continuously at the local water office.** Date:  
 "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.) Locations posted:

**Certification**

This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.

Name: Peggy Maxie	Title: Manager/Water Operator	Date: 5/30/2023
----------------------	----------------------------------	--------------------

**Submittal**

Email the following required items to [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov) regardless of distribution methods used.  
1. CCR (Water Quality Report)      2. Certification      3. Proof of delivery method(s)

**2022 Annual Drinking Water Quality Report**  
**Beat III Greene County Water System, Inc.**  
**PWS#: 0210001**  
**May 2023**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

**Contact & Meeting Information**

If you have any questions about this report or concerning your water utility, please contact Peggy Maxie at 601.381.1403. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday of each month at 6:30 PM at the water office in Sand Hill.

**Source of Water**

Our water source is from wells drawing from the Catahoula Formation Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Beat III Greene County Water System, Inc. have received a lower to moderate susceptibility ranking to contamination.

**Period Covered by Report**

We routinely monitor for contaminants in your drinking water according to federal and state laws. This report is based on results of our monitoring period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022. In cases where monitoring wasn't required in 2022, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

**Terms and Abbreviations**

In the table you may find unfamiliar terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) : The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

PWS ID#: 0210001		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2022	.0347	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2018/20*	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2018/20*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Unregulated Contaminants</b>								
Sodium	N	2021*	2.19	2.18 – 2.19	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
<b>Disinfection By-Products</b>								
Chlorine	N	2022	1.4	.93 – 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2022.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

#### LEAD INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

#### VIOLATIONS

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however the EPA has determined that your water IS SAFE at these levels.

#### UNREGULATED CONTAMINANTS

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Beat III Greene County Water System, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010013000	04/15	05/15
SERVICE ADDRESS		
79 VIRGILS LANE		
CURRENT	METER READINGS PREVIOUS	USED
257	264	3
CHARGE FOR SERVICES		

RETURN THIS STUB WITH PAYMENT TO:  
**BEAT 3 GREENE COUNTY WATER SYSTEM**  
 39560 HWY. 63 NORTH  
 RICHTON, MS 39476  
 www.beat3gcwater.com

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 15  
 RICHTON, MS

PAY NET AMOUNT ON RECEIPT OF BILL	DUE DATE	PAY GROSS AMOUNT AFTER THE 15TH
	06/10/2023	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
70.88	3.10	73.98

<http://ccrwater.net/beat3gcwater-147076> CALL FOR PAPER COPY

WTR	31.04
BT3	1.00
INS	1.85
PAST DUE	36.99
NET DUE >>>	70.88
SAVE THIS >>	3.10
GROSS DUE >>	73.98

**RETURN SERVICE REQUESTED**

010013000  
 PHYLLIS # 2 ELMORE  
 2466 PIAVE CHURCH ROAD  
 RICHTON MS 39476-7894



**USPS Generated**

Note to Mailer: Your electronic postage statement has been submitted to the USPS PostalOne! system on May 31, 2023 09:04 AM.

The labels and electronic mailing information associated to this form, must match the physical mailing being presented to the USPS® with this form.

Postage Statement ID: 547466828  
 Post Office of Permit: Post Office Richton MS 39476-9998  
 Mailing Group ID: 414082363  
 Account Holder: BEAT 3 GREENE COUNTY WATER ASSN  
 Account Number: 1624575  
 Permit Holder: BEAT 3 GREENE COUNTY WATER ASSN  
 Permit Type and Number: PI 15  
 Mail Agent: BEAT 3 GREENE COUNTY WATER ASSN  
 Mail Owner Name: BEAT 3 GREENE COUNTY WATER ASSN  
 Mail Owner's Permit Type and Number:  
 CRID: 3979279  
 Customer Reference ID:  
 Mail Class and Price Eligibility: First-Class - Regular  
 Processing Category: PostCards only  
 Single Piece Weight Declared by Mailer: 0.0050 lbs (.08 oz)  
 Total Mail Pieces: 1,315 pieces  
 Total Weight: 6.5750 lbs  
 Total Postage Amount: \$517.45  
 Permit Account for Insufficient Affixed Postage:  
 Total Postage Affixed: \$0.00  
 Total Postage Due: ~~\$517.45~~  
 Handling Unit :

1' MM Trays	2' MM Trays	2' EMM Trays	Flat Trays	Sacks	Pallets	Other
4						

**Important: Please bring your mailing by - Jun 07, 2023**

**Post Office of Mailing**  
 BMEU RICHTON 201 FRONT ST  
 RICHTON, MS 394769998

**Hours**  
 Mon 08:30 AM - 02:00 PM  
 Tue 08:30 AM - 02:00 PM  
 Wed 08:30 AM - 02:00 PM  
 Thu 08:30 AM - 02:00 PM  
 Fri 08:30 AM - 02:00 PM  
 Sat Closed  
 Sun Closed

**Note:**

- \*This mailing may be subject to additional verification at the time of acceptance.
- \*This mailing cannot be processed at the self service terminal.

**SCAN AT ACCEPTANCE**



9275 7900 0000 0000 5474 6682 87



RICHTON  
201 FRONT ST  
RICHTON, MS 39476-9998  
(800)275-8777

05/31/2023 11:04 AM

Product	Qty	Unit Price	Price
---------	-----	------------	-------

Cust Permit Dep			\$517.45
Permit Type: Permit Imprint			
Permit Number: 15			
Permit Acct Number: 1624575			
Customer Name: BEAT 3 GREENE COUNTY WATER ASSN			

Grand Total: \$517.45

Personal/Bus Check \$517.45

Preview your Mail  
Track your Packages  
Sign up for FREE @  
<https://informedelivery.usps.com>

All sales final on stamps and postage.  
Refunds for guaranteed services only.  
Thank you for your business.

Tell us about your experience.  
Go to: <https://postalexperience.com/Pos>  
or scan this code with your mobile device.



or call 1-800-410-7420.

UFN: 276799-0476  
Receipt #: 840-53900343-1-3721764-1  
Clerk: 05



RICHTON  
201 FRONT ST  
RICHTON, MS 39476-9998  
(800)275-8777

05/31/2023 11:05 AM

Product	Qty	Unit Price	Price
---------	-----	------------	-------

Ship Confirm Accept	1		\$0.00
Tracking #:			
9275 7900 0000 0000 5474 6682 87			

Grand Total: \$0.00

Preview your Mail  
Track your Packages  
Sign up for FREE @  
<https://informedelivery.usps.com>

All sales final on stamps and postage.  
Refunds for guaranteed services only.  
Thank you for your business.

Tell us about your experience.  
Go to: <https://postalexperience.com/Pos>  
or scan this code with your mobile device.



or call 1-800-410-7420.

UFN: 276799-0476  
Receipt #: 840-53900343-1-3721782-1  
Clerk: 05