

Corrected

RECEIVED  
MSDH-WATER SUPPLY

2023 JUN 29 PM 4:11

# Certification

Water systems serving 10,000 or more must use:  
Distribution Method I

Water systems serving 500 - 9,999 must use:  
Distribution Method I OR  
Distribution Method II, III, and IV

Water system serving less than 500 people must use:  
Distribution Method I OR  
Distribution Method II, III, and IV OR  
Distribution Method III and IV

OFFICE USE ONLY

Public Water Supply name(s):

City of Hattiesburg

7-digit Public Water Supply ID #(s):

0180008

## Distribution (Methods used to distribute CCR to our customers)

I. CCR directly delivered using one or more method below:

- \*Provided direct Web address to customer
- Hand delivered
- Mail paper copy
- Email

\*Add direct Web address (URL) here:

http://www.hattiesburgms.com/  
wp-content/uploads/Water-  
Consumer-Confidence-Report-2022.pdf

II. Published the complete CCR in the local newspaper.

For paper copy call:  
601-545-4630

III. Inform customers the CCR will not be mailed but is available upon request.

List method(s) used (examples - newspaper, water bills, newsletter, etc.).

Date(s) notified:

Location distributed:

IV. Post the complete CCR continuously at the local water office.

"Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)

Date:

Locations posted:

## Certification

This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.

Name:



Title:

Director

Date:

6/29/23

## Submittal

Email the following required items to [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov) regardless of distribution methods used.

1. CCR (Water Quality Report)
2. Certification
3. Proof of delivery method(s)

**City of Hattiesburg**

**0180008**

**2022**

**Drinking Water Quality Report**

**Spanish (Español)**

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

**Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**

The City of Hattiesburg get its water from 15 deep wells in the miocene aquifer system.

**Source water assessment and its availability**

Hattiesburg's source water assessment is available by visiting the State Health Department web site

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

The Hattiesburg water system is owned and operated by the the City. and the Mayor and Counsel meet the first Tuesday of each month, and welcomes public input and commit

## Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water

distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

## Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

## Other Information

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", The City of Hattiesburg is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6 --1.2 ppm was 3. The percentage of fluoride samples

collected in the previous calendar year that was within the optimal range of 0.6--1.2 ppm was 15%. The number of months samples were collected and analyzed in the previous calendar year was 9 .

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Hattiesburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### **Additional Information for Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

---

### **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is

not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	1.70	.6	2.2	2022	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	60	60	6.21			2022	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	80	80	5.53	2.24	5.53	2022	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Antimony (ppb)	.006	.006	ND	.0005	.0005	2022	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	.010	.010	ND	.0005	.0005	2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.0742	.0417	.0742	2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	.004	.004	ND	.0005	.0005	2022	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	.005	.005	ND	.0005	.0005	2022	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	0.1	0.1	ND	.0005	.0005	2022	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.152	0.1	0.152	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Mercury [Inorganic] (ppb)	.002	.002	ND	.0005	.0005	2022	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	.08	.08	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	.02	.02	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	.05	.05	ND	.0025	.0025	2022	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	.002	.002	ND	.0005	.0005	2022	No	Discharge from electronics, glass, and Leaching from ore- processing sites; drug factories
<b>Volatile Organic Contaminants</b>								
1,1,1-Trichloroethane (ppb)	200	200	ND	0.5	0.5	2022	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	ND	.05	.05	2022	No	Discharge from industrial chemical factories
1,2-Dichloroethane (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
Benzene (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from chemical plants and other industrial activities
Chlorobenzene ( )	100	100	ND	0.5	0.5	2022	No	Discharge from chemical and
Dichloromethane (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	ND	.05	0.5	2022	No	Discharge from petroleum

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
								refineries
Styrene (ppb)	100	100	ND	0.5	0.5	2022	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from factories and dry cleaners
Toluene (ppm)	1000	0001	ND	0.5	0.5	2022	No	Discharge from petroleum factories
Trichloroethylene (ppb)	5	5	ND	0.5	0.5	2022	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	2	2	ND	0.5	0.5	2022	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10000	10000	ND	0.5	0.5	2022	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	ND	0.5	0.5	2022	No	Discharge from industrial chemical factories
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	1	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	3	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected



<b>Unit Descriptions</b>	
NR	NR: Monitoring not required, but recommended.

<b>Important Drinking Water Definitions</b>	
<b>Term</b>	<b>Definition</b>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: Jeff Byrd  
Address: 900 James Street  
Hattiesburg, MS 39401  
Phone: 601-545-4530

# Consumer Confidence Report Certification Form

(updated with electronic delivery methods)

RECEIVED  
PUBLIC WATER SUPPLY  
June 02  
2023 MAY 33 AM 8:07

(suggested format)

CWS Name: City of Hattiesburg

PWSID No: 0180008

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state/primacy agency.

Certified by:

Name: Alan Howe

Title: Director

Phone #: 601-408-0586 Date: 5/15/2023

Please check all items that apply.

CCR was distributed by mail.

CCR was distributed by other direct delivery method. Specify direct delivery methods:

Mail – notification that CCR is available on website via a direct URL

Email – direct URL to CCR

Email – CCR sent as an attachment to the email

Email – CCR sent embedded in the email

Other: \_\_\_\_\_

Not direct!  
↓

If the CCR was provided by a direct URL, please provide the direct URL Internet address:

www.hattiesburgms.com/cityservices/water-sewer/

If the CCR was provided electronically, please describe how a customer requests paper CCR delivery:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

"Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the state/primacy agency:

posting the CCR on the Internet at www.hattiesburgms.com/city services/  
Water-sewer

mailing the CCR to postal patrons within the service area (attach a list of zip codes used)

advertising availability of the CCR in news media (attach copy of announcement)

publication of CCR in local newspaper (attach copy)

posting the CCR in public places (attach a list of locations)

delivery of multiple copies to single bill addresses serving several persons such as:  
apartments, businesses, and large private employers

delivery to community organizations (attach a list)

electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)

electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)

(for systems serving at least 100,000 persons) Posted CCR on a publicly-accessible Internet site at the address: www.\_\_\_\_\_

Delivered CCR to other agencies as required by the state/primacy agency (attach a list)

# City of Hattiesburg

0180008

2022

## Drinking Water Quality Report

### Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúscalo o hable con alguien que lo entienda bien.

### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

### Where does my water come from?

The City of Hattiesburg get its water from 15 deep well in the miocene aquifer system.

## **Source water assessment and its availability**

Hattiesburg's source water assessment is available by visiting the State Health Department web site

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## **How can I get involved?**

The Hattiesburg water system is owned and operated by the the City. and the Mayor and Counsel meet the first Tuesday of each month, and welcomes public input and commit

## **Cross Connection Control Survey**

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

### **Source Water Protection Tips**

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

### **Other Information**

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", The City of Hattiesburg is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6 --1.2 ppm was 3. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6--1.2 ppm was 15%. The number of months samples were collected and analyzed in the previous calendar year was 9 .

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Hattiesburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### **Additional Information for Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

---

## **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased

protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, FT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	.6	.6	2.2	2022	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	6.21	2.81	6.21	2022	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	5.53	2.24	5.53	2022	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Antimony (ppb)	6	6	.0005	.0005	5	2022	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	.0005	NA	NA	2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.0417	.0417	72	2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	.0005	NA	NA	2022	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	.0005	NA	NA	2022	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	.0005	NA	NA	2022	No	Discharge from steel and pulp mills; Erosion of natural deposits



Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Fluoride (ppm)	4	4	.152	.145	1	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	.0005	NA	NA	2022	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	NA	NA	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	NA	NA	2022	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	.05	NA	NA	2022	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	.5	2	.0005	NA	NA	2022	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
<b>Volatile Organic Contaminants</b>								
1,1,1-Trichloroethane (ppb)	200	200	.5	NA	NA	2022	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	.5	NA	NA	2022	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	.5	NA	NA	2022	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	.05	NA	NA	2022	No	
1,2-Dichloroethane (ppb)	0	5	.5	NA	NA	2022	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	.5	NA	NA	2022	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	.5	NA	NA	2022	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	.5	NA	NA	2022	No	Discharge from chemical plants and other industrial activities
Chlorobenzene ( )	100	100	.5	NA	NA	2022	No	Discharge from chemical and

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Dichloromethane (ppb)	0	5	.5	NA	NA	2022	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	.5	NA	NA	2022	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	.5	NA	NA	2022	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	.5	NA	NA	2022	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	.5	NA	NA	2022	No	Discharge from petroleum factories
Trichloroethylene (ppb)	0	5	.5	NA	NA	2022	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	.5	NA	NA	2022	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	.5	NA	NA	2022	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	.5	NA	NA	2022	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	.5	NA	NA	2022	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	.5	NA	NA	2022	No	Discharge from industrial chemical factories
trans-1,2-Dichloroethylene (ppb)	100	100	.5	NA	NA	2022	No	Discharge from industrial chemical factories
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	1.3	2019		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	.015	2019		No	Corrosion of household plumbing systems; Erosion of natural deposits	

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)

Unit Descriptions	
ppb	ppb: parts per billion, or micrograms per liter ( $\mu\text{g/L}$ )
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Jeff Byrd  
 Address: 900 James Street  
 Hattiesburg, MS 39401  
 Phone: 601-545-4530

**Consumer Confidence Report**

**Posted in the Public Buildings located below:**

**City Hall**

**Forrest County Library**

**Water Billing Office**

**Water Plant #2**



# WATER BILLING STATEMENT FINAL NOTICE

WATER BILLING OFFICE  
Office: 105 South Park Ave Hattiesburg MS 39401  
Mailing: PO Box 1897 Hattiesburg MS 39403-1897  
Phone: 601-545-4634

Office Hours  
Lobby: 8 AM - 4 PM  
Drive-Thru: 8 AM - 5 PM  
Mon-Fri (Except Holidays)

## SERVICE DETAILS

CUSTOMER NAME: AM EQUITY REALTY  
ACCOUNT NUMBER: 85625  
SERVICE ADDRESS: 5328 HWY 42  
SERVICE PERIOD: 6/13/2023  
BILLING DATE: 6/18/2023

## ACCOUNT BALANCE SUMMARY

PAST DUE BALANCE: \$69.71  
CURRENT CHARGES: \$69.71  
**TOTAL AMOUNT DUE: \$139.42**

METER #	PREVIOUS READ	CURRENT READ	USAGE
130300416	2	3	1

DUE DATE: 7/3/2023  
DELINQUENT DATE: 7/3/2023

### CURRENT CHARGES BREAKDOWN

WATER	\$21.60
SEWER	\$21.60
GARBAGE	\$25.00
TAX	\$1.51
<b>TOTAL CURRENT CHARGES</b>	<b>\$69.71</b>

### NOTICE: IF YOU HAVE A PAST DUE BALANCE

Payments not received on customer account by the delinquent date will be disconnected and have a service fee applied.

See reverse side for list of payment options.

## CITY NEWS AND NOTES


### NEWS

For the latest news regarding major announcements, project updates and more – visit [hattiesburgms.com/news](http://hattiesburgms.com/news)

To view the 2022 Water Quality Report visit :  
<https://www.hattiesburgms.com/wp-content/uploads/Water-Consumer-Confidence-Report-2022.pdf>

## CONSUMPTION GRAPH

6 MONTH WATER USAGE (USAGE LISTED IN THE THOUSANDS OF GALLONS)



Please detach and return bottom portion of bill with payment.

## PAYMENT COUPON



Water Billing Office  
PO Box 1897  
Hattiesburg, MS 39403-1897

### FINAL NOTICE

ACCOUNT NUMBER: 85625  
PAST DUE BALANCE: \$69.71  
CURRENT BALANCE: \$69.71  
**TOTAL AMOUNT DUE: \$139.42**  
DUE DATE: 7/3/2023

TOTAL AMOUNT ENCLOSED: \_\_\_\_\_

RETURN SERVICE REQUESTED

AM EQUITY REALTY  
5328 HWY 42  
HATTIESBURG MS 39401

Please remit and make checks payable to:

CITY OF HATTIESBURG  
PO BOX 1897  
HATTIESBURG MS 39403-1897



Change of address  
Enroll for Auto Bank Draft