

2023 JUN -9 AM 7:29

# Certification

Water systems serving 10,000 or more must use:  
 Distribution Method I

Water systems serving 500 - 9,999 must use:  
 Distribution Method I OR  
 Distribution Method II, III, and IV

Water system serving less than 500 people must use:  
 Distribution Method I OR  
 Distribution Method II, III, and IV OR  
 Distribution Method III and IV

OFFICE USE ONLY

Public Water Supply name(s):  
 North Pike Water Association, Inc.

7-digit Public Water Supply ID #(s):  
 0570008

**Distribution** (Methods used to distribute CCR to our customers)

I. CCR directly delivered using one or more method below:

- \*Provided direct Web address to customer
- Hand delivered
- Mail paper copy
- Email

\*Add direct Web address (URL) here:  
 Example: "The current CCR is available at [www.waterworld.org/ccrMay2023/0830001.pdf](http://www.waterworld.org/ccrMay2023/0830001.pdf). call (000) 000-0000 for paper copy".

II. Published the complete CCR in the local newspaper.

Date(s) published:  
 June 6, 2023

III. Inform customers the CCR will not be mailed but is available upon request.  
 List method(s) used (examples – newspaper, water bills, newsletter, etc.).

Date(s) notified:  
 May 31, 2023  
 Location distributed:  
 Newspaper

IV. Post the complete CCR continuously at the local water office.  
 "Good Faith Effort" in other public buildings with the water system service area (i.e. City Hall, Public Library, etc.)

Date: June 14, 2023  
 Locations posted:  
 Water office

**Certification**

This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and the appropriate notices of availability have been given and that the information contained in its CCR is correct and consistent with the compliance monitoring data previously submitted to the MS State Department of Health, Bureau of Public Water Supply and the requirements of the CCR rule.

Name:  
 Mark Wallace

Title:  
 President

Date:  
 8-8-23

**Submittal**

Email the following required items to [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov) regardless of distribution methods used.  
 1. CCR (Water Quality Report)      2. Certification      3. Proof of delivery method(s)

2022 Annual Drinking Water Quality Report  
North Pike Water Association, Inc.  
PWS#: 0570008  
May 2023

RECEIVED  
MSDH-WATER SUPPLY  
2023 JUN 15 PM 12:43

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

#### About Our System

North Pike Water Association, Inc. has an approximately population of 5,383 and 1794 metered connections. We have four board members and have completed the required Board Management Training. Our water district has one certified Class C operator. Rates are looked at on a yearly basis and adjusted accordingly. Long term plans are to identify and upgrade water lines where needed.

#### Contact & Meeting Information

If you have any questions about this report or concerning your water utility, please contact David Gunther at 601.684.7399. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:00 PM at 705 East Railroad Ave., Summit, MS 39666.

#### Source of Water

Our water source is from wells drawing from the Citronelle Formation and the Miocene Series Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the North Pike Water Association, Inc. have received lower to higher susceptibility rankings to contamination.

#### Period Covered by Report

We routinely monitor for contaminants in your drinking water according to federal and state laws. This report is based on results of our monitoring period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022. In cases where monitoring wasn't required in 2022, the table reflects the most recent testing done in accordance with the laws, rules, and regulations.

As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

#### Terms and Abbreviations

In the table you may find unfamiliar terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per billion (ppb) or micrograms per liter: one part by weight of analyte to 1 billion parts by weight of the water sample.

Parts per million (ppm) or Milligrams per liter (mg/l): one part by weight of analyte to 1 million parts by weight of the water sample.

Picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

## TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Gross Alpha	N	2018*	1.8	No Range	pCi/L	0	15	Erosion of natural deposits
6. Radium 226	N	2018*	.34	No Range	pCi/L	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
8. Arsenic	N	2022	3.8	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2022	.0536	.0263 - .0536	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2020/22	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2022	.1	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2020/22	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2022	.166	.125 - .166	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Unregulated Contaminants</b>								
Sodium	N	2022	21.3	6.54 – 21.3	ppm	20	0	Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
<b>Disinfection By-Products</b>								
Chlorine	N	2022	1.3	1.1 – 1.5	mg/l	0	MDRL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2022.

Sodium. EPA recommends that drinking water sodium not exceed 20 milligrams per liter (mg/L). Excess sodium from salt in the diet increases the risk of high blood pressure and cardiovascular disease.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

### LEAD INFORMATION

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

### VIOLATIONS

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however the EPA has determined that your water IS SAFE at these levels.

### UNREGULATED CONTAMINANTS

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water,

may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The North Pike Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. A copy of this report will not be mailed to each customer.

STATE OF MISSISSIPPI,  
COUNTY OF PIKE

PERSONALLY CAME before me, the undersigned, a notary public in and for PIKE County, Mississippi, the CLERK of the McCOMB ENTERPRISE-JOURNAL, a newspaper published in the City of McComb, Pike County, in said state who being duly sworn, deposes and says that the McCOMB ENTERPRISE-JOURNAL is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy in the

matter of 2022 Annual Drinking Water  
Quality Report  
North Pike Water Assoc.

has been made in said paper 1 times consecutively, to wit:

On the 6th day of June, 20 23

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

On the \_\_\_\_\_ day of \_\_\_\_\_, 20 \_\_\_\_\_

SWORN TO and subscribed before me, this

6th day of June, 20 23

Linda Gentry  
Notary Public

Vicki Renee  
Clerk

My Commission Expires: June 24, 2025

McComb, Miss. \_\_\_\_\_, 20 \_\_\_\_\_

To McComb Enterprise-Journal

TO PUBLISHING \_\_\_\_\_

case of \_\_\_\_\_

\_\_\_\_\_ words space \_\_\_\_\_

\_\_\_\_\_ times and making proof, \$ 935.00

RECEIVED OF \_\_\_\_\_

payment in full of the above account.

\_\_\_\_\_, 20 \_\_\_\_\_





**NORTH PIKE WATER ASSOCIATION**  
 P.O. BOX 4181 SUMMIT, MISSISSIPPI 39666  
 (601) 234-7188

**RETURN  
 SERVICE  
 REQUESTED**

POSTAGE  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 SUMMIT, MS 39666  
 PERMIT NO. 17

4419 5/31/2023 4192 MAGNOLIA PISGAH

SERVICES	Current	Meter Readings Previous	Usage	CHARGES
Water	662900	653600	9300	60.25
Maintenance Fee/Generator				1.65
<b>Total Due</b>				<b>\$61.90</b>
***After Due Date Penalty 6.19 \$ 68.09 ***				

North Pike Water Assn.

CUSTOMER NUMBER 4419	DUE DATE 6/15/2023
TOTAL DUE UPON RECEIPT 61.90	AFTER DUE DATE PAY 68.09

MAIL THIS STUB WITH YOUR PAYMENT

WALTER F. BEESLEY  
 4192 Magnolia Pisgah Rd  
 Summit MS 39666-7066

Service From 4/19/2023 TO 5/22/2023  
 Last payment received 5/3/23 for \$66.30.

The CCR Report will be published in the Enterprise Journal. Service

for all accounts having a past due balance will be subject to disconnection. For billing questions or help, please call 601-681-1188.

