

Consumer Confidence Report

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) for Keesler Air Force Base (KAFB) and the Gulf Coast Veterans Health Care System as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Where does my water come from?

Drinking water from KAFB/Gulf Coast Veterans Health Care System, which will be referred to as Keesler throughout the document, is pumped from the Lower Graham Ferry Aquifer, a groundwater source. All water provided to Keesler is pumped from wells located on base property. The water from the wells is mixed, treated, stored, and distributed. At Keesler, the only treatment performed on source water is the addition of chlorine and fluoride. Because of the limited chemical treatment, the analytical results for Keesler's drinking water are representative of its source water.

Is my water within standards?

Yes, the drinking water system at Keesler meets the required standards for both Environmental Protection Agency (EPA) and Mississippi State regulations.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

How is the water treated?

Your water is treated by chlorine disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Those substances include microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife and inorganic contaminants. More information regarding these substances can be found at <https://www.epa.gov/ccl/types-drinking-water-contaminants>. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the number of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

Education is key to getting involved and understanding your drinking water. Additional information from the EPA is located/available at <http://www.epa.gov/safewater/>.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5-minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shutting off water while brushing your teeth, washing your hair and shaving can save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.

- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Required Fluoridation Information

To comply with the “Regulation Governing Fluoridation of Community Water Supplies”, it is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6 – 1.2 parts per million (ppm) was **11**. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6 - 1.2 ppm was **86%**. The number of months samples were collected and analyzed in the previous calendar year was **12**.

Results of Voluntary Monitoring:

What are per- and polyfluoroalkyl substances and where do they come from?

Per- and polyfluoroalkyl substances (PFAS) are a group of thousands of man-made chemicals. PFAS have been used in a variety of industrial and consumer products around the globe, including in the U.S., for decades. Due to their widespread use and environmental persistence, most people in the U.S. have been exposed to certain PFAS. PFAS have been used to make coatings and products that are used as oil and water repellents for carpets, clothing, paper packaging for food, and cookware. They are also contained in some foams (aqueous film-forming foam or AFFF) used for fighting petroleum fires.

The EPA has announced the final National Primary Drinking Water Regulation (NPDWR) for six PFAS.

On April 10, 2024, the EPA finalized a NPDWR establishing legally enforceable levels, called Maximum Contaminant Levels (MCLs), for six PFAS in drinking water. PFOA, PFOS, PFHxS, PFNA, and HFPO-DA as contaminants with individual MCLs, and PFAS mixtures containing at least two or more of PFHxS, PFNA, HFPO-DA, and PFBS using a Hazard Index MCL to account for the combined and co-occurring levels of these PFAS in drinking water. EPA also finalized health-based, non-enforceable Maximum Contaminant Level Goals (MCLGs) for these PFAS.

Has Keesler AFB tested its water for PFAS?

Yes. In December 2023 and January 2024 samples were collected from 8 locations around KAFB. We are pleased to report that drinking water testing results were below the detection limit. This means that PFAS were not detected in your water system. In accordance with DoD policy, the water system will be resampled every two years for your continued protection.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Keesler Air Force Base is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the number of contaminants in water provided by public water systems. The table below lists all the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State of Mississippi requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

| Contaminants | MCLG or MRDLG | MCL, TT, or MRDL | Detect In Your Water | Range | | Sample Date | Violation | Typical Source |
|---|---------------------|------------------------|-------------------------------|-------|------|----------------|-----------|---|
| | | | | Low | High | | | |
| Disinfectants & Disinfection By-Products | | | | | | | | |
| (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants) | | | | | | | | |
| Chlorine (as Cl ₂) (ppm) | 4 | 4 | 1.2 | .5 | 2.44 | 2023 | No | Water additive used to control microbes |
| Halo-acetic Acids (HAA5) (ppb) | NA | 60 | 8.6 | NA | NA | 2023 | No | By-product of drinking water chlorination |

| Contaminants | MCLG or MRDLG | MCL, TT, or MRDL | Detect In Your Water | Range | | Sample Date | Violation | Typical Source |
|--|---------------|------------------|----------------------|-------------|------------------------|-------------|--|---|
| | | | | Low | High | | | |
| TTHMs [Total Trihalomethanes] (ppb) | NA | 80 | 15.3 | NA | NA | 2023 | No | By-product of drinking water disinfection |
| Inorganic Contaminants | | | | | | | | |
| Barium (ppm) | 2 | 2 | .00897 | .0024 | .00897 | 2023 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Fluoride (ppm) | 4 | 4 | 1.2 | .6 | 1.2 | 2023 | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Contaminants | MCLG | AL | Your Water | Sample Date | # Samples Exceeding AL | Exceeds AL | Typical Source | |
| Inorganic Contaminants | | | | | | | | |
| Copper - action level at consumer taps (ppm) | 1.3 | 1.3 | 0 | 2023 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits | |
| Lead - action level at consumer taps (ppb) | 0 | 15 | 2 | 2023 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits | |

| Unit Descriptions | |
|--------------------------|--|
| Term | Definition |
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or micrograms per liter (µg/L) |
| NA | NA: not applicable |
| ND | ND: Not detected |
| NR | NR: Monitoring not required but recommended. |

| Important Drinking Water Definitions | |
|---|---|
| Term | Definition |
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |

Important Drinking Water Definitions

| | |
|-------|---|
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |

For more information please contact:

Contact Name: Maj Michael Palmer
Address: 81 OMRS/SGXB, Bioenvironmental Engineering
301 Fisher St. Bldg 420
Keesler AFB, MS 39534
Phone: 228-376-0590