

QUALITY ON TAP
LINCOLN RURAL WATER ASSOCIATION
Heucks Retreat
PWI ID# 430030

May 29, 2024

Lincoln Rural Water is pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of one well pumping from the Catahoula Aquifer. Lincoln Rural Water is pleased to report that our drinking water meets all federal and state requirements. The following reports show our water quality and what it means.

If you have any question about this report or concerning your water utility, please contact our office at 1536 Monticello St., Brookhaven, Ms.ms. 601-833-6449. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 3rd Tuesday of each month at the above location at 7:00 P.M. and our Annual Meeting is held on the 2nd Monday of March at the Lincoln County Courthouse at 7:00 P.M.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

Lincoln Rural Water Association routinely monitors for as many as 154 constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2023. All drinking water, including bottled drinking water, may be reasonably expected to contain at least a small amount of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Addition information for Lead

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about a leak in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations is warranted.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request.

The wells for the Lincoln Rural Water association have received lower rankings in terms of susceptibility to contamination.

Water Quality Data Table

430030 Heucks Retreat

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl ₂) (ppm)	4	4	1.10	.90	1.40	2023	No	Water additive used to control microbes
Haloacetic Acid (HAA5)PPB	NA		1.37ppb	1.37	3.87	2023		By product of drinking water chlorination
TTHMS [Total Trihalomethanes] (ppb)	NA	80	2.05ppb.	NA	NA	2023	No	By-product of drinking water disinfection
Inorganic Contaminants								
Fluoride (ppm)	4	4	.1ppm	.1	.505	20232	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

Inorganic Contaminants	MCLG	AL	YOUR SAMPLE		#SAMPLES Exceeding AI	EXCEED AI	TYPICAL SOURCE
			Water	Date			
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2023	10	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer tap (ppb)	0	.015	.001	2023	10	No	Corrosion of household plumbing systems; Erosion of natural deposits

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have any questions.

4