

# **2024 Annual Drinking Water Quality Report Diamondhead Water and Sewer District**

## **Spanish (Espanol)**

Este informe contiene informacion muy importante sobre la calidad de su agua beber. Traduscalo o hable con alguien que lo entienda bien.

## **Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Your water comes from One of Four Ground Water Wells

## **Source water assessment and its availability**

Contact Our Office or You can contact your local Health Dept

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## **How can I get involved?**

Contact your local Health Dept

## **Description of Water Treatment Process**

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

## **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

## **Cross Connection Control Survey**

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

## **Source Water Protection Tips**

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

## **Other Information**

To comply with the "Regulation Governing Fluoridation of Community water Supplies" Diamondhead Water and Sewer District is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range 0.6-1.2 parts per million (ppm)

was 2. The percentage of fluoride samples collected in the previous calendar year within the optimal range of 0.6-1.2 ppm was 29% .The number of months that samples were collected and analyzed in the previous year was 12

### **Additional Information for Lead**

The system inventory includes lead service lines.  
Contact The District

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. DIAMONDHEAD UTILITIES-NORTH is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact DIAMONDHEAD UTILITIES-NORTH (Public Watersystem Id: MS0230005) by calling 228-255-5813 or emailing [jhigg@dwsd.us](mailto:jhigg@dwsd.us). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

---

## **Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be

more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl2) (ppm)	4	4	0.8	0.4	1.4	2024	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	6.15	NA	NA	2024	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	15	NA	NA	2024	No	By-product of drinking water disinfection
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	0.08	0.08	0.08	2024	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	0.02	0.02	2024	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (optional) (ppm)	NA		86.5	65.4	152	2024	No	Erosion of natural deposits; Leaching
Volatile Organic Contaminants								
1,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2024	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
1,2,4-Trichlorobenzene (ppb)	70	70	0.5	0.5	0.5	2024	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories
Benzene (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	0.5	0.5	0.5	2024	No	Discharge from chemical and agricultural chemical factories
Dichloromethane (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	0.5	0.5	0.5	2024	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	0.5	0.5	2024	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	0.5	0.5	0.5	2024	No	Discharge from petroleum factories
Trichloroethylene (ppb)	00	5	0.5	0.5	0.5	2024	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	00	2	0.5	0.5	0.5	2024	No	Leaching from PVC piping; Discharge from plastics factories

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
Xylenes (ppm)	10	10	0.5	0.5	0.5	2024	No	Discharge from petroleum factories; Discharge from chemical factories	
cis-1,2-Dichloroethylene (ppb)	70	70	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories	
o-Dichlorobenzene (ppb)	600	600	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories	
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories	
trans-1,2-Dichloroethylene (ppb)	100	100	0.5	0.5	0.5	2024	No	Discharge from industrial chemical factories	
Contaminants	MCLG	AL	Your Water	Range		# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.2	0.1	0.216	0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	00	15	0.001	0.001	0.0022	0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Violations and Exceedances

## Additional Monitoring

As part of an on-going evaluation program the EPA has required us to monitor some additional contaminants/chemicals. Information collected through the monitoring of



these contaminants/chemicals will help to ensure that future decisions on drinking water standards are based on sound science.

Name	Reported Level	Range	
		Low	High
11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS) (ppb)	0.005	0.005	0.005
1H,1H, 2H, 2H-perfluorodecane sulfonic acid (8:2FTS) (mg/L)	0.00005	0.00005	0.00005
1H,1H, 2H, 2H-perfluorohexane sulfonic acid (4:2FTS) (mg/L)	0.00003	0.00003	0.00003
1H,1H, 2H, 2H-perfluorooctane sulfonic acid (6:2FTS) (mg/L)	0.00005	0.00005	0.00005
4,8-dioxa-3H-perfluorononanoic acid (ADONA) (ppb)	0.003	0.003	0.003
9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9CI-PF3ONS) (ppb)	0.002	0.002	0.002
N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA) (mg/L)	0.00005	0.00005	0.00005
N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA) (mg/L)	0.00006	0.00006	0.00006
hexafluoropropylene oxide dimer acid (HFPO DA) (mg/L)	0.00005	0.00005	0.00005
lithium (mg/L)	0.009	0.009	0.009
nonafluoro-3,6-dioxaheptanoic acid (NFDHA) (mg/L)	0.00002	0.00002	0.00002
perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA) (mg/L)	0.00003	0.00003	0.00003
perfluoro-3-methoxypropanoic acid (PFMPA) (mg/L)	0.00004	0.00004	0.00004
perfluoro-4-methoxybutanoic acid (PFMBA) (mg/L)	0.00004	0.00004	0.00004
perfluorobutanesulfonic acid (PFBS) (mg/L)	0.00003	0.00003	0.00003
perfluorobutanoic acid (PFBA) (mg/L)	0.00005	0.00005	0.00005
perfluorodecanoic acid (PFDA) (mg/L)	0.00003	0.00003	0.00003
perfluorododecanoic acid (PFDoA) (mg/L)	0.00003	0.00003	0.00003
perfluoroheptanesulfonic acid (PFHpS) (mg/L)	0.00003	0.00003	0.00003
perfluoroheptanoic acid (PFHpA) (mg/L)	0.00003	0.00003	0.00003
perfluorohexanesulfonic acid (PFHxS) (mg/L)	0.00003	0.00003	0.00003
perfluorohexanesulfonic acid (PFHxS) (mg/L)	0.00003	0.00003	0.00003
perfluorononanoic acid (PFNA) (mg/L)	0.00004	0.00004	0.00004
perfluorooctanesulfonic acid (PFOS) (mg/L)	0.00004	0.00004	0.00004
perfluorooctanoic acid (PFOA) (mg/L)	0.00004	0.00004	0.00004
perfluoropentanesulfonic acid (PFPeS) (mg/L)	0.00004	0.00004	0.00004
perfluoropentanoic acid (PFPeA) (mg/L)	0.00003	0.00003	0.00003
perfluorotetradecanoic acid (PFTA) (mg/L)	0.00003	0.00003	0.00003

Name	Reported Level	Range	
		Low	High
perfluorotridecanoic acid (PFTrDA) (mg/L)	0.007	0.007	0.007
perfluoroundecanoic acid (PFUnA) (mg/L)	0.002	0.002	0.002

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
mg/L	mg/L: Number of milligrams of substance in one liter of water
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

<b>Important Drinking Water Definitions</b>	
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

<b>For more information please contact:</b>
---------------------------------------------

Contact Name: Joe Higginbotham

Address: 4425 PARK TEN DR

DIAMONDHEAD, MS 39525

Phone: 228-255-5813