

2024 Annual Drinking Water Consumer Confidence Report

South Terry Water Association

PWS ID # 0250023

Report Completed on May 1, 2025

We are pleased to present to you your 2024 Annual Report. This report is designed to inform you about the quality water and services we deliver to you every day. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. In addition to the contaminants listed below in the chart, we tested for 22 additional organic chemicals for which the state and EPA have set standards. We found no detectable levels of those chemicals. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. We routinely monitor contaminants in your drinking water according to Federal and State laws. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. This table shows the results of our monitoring for the period of January 1st to December 31, 2024.

Water System Information

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for South Terry Water Association received a lower susceptibility ranking to contamination. Our water source consists of 2 wells that draw from the Forest Hill Aquifer.

This past year we installed new lines to increase water pressure in areas of our system. We have plans to paint our water tower and replace motors on both wells. We spent \$205,090 this past year. We currently have no plans for a rate increase.

If you have any questions about this report or concerning your water utility, please contact Sylvia McDavid at 601-878-5308. We want our valued customers to be informed about their water utility. If you want to learn more, please attend our Annual Meeting on Thursday, September 11, 2025 at 2418 Old Hwy 51 at 7:00 pm.

Definitions

In the table below you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Action Level – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level – The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal – The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

ppb – parts per billion = micrograms per liter (=1 drop in 1 billion gallons)

ppm – parts per million = milligrams per liter (=1 drop in 1 million gallons)

Contaminant Table							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	MCLG	MCL	Major Source in Drinking Water
Inorganic Contaminants							
13.Barium	N	2022*	0.0091 ppm	0.0089 to 0.0091	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
21.Copper	N	1/1/22 to 12/31/24	0.1 ppm	None	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
		8/27/24	0.069	0.0063 to 0.2			
23.Fluoride	N	2022*	0.495 ppm	0.494 to 0.495	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
24.Lead	N	1/1/22 to 12/31/24	3.0 ppb	None	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
		8/27/24	2.76	0.9 to 15.6			
26.Nitrate (as Nitrogen)	N	2024	0.303 ppm	0.297 to 0.309	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants & Disinfectant By-Products							
83.Chlorine	N	2024	1.00 ppm	0.70 to 1.20	4	4	Water additive used to control microbes
84.Haloacetic Acids (HAA)	N	2024	0.038 ppb	0.000 to 04.350	n/a	60	By-product of drinking water disinfection
85.TTHM [Total trihalomethanes]	N	2024	0.038 ppb	0.000 to 6.840	n/a	100/80	By-product of drinking water disinfection

* Most recent sample results available

Health Effects

(24) Lead. Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure kidney or nervous system problems.

Compliance with National Primary Drinking Water Regulations

Significant Deficiencies

During a sanitary survey conducted on 11/15/2024, the MS State Department of Health cited the following significant deficiency(s): Operations Record. The system is scheduled to complete corrective actions by using a compliance plan or is within the 120 days minimum.

Lead Service Lines

South Terry Water Association has completed the Lead Service Line Inventory and no lead lines were found. The methods used to make that determination were operator knowledge.

Lead Educational Statement

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Terry Water Association is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take

responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Sylvia McDavid, South Terry Water Association. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. The MS Public Health Laboratory (MPHL) can provide information on lead and copper testing and/or other laboratories certified to analyze lead and copper in drinking water. MPHL can be reached at 601-576-7582 (Jackson, MS).

Additional Information

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

EPA is reviewing the drinking water standard for arsenic because of special concerns that it may not be stringent enough. Arsenic is a naturally occurring mineral known to cause cancer in humans at high concentrations.

The average household uses approximately 400 gallons of water per day. There are many low cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- ▶ Take short showers - a 5-minute shower uses 4 to 5 gallons of water compared to 50 gallons for a bath.
- ▶ Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- ▶ Use a water-efficient showerhead. They are inexpensive, easy to install and can save you up to 750 gallons a month.
- ▶ Run your clothes wash and dishwasher only when they are full. You can save up to 1,000 gallons a month.

- ▶ Water plants only when necessary.
- ▶ Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- ▶ Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- ▶ Teach your children about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- ▶ Visit www.epa.gov/watersense for more information.

Please call our office if you have any questions.



Consumer Confidence Report (CCR) Certification Receipt

Mississippi State Department of Health

Water System: 0250023 - SOUTH TERRY WATER ASSN

CCR Year: 2024

Population Served: 573

CCR Distribution Methods

Mail Copy: No

Hand Delivered: No

Emailed Copy: No

Newspaper(s):

Website Address: <http://msmithreports.com/southterrywa2024ccr>

Emailed Web Address: No

Web Address on Bill: Yes

Web Address Mailed: No

Certification

The applicant certified that:

- This Community public water system confirms it has distributed its Consumer Confidence Report (CCR) to its customers and to the MS State Department of Health, Bureau of Public Water Supply (MSDH/BPWS).
- The appropriate notices of availability have been given.
- The information contained in its CCR is correct and consistent with the compliance monitoring data previously analyzed and reported for this public water system including sample results from the MS Public Health Laboratory, MSDH/BPWS, and other outside or contract laboratories and the requirements of the CCR rule.
- Additionally, requirements for distribution vary by the size of the system and have been met. As required, we have made **good faith efforts** to reach customers who are served by the system but are not bill-paying customers, such as renters or workers. We have posted in public places such as libraries, cafeterias or lunchrooms, apartment buildings, or large private employers; or provided multiple copies to facilities for distribution.

Signature Information

Signed By: Sylvia McDavid

Title/Role: Office manager

Date/Time: 2025-05-26 12:14:28 CDT

Receipt ID: 6de45002-967e-4b5b-acf0-9b70b27fa029

This document serves as the official receipt for your Consumer Confidence Report (CCR) Certification.

Generated: 2025-05-26 12:14:26 CDT