

**2024 Annual Drinking Water Quality Report**  
**Town of Goodman**  
**PWS ID# 0260008**  
**June 2025**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about from where your water comes, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. Our water source is groundwater. Our wells draw from the Meridian Upper and Middle Wilcox Aquifers.

**Source of Water**

A Source Water Assessment has been completed for our public water system to determine the overall susceptibility of the drinking water supply and to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water supply and is available upon request. The wells for the Town of Goodman have received lower to moderate susceptibility rankings.

**Contact and Meeting Information**

If you have any questions about this report or concerning your water, please contact Town of Goodman at 662- 472-2263. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at 5:30 P.M. on the first Tuesday of each month at Town Hall.

**Covered Period by Report**

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, (2024). In cases where monitoring wasn't required in 2024 the table reflects the most recent testing done in accordance with the laws, rules, and regulations. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. All drinking water, including bottled water may be reasonably expected to contain at least small amounts of some constituents. The presence of contaminants does not necessarily indicate that water poses a health risk

**Terms and Abbreviations**

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Parts per million (ppm) or Milligrams per liter (mg/L)* - One part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter (ug/L)* - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## TEST RESULTS

### Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range of detects or # of samples exceeding MCL/ACL	MCLG	MCL	Likely Source of Contamination
10. Barium (ppm)	2022*	N	0.0236	0.0225-0.0236	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper (ppm)	2023*	N	0.2	0	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits
17. Lead (ppb)	2023*	N	2	0	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfectants and Disinfection Byproducts Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range of detects or # of samples exceeding MCL/ACL	MCLG	MCL	Likely Source of Contamination
81. HAA5 (ppb)	2023*	N	3.44	No Range	0	60	By-product of drinking water disinfection
82. TTHM (ppb)	2023*	N	4.21	No Range	0	80	By-product of drinking water disinfection
Chlorine (ppm)	2024	N	1.0	0.50 – 1.70	0	MRDL = 4	Water additive used to control microbes

### Unregulated Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Sodium (ppb)	2024	N	70.8	68.3-70.8	20	None	Road Salt, Water treatment Chemicals, Water Softeners and Sewage Effluents

\*Most recent sample. No sample required for 2024.

Sodium. EPA recommends that drinking water sodium not exceed 20 milligrams per liter(mg/l). Excess sodium from salt in the diet increases the risk of high blood pressure and cardiovascular disease.

We are required to monitor your drinking water for specific contaminants monthly. Results of regular monitoring are an indicator of where our drinking water meets health standards. To ensure systems complete all monitoring requirements, MSDH now notifies systems of any samples prior to the end of the monitoring period.



In addition to the above contaminants, we tested for additional chemicals for which the state and EPA have set standards. We found no detectable levels of those chemicals.

### **Violations**

We are required to monitor your drinking water for contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 12/01/2023 through 1/24/2024, we received a violation for record keeping without rule code. This has since been completed.

### **Significant Deficiencies**

During a sanitary survey conducted on 9/17/2020, the Mississippi State Department of Health cited the following significant deficiency(s): Pressure. This system is scheduled to complete corrective actions by 1/28/21 using a compliance plan or are within the initial 120 days minimum.

During a sanitary survey conducted on 6/22/2022, the Mississippi Department of Health cited the following significant deficiency(s): Automatic controls. This system is scheduled to complete corrective actions by 11/13/22 using a compliance plan or are within the initial 120 days minimum.

### **Enforcement Action**

On 5/27/2022 this system was required by the MS State Department of Health, Bureau of Public Water Supply to participate in an administrative hearing due to violations of the Ground water rule, TTHM/HAA5. This system is schedule complete corrective action using a compliance plan or within the initial 120 days minimum

### **Lead Information**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of Goodman is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Town of Goodman. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. The MS Public Health Laboratory (MPHL) can provide information on lead and copper testing and/or other laboratories certified to analyze lead and copper in drinking water. MPHL can be reached at 601-576-7582 (Jackson, MS).

Our system has completed the Lead Service Line Inventory, and no lead lines were found. The methods used to make that determination were visual inspections, water operator knowledge and archived records. This inventory report is available for viewing at our office upon request.

### **Unregulated Contaminants**

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the

occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The Town of Goodman works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.