

2025 Quality Water Report
Hidden Valley Light Association
[PWS ID# 0690053]
May 2026

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is a ground water well that pumps from the **Sparta Aquifer**. Our source water assessment is available upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

This report shows our water quality and what it means.

If you have any questions about this report or concerning your water utility, please contact **Michael Sivley** (Certified Water Operator) 662-420-6452. We want our valued customers to be informed about their water utility.

Hidden Valley Light Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, **2025**. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detected in your water	Range Low / High		Sample Date	Violation	Typical Source
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as C12) (ppm)	4	4	.9	.6	1.3	2025	No	Water additive used to control microbes
TTHM	100/80		5.68			2025	No	By-product of drinking water disinfection
HAA5	60		14.5			2025	No	By-product of drinking water disinfection
Inorganic Contaminants								
Nitrate [measured as Nitrogen] (ppm)	10	10	.02	NA	NA	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.102	NA	NA	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (optional) (ppm)	NA		12	NS	NA	2025	No	Erosion of natural deposits; Leaching
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Cooper – Action level at consumer taps (ppm)	1.3	1.3	.1	2025		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead – action level at consumer taps (ppb)	0	15	1	2025		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Barium	2		.0491	2025		No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Chromium	.1		.0011	2025		No	Discharge from steel and pulp mills; Erosion of natural deposit	
Fluoride	4		.12	2025		No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Mercury	.002		.0009	2025		No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from crops	

	Unit Descriptions
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per million, or micrograms per liter (mg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended
	Important Drinking Water Definitions
Terms	Definitions
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a Contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exceptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated.
MPL	MPL: State Assigned Maximum Permissible Level.

2025 Quality Water Report

Monitoring and reporting of compliance data violations

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Beginning January 1, 2004, the Mississippi State Department of Health (MSDH) required public water systems that use chlorine as a disinfectant to monitor/test for chlorine residuals as required by the Stage 1 Disinfection-By-Products Rule.

Significant Deficiencies:

During a sanitary survey conducted on 5/5/2022, the Mississippi Department of Health cited the following significant deficiency(s): INADEQUATE FOLLOWUP OF PREVIOUS DEFICIENCIES.

Our system has failed to meet the compliance deadline and enforcement action is pending.

Corrective Actions: The electrical for the plant has been upgraded. The well was grouted on 2/11/2026. Upgrades to the chlorine and ph have been made and are adjusted as needed. Readings are taken 3 times a week. The tank has been inspected. A backup generator is available if there is a power failure. The Emergency Response plan has been adopted and has been produced to the MSDH.

During a sanitary survey conducted on 5/5/2022, the Mississippi Department of Health cited the following significant deficiency(s): SITE SECURITY. Our system has failed to meet the compliance deadline and enforcement action is pending.

Corrective Actions: A lock on the door to the well house has been installed for site security.

During a sanitary survey conducted on 11/14/2025, the Mississippi Department of Health cited the following deficiency (s): CONDITION OF STORAGE TANKS, No tank inspection was available for the pressure tank.

We recommend that tanks be inspected for every year after the tank is five years old.

Our system has failed to meet the compliance deadline and enforcement action is pending.

Corrective Actions: The tank was inspected on 2/11/2026 and will be inspected every year going forward.

During a sanitary survey conducted on 11/14/2025, the Mississippi Department of Health cited the following deficiency (s): IMPROPERLY CONSTRUCTED WELL, Wells that have not been grouted pose a potential risk of source water contamination.

Our system has failed to meet the compliance deadline and enforcement action is pending.

Corrective Actions: The well was grouted on 2/11/2026, proof has been produced to the MSDH.

Lead

The Hidden Valley Light Association has completed the Lead Service Line Inventory, and no lead lines were found. The methods used to make that determination were visual inspections, water operator knowledge, and archived records.

Lead Educational Statement

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hidden Valley Light Association is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Hidden Valley Light Association. Information on lead in drinking water, testing

2025 Quality Water Report

methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. The MS Public Health Laboratory (MPHL) can provide information on lead and copper testing and/or other laboratories certified to analyze lead and copper in drinking water. MPHL can be reached at 601-576-7582 (Jackson, MS).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call 662-420-6452 if you have questions. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.