

2025 Annual Drinking Water Quality Report
City of Water Valley
PWS ID# 0810011
June 2026

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. Our water source is groundwater. The City of Water Valley's water comes from six wells located within the city. All six wells pumps water from the Meridian-Upper Wilcox aquifer.

Contact and Meeting Information

If you have any questions about this report or concerning your water, please contact Mayor Thomas Reynolds 662-473-2431. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at 6:00 P.M. on the first Tuesday of each month at city hall.

Source of Water

A Source Water Assessment has been completed for our public water system to determine the overall susceptibility of the drinking water supply and to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water supply and is available upon request. The wells for Town of Shaw have received moderate to higher susceptibility rankings to contamination.

Covered Period by Report

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. Unless otherwise noted the data presented in this table is from testing done January 1 through December 31, (2025). In cases where monitoring wasn't required in 2025 the table reflects the most recent testing done in accordance with the laws, rules and regulations. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. All drinking water, including bottled water may be reasonably expected to contain at least small amounts of some constituents. The presence of contaminants does not necessarily indicate that water poses a health risk.

Terms and Abbreviations

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) – the concentration of contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level – The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal – The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) – one part by weight of analyte to 1 million parts by weight of the water sample.

Parts per billion (ppb) or Micrograms per liter – one part by weight of analyte to 1 billion parts by weight of the water sample.

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range of detects or # of samples exceeding MCL/ACL	MCLG	MCL	Likely Source of Contamination
13. Chromium	2025	N	1.8	1.0 – 1.8	.01	.01	Discharge from steel and pulp mills; erosion of natural deposits
10. Barium (ppm)	2025	N	0.0245	0.0203 – 0.0245	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper (ppm)	2022*	N	0	NO RANGE	1.3	AL=1.3	Corrosion of household plumbing systems, erosion of natural deposits
17. Lead (ppb)	2022*	N	0	NO RANGE	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (ppm)	2025	N	0.844	0.446 - 0.844	10	10	Runoff from fertilizer use; leaching from Septic tanks; sewage; erosion of natural deposits

Disinfectants and Disinfection Byproducts Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range of detects or # of samples exceeding MCL/ACL	MCLG	MCL	Likely Source of Contamination
81. HAA5 (ppb)	2025	N	2	0.0 – 1.18	0	60	By-product of drinking water disinfection
82. TTHM (ppb)	2025	N	13	1.14 – 8.8	0	80	By-product of drinking water disinfection
Chlorine (ppm)	2025	N	1.20	0.86 - 1.64	0	MRDL = 4	Water additive used to control microbes

Unregulated Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
**Sodium (ppb)	2023*	N	6.23	3.87 – 6.23	20	None	Road Salt, Water treatment Chemicals, Water Softeners and Sewage Effluents

*Most recent sample. No sample required for 2025

**Sodium. EPA recommends that drinking water sodium not exceed 20 milligrams per liter(mg/l). Excess sodium from salt in the diet increases the risk of high blood pressure and cardiovascular disease.

Some People who drink water containing Total Trihalomethanes and Haloacetic Acids in excess of the maximum contaminant level (MCL) over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Violations

Lead Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant woman and your children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Water Valley is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Our system has completed the Lead Service Line Inventory, and no leads were found. The methods used to make that determination were visual inspections, water operator knowledge and archived records. This inventory report is available for viewing at our office upon request

Unregulated Contaminants

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The City of Water Valley works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.