

CITY OF JACKSON
J. H. Fewell (TF081)
Monthly Report

System ID **250008-01**
Month of **August 2020**

- | | |
|---|------------|
| 1. Total number of turbidity measurements taken during the month. | CONTINUOUS |
| 2. Percentage of turbidity that were equal to or less than the turbidity limit of 0.3 NTU. | 100.0% |
| 3. Number of filters that exceeded 0.5 NTU in 2 consecutive readings taken 15 min. apart after first four hours of operation. | NONE |
| 4. Number of filters that exceeded 1.0 NTU in 2 consecutive readings taken 15 min. apart in 3 consecutive months. | NONE |
| 5. Lowest daily disinfectant concentration entering the distribution system in mg/l. | |

1	3.2	7	3.5	13	3.1	19	3.6	25	2.7
2	4.0	8	3.5	14	3.1	20	3.7	26	3.3
3	3.5	9	3.3	15	2.8	21	3.3	27	3.4
4	3.5	10	3.2	16	3.0	22	3.5	28	3.4
5	3.7	11	3.3	17	3.0	23	3.1	29	3.4
6	3.7	12	2.6	18	3.4	24	3.0	30	3.3
								31	2.9

- | | |
|--|-----------|
| 6. Date and duration of each period the disinfectant fell below 0.2 mg/l for more than an hour while entering the distribution system. | NONE |
| 7. Total number of disinfectant residual measured in the distribution system where total coliform samples were collected. | 135 |
| 8. Number of instances where disinfectant was not measured in the distribution system where total coliform samples were collected. | NONE |
| 9. Number of instances where disinfectant was measured in the distributed system but not detected. | NONE |
| 10. Date of last calibration for online monitoring equipment. | 8/28/2020 |

City of Jackson, MS
J. H. Fewell (TF081)
Turbidity Compliance Report

System ID **250008-01**
Month of **August 2020**

Aug 2020	TURBIDITIES (NTU)			
	RAW	SETTLED	FILTER	HS #1
8/1	7.5294	0.4794	0.2586	0.1437
8/2	54.5500	0.6631	0.2639	0.1794
8/3	9.5100	0.6519	0.2827	0.1844
8/4	9.6625	0.4594	0.2651	0.2194
8/5	8.8750	0.6331	0.2705	0.2212
8/6	8.9944	0.5494	0.2897	0.1825
8/7	7.9888	0.5369	0.2733	0.1688
8/8	7.1613	0.4094	0.2850	0.1550
8/9	5.9038	0.9856	0.2613	0.1825
8/10	6.2000	0.7494	0.2636	0.2494
8/11	5.2981	0.4870	0.2872	0.2144
8/12	7.2537	0.3523	0.2626	0.1744
8/13	6.6500	0.4475	0.2583	0.1744
8/14	7.6944	0.4324	0.2804	0.1587
8/15	70.1000	0.4691	0.2926	0.1675
8/16	11.3931	0.6225	0.2511	0.1775
8/17	38.3650	0.6648	0.2777	0.2219
8/18	7.5050	0.5192	0.2545	0.1775
8/19	7.0000	0.4761	0.2547	0.2025
8/20	8.4862	0.5403	0.2482	0.1581
8/21	6.3381	0.4100	0.2404	0.1437
8/22	7.4781	0.3992	0.2387	0.1406
8/23	7.3975	0.5321	0.2861	0.1538
8/24	12.3444	0.5753	0.2731	0.2013
8/25	7.9231	0.5508	0.2516	0.1700
8/26	7.2588	0.3764	0.2427	0.1575
8/27	7.8375	0.6890	0.2253	0.1500
8/28	68.6019	0.6167	0.2711	0.1756
8/29	24.0156	0.4555	0.2621	0.1669
8/30	13.0156	0.8094	0.2522	0.1594
8/31	10.8131	0.8294	0.2830	0.1900
MIN	5.2981	0.3523	0.2253	0.1406
MAX	70.1000	0.9856	0.2926	0.2494
AVG	15.1337	0.5604	0.2648	0.1781

City of Jackson, MS
J. H. Fewell (TF081)
Turbidity Compliance

System ID 250008-01
Month of August 2020

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	0.1350	0.1275	0.1306	0.1319	0.1412	0.1437
8/2	0.1419	0.1412	0.1450	0.1400	0.1794	0.1431
8/3	0.1325	0.1575	0.1444	0.1394	0.1844	0.1437
8/4	0.1506	0.1344	0.1319	0.1656	0.1519	0.2194
8/5	0.1456	0.1425	0.1706	0.1550	0.2212	0.1437
8/6	0.1406	0.1825	0.1437	0.1406	0.1506	0.1462
8/7	0.1450	0.1519	0.1688	0.1437	0.1575	0.1612
8/8	0.1550	0.1437	0.1425	0.1531	0.1456	0.1431
8/9	0.1506	0.1444	0.1388	0.1825	0.1437	0.1406
8/10	0.1381	0.1381	0.1506	0.1437	0.1462	0.2494
8/11	0.2144	0.1781	0.1706	0.1731	0.1494	0.1462
8/12	0.1506	0.1369	0.1450	0.1744	0.1612	0.1462
8/13	0.1744	0.1513	0.1594	0.1575	0.1663	0.1625
8/14	0.1538	0.1587	0.1562	0.1500	0.1556	0.1538
8/15	0.1625	0.1675	0.1619	0.1513	0.1594	0.1600
8/16	0.1656	0.1556	0.1556	0.1469	0.1775	0.1544
8/17	0.1494	0.2219	0.1769	0.1681	0.1562	0.1619
8/18	0.1388	0.1400	0.1462	0.1556	0.1775	0.1538
8/19	0.2025	0.1625	0.1456	0.1356	0.1506	0.1356
8/20	0.1338	0.1356	0.1388	0.1425	0.1462	0.1581
8/21	0.1437	0.1437	0.1437	0.1338	0.1262	0.1319
8/22	0.1306	0.1287	0.1356	0.1312	0.1406	0.1381
8/23	0.1369	0.1394	0.1456	0.1444	0.1538	0.1513
8/24	0.1444	0.1538	0.1481	0.1544	0.1625	0.2013
8/25	0.1700	0.1425	0.1388	0.1437	0.1538	0.1506
8/26	0.1575	0.1431	0.1400	0.1369	0.1569	0.1419
8/27	0.1287	0.1369	0.1369	0.1381	0.1500	0.1375
8/28	0.1362	0.1331	0.1456	0.1587	0.1694	0.1756
8/29	0.1669	0.1600	0.1631	0.1462	0.1575	0.1600
8/30	0.1594	0.1506	0.1444	0.1550	0.1481	0.1506
8/31	0.1469	0.1388	0.1525	0.1575	0.1900	0.1444
MIN	0.1287	0.1275	0.1306	0.1312	0.1262	0.1319
MAX	0.2144	0.2219	0.1769	0.1825	0.2212	0.2494
AVG	0.1517	0.1498	0.1489	0.1500	0.1590	0.1564

City Of Jackson, MS
J. H. Fewell (TF081)
Disinfectant Compliance

System ID **250008-01**
Month of **August 2020**

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	4.0	4.0	4.0	4.0	3.2	3.3
8/2	4.0	4.0	4.0	4.0	4.0	4.0
8/3	4.0	4.0	3.9	3.5	3.6	3.7
8/4	3.7	3.7	3.7	3.6	3.5	3.5
8/5	3.7	3.7	3.7	3.8	3.8	3.9
8/6	3.9	3.9	3.9	3.8	3.8	3.7
8/7	4.0	4.0	3.8	3.7	3.5	3.6
8/8	3.7	3.7	3.7	3.6	3.5	3.6
8/9	3.8	3.7	3.6	3.3	3.3	3.3
8/10	3.4	3.3	3.2	3.3	3.3	3.4
8/11	3.5	3.6	3.3	3.3	3.4	3.4
8/12	3.4	3.4	3.4	3.5	3.5	2.6
8/13	3.2	3.4	3.4	3.1	3.1	3.3
8/14	3.4	3.3	3.4	3.3	3.1	3.4
8/15	3.4	3.2	3.0	2.8	2.9	3.1
8/16	3.4	3.4	3.3	3.1	3.0	3.2
8/17	3.5	3.5	3.5	3.4	3.0	3.3
8/18	3.5	3.6	3.4	3.4	3.4	3.6
8/19	3.7	3.7	3.8	3.7	3.6	3.6
8/20	3.7	3.8	3.8	3.7	3.8	3.8
8/21	3.8	3.9	3.9	3.8	3.5	3.3
8/22	3.6	3.6	3.7	4.0	3.9	3.5
8/23	3.7	3.5	3.5	3.3	3.1	3.7
8/24	3.9	3.7	3.3	3.0	3.6	3.5
8/25	3.5	3.4	3.4	2.7	2.9	3.5
8/26	3.5	3.6	3.6	3.3	3.8	3.7
8/27	3.4	3.6	3.6	3.6	3.7	3.8
8/28	3.7	3.9	3.5	3.8	3.6	3.4
8/29	3.6	3.7	3.7	3.7	3.8	3.4
8/30	3.6	3.6	3.4	3.3	3.4	3.8
8/31	4.0	3.9	3.5	2.9	3.5	3.5
MIN	3.2	3.2	3.0	2.7	2.9	2.6
MAX	4.0	4.0	4.0	4.0	4.0	4.0
AVG	3.6	3.7	3.6	3.5	3.4	3.5

J.H. Fewell (TF081) Turbidity Compliance Report

Date	Hour	FILTERS (NTU)														
		#12	#14	#16	#17	#18	#19	#20	#21	#22	#23	#24	#25	#26	#27	#28
8/29/2020	12:00 AM	OFF	OFF	OFF	0.0586	0.1283	0.1488	0.2116	OFF	0.1878	0.1735	OFF	0.1606	OFF	0.1172	0.1558
	04:00 AM	OFF	OFF	OFF	0.0635	0.1219	0.1343	0.1913	OFF	0.1841	0.1604	OFF	0.1502	OFF	0.1093	0.1466
	08:00 AM	OFF	OFF	OFF	0.0483	0.1197	0.1269	0.1817	0.2524	0.1799	0.1542	OFF	0.1445	OFF	0.1062	0.1445
	12:00 PM	OFF	OFF	OFF	0.0559	0.1194	0.1241	0.1777	0.2523	0.1784	0.1517	OFF	0.1486	OFF	0.1050	0.1465
	04:00 PM	OFF	OFF	OFF	0.0817	0.1205	0.1316	0.1876	0.2621	0.1856	0.1586	OFF	0.1526	OFF	0.1665	0.2159
	08:00 PM	OFF	OFF	OFF	0.0817	0.1221	0.1293	0.1838	0.2570	0.1825	0.1565	OFF	0.1496	OFF	0.1572	0.2117
	AVG	OFF	OFF	OFF	0.0649	0.1220	0.1326	0.1892	0.2563	0.1832	0.1592	OFF	0.1511	OFF	0.1234	0.1669
8/30/2020	12:00 AM	OFF	OFF	OFF	0.0738	0.1218	0.1268	0.1794	0.2522	0.1791	0.1538	OFF	0.1485	OFF	0.1467	0.2034
	04:00 AM	OFF	OFF	OFF	0.0684	0.1195	0.1194	0.1704	0.2431	0.1551	0.1457	OFF	0.1429	OFF	0.1332	0.1840
	08:00 AM	OFF	OFF	OFF	0.0641	0.1178	0.1152	0.1749	0.2407	0.1516	0.1443	OFF	0.1703	OFF	0.1287	0.1786
	12:00 PM	OFF	OFF	OFF	0.0624	0.1157	0.1136	0.1720	0.2425	0.1528	0.1451	OFF	OFF	OFF	0.1308	0.1812
	04:00 PM	OFF	OFF	OFF	0.0608	0.1191	0.1195	0.1734	0.2472	OFF	0.1472	OFF	OFF	OFF	0.1317	0.1919
	08:00 PM	OFF	OFF	OFF	0.0615	0.1209	0.1241	0.1739	0.2487	OFF	0.1488	OFF	OFF	OFF	0.1305	0.1909
	AVG	OFF	OFF	OFF	0.0653	0.1191	0.1198	0.1740	0.2457	0.1581	0.1476	OFF	0.1511	OFF	0.1336	0.1879
8/31/2020	12:00 AM	OFF	OFF	OFF	0.0588	0.1187	0.1153	0.1633	0.2382	OFF	0.1411	OFF	OFF	OFF	0.1194	0.1790
	04:00 AM	OFF	OFF	OFF	0.0617	0.1169	0.1144	0.1601	0.2362	0.2114	0.1393	OFF	OFF	OFF	0.1177	0.1753
	08:00 AM	OFF	OFF	OFF	0.0548	0.1181	0.1142	0.1667	0.2366	0.2090	0.1396	OFF	OFF	OFF	0.1171	0.1656
	12:00 PM	OFF	OFF	OFF	0.0541	0.1400	0.1547	0.2263	0.2830	0.2076	0.1396	OFF	OFF	OFF	0.1174	0.1727
	04:00 PM	OFF	OFF	OFF	0.0519	0.1333	0.1430	0.2007	0.2659	0.1945	0.1347	OFF	OFF	OFF	0.1088	0.1629
	08:00 PM	OFF	OFF	OFF	0.0478	0.1295	0.1333	0.1865	0.2582	0.1912	0.1329	OFF	OFF	OFF	0.1066	0.1528
	AVG	OFF	OFF	OFF	0.0558	0.1270	0.1306	0.1798	0.2541	0.2027	0.1380	OFF	OFF	OFF	0.1145	0.1672

JH Fewell (TF081) UV Compliance

System ID	Month of			August 2020			Total Off-Specification Volume (MG) = 0							
Date	Min Flow Rate (MGD)	Total Production (Gals)	UV Reactor #1			UV Reactor #2			UV Reactor #3			UV Reactor #4		
			Run Time (Hrs)	Calc Min Dose (mJ/cm ²)	Min UVT (%)	Run Time (Hrs)	Calc Min Dose (mJ/cm ²)	Min UVT (%)	Run Time (Hrs)	Calc Min Dose (mJ/cm ²)	Min UVT (%)	Run Time (Hrs)	Calc Min Dose (mJ/cm ²)	Min UVT (%)
8/1/2020	16.2	16175052	OFFLINE	24	27	85	24.0	25	75	OFFLINE				
8/2/2020	14.0	14002989		24.0	27	85	14.0	25	75	2.6	28	87		
8/3/2020	16.2	16178258		24.0	28	85	24.0	26	75	OFFLINE				
8/4/2020	14.9	14908895		24.0	27	85	20.1	25	75					
8/5/2020	16.1	16133385		24.0	27	85	24	25	75					
8/6/2020	16.2	16208913		24.0	27	85	24	25	75					
8/7/2020	16.1	16067149		24.0	26	85	24	24	75					
8/8/2020	16	16042176		24	27	85	24	24	75					
8/9/2020	16.1	16070433		24	27	85	24	24	75					
8/10/2020	15.3	15286126		24	26	85	21.4	25	75					
8/11/2020	15.3	15302318		24	26	85	21.5	27	75					
8/12/2020	16.2	16202492		24	25	85	24	24	75					
8/13/2020	14.8	14768541		24	25	85	20	27	75					
8/14/2020	14.2	14184107		10.1	25	85	24	27	75	8.2	25	87		
8/15/2020	12.4	12382354		OFFLINE			24	25	75	13.6	26	87		
8/16/2020	14.3	14307473					20.6	25	75	24	28	87		
8/17/2020	14.7	14662970					19.5	27	85	4.2	25	75		
8/18/2020	14.2	14159458	OFFLINE	24	28	85	OFFLINE			19.8	29	87		
8/19/2020	15.4	15401921		24	28	85				24	29	87		
8/20/2020	15.4	15424399		24	28	85				24	28	87		
8/21/2020	15.2	15206373		24	28	85				24	25	87		
8/22/2020	15.5	15469880		23.7	28	85				24	27	87		
8/23/2020	15.7	15701921		23.6	27	85				24	27	87		
8/24/2020	17.1	17118078		23.6	27	85	3.7	27	75	24	28	87		
8/25/2020	15.6	15558523		23.6	27	85	OFFLINE			24	28	87		
8/26/2020	15.6	15554849		23.6	27	85				24	28	87		
8/27/2020	15.3	15312514		23.6	28	85				24	27	87		
8/28/2020	14.1	14144513		23.6	27	85				19.6	27	87		
8/29/2020	15.5	15464288		23.6	27	85				24	29	87		
8/30/2020	15.3	15256544		23.6	27	85				24.0	28	87		
8/31/2020	16.6	16565572		23.6	27	85	14.3	26	75	12.4	28	87		

CITY OF JACKSON
O. B. Curtis Conventional (TF082)
Monthly Report For HS# 1 Based on Finished Water

System ID **250008-02**
Month of **August 2020**

- | | |
|---|------------|
| 1. Total number of turbidity measurements taken during the month. | CONTINUOUS |
| 2. Percentage of turbidity that were equal to or less than the turbidity limit of 0.3 NTU. | 100.0% |
| 3. Number of filters that exceeded 0.5 NTU in 2 consecutive readings taken 15 min. apart after first four hours of operation. | NONE |
| 4. Number of filters that exceeded 1.0 NTU in 2 consecutive readings taken 15 min. apart in 3 consecutive months. | NONE |
| 5. Lowest daily disinfectant concentration entering the distribution system in mg/l. | |

1	2.8	7	2.7	13	3.0	19	3.4	25	2.0
2	2.5	8	2.5	14	2.4	20	2.5	26	3.2
3	2.6	9	2.3	15	2.0	21	1.0	27	3.0
4	2.7	10	2.1	16	1.0	22	0.7	28	3.0
5	3.2	11	2.5	17	2.3	23	0.6	29	2.8
6	1.5	12	2.7	18	2.9	24	2.1	30	3.0
								31	3.1

- | | |
|--|-----------|
| 6. Date and duration of each period the disinfectant fell below 0.2 mg/l for more than an hour while entering the distribution system. | NONE |
| 7. Total number of disinfectant residual measured in the distribution system where total coliform samples were collected. | 135 |
| 8. Number of instances where disinfectant was not measured in the distribution system where total coliform samples were collected. | NONE |
| 9. Number of instances where disinfectant was measured in the distributed system but not detected. | NONE |
| 10. Date of last calibration for online monitoring equipment. | 8/23/2020 |

City Of Jackson, MS
O. B. Curtis Conventional (TF082)
Turbidity Compliance Report Based on Finished Water

System ID 250008-02
Month of August 2020

Aug 2020	TURBIDITIES (NTU)			
	RAW	SETTLED	FILTERS	FINISHED
8/1	3.3250	0.3044	0.0870	0.1231
8/2	3.2000	0.1856	0.0791	0.1219
8/3	3.0812	0.4706	0.0812	0.2250
8/4	3.0437	0.1894	0.0774	0.2250
8/5	3.1562	0.1881	0.0770	0.1412
8/6	3.1188	0.1906	0.0937	0.1531
8/7	3.0938	0.1975	0.0827	0.1338
8/8	2.8875	0.1412	0.0846	0.1306
8/9	2.7500	0.1769	0.0696	0.1256
8/10	2.5750	0.1706	0.0670	0.1300
8/11	2.8500	0.1388	0.0703	0.1562
8/12	2.5938	0.1525	0.0718	0.1694
8/13	2.2125	0.1587	0.0764	0.1325
8/14	2.0375	0.1063	0.0735	0.1394
8/15	2.0188	0.2250	0.0836	0.2500
8/16	2.2438	0.1994	0.0900	0.1294
8/17	2.2062	0.1656	0.0905	0.2531
8/18	2.0750	0.2081	0.0944	0.1875
8/19	2.3312	0.1831	0.2660	0.2156
8/20	2.9313	0.2013	0.1280	0.1581
8/21	3.2313	0.1906	0.1021	0.1469
8/22	3.0625	0.1550	0.1035	0.1562
8/23	2.7875	0.1513	0.1191	0.2688
8/24	2.2812	0.5110	0.1216	0.1744
8/25	2.2750	0.3919	0.1166	0.1725
8/26	2.3688	0.3419	0.1116	0.1538
8/27	2.3500	0.4531	0.1019	0.1525
8/28	2.0000	0.3756	0.0982	0.1481
8/29	1.5437	0.7569	0.0926	0.1300
8/30	1.5500	0.4750	0.0975	0.1850
8/31	1.6562	0.3830	0.0942	0.1912
MIN	1.5437	0.1063	0.0670	0.1219
MAX	3.3250	0.7569	0.2660	0.2688
AVG	2.5431	0.2625	0.0969	0.1372

City of Jackson, MS
O. B. Curtis Conventional (TF082)
Turbidity Compliance Based on Finished Water

System ID 250008-02
Month of August 2020

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	0.1231	0.1169	0.1112	0.1206	0.1137	0.1137
8/2	0.1200	0.1219	0.1187	0.1175	0.1156	0.1206
8/3	0.1356	0.1575	0.1362	0.1156	0.1206	0.2250
8/4	0.2250	0.1256	0.1306	0.1256	0.1156	0.1175
8/5	0.1200	0.1150	0.1169	0.1225	0.1412	0.1175
8/6	0.1231	0.1219	0.1187	0.1531	0.1338	0.1344
8/7	0.1338	0.1325	0.1300	0.1269	0.1238	0.1269
8/8	0.1256	0.1256	0.1231	0.1269	0.1306	0.1250
8/9	0.1244	0.1256	0.1187	0.1250	0.1169	0.1150
8/10	0.1137	0.1100	0.1300	0.1169	0.1187	0.1225
8/11	0.1225	0.1325	0.1281	0.1456	0.1381	0.1562
8/12	0.1650	0.1694	0.1681	0.1575	0.1437	0.1381
8/13	0.1262	0.1325	0.1325	0.1238	0.1194	0.1194
8/14	0.1187	0.1306	0.1163	0.1187	0.1394	0.1187
8/15	0.1187	0.2500	0.1125	0.1088	0.1063	0.1119
8/16	0.1094	0.1106	0.1281	0.1281	0.1294	0.1150
8/17	0.1231	0.2531	0.1200	0.1231	0.1181	0.1194
8/18	0.1213	0.1875	0.1425	0.1362	0.1338	0.1338
8/19	0.1306	0.1269	0.2156	0.1306	0.1287	0.1325
8/20	0.1406	0.1494	0.1575	0.1581	0.1519	0.1437
8/21	0.1444	0.1400	0.1469	0.1431	0.1406	0.1369
8/22	OFF	OFF	0.1562	0.1469	0.1394	0.1350
8/23	0.1369	0.2688	0.1375	0.1344	0.1350	0.1456
8/24	0.1575	0.1744	0.1719	0.1675	0.1656	0.1581
8/25	0.1619	0.1725	0.1663	0.1587	0.1550	0.1506
8/26	0.1538	0.1462	0.1450	0.1450	0.1444	0.1350
8/27	0.1338	0.1406	0.1412	0.1412	0.1406	0.1525
8/28	0.1481	0.1456	0.1400	0.1394	0.1325	0.1300
8/29	0.1300	0.1281	0.1269	0.1256	0.1287	0.1256
8/30	0.1281	0.1850	0.1344	0.1306	0.1287	0.1294
8/31	0.1306	0.1356	0.1369	0.1912	0.1269	0.1275
MIN	0.1094	0.1100	0.1112	0.1088	0.1063	0.1119
MAX	0.2250	0.2688	0.2156	0.1912	0.1656	0.2250
AVG	0.1349	0.1511	0.1374	0.1356	0.1315	0.1333

City Of Jackson, MS
O. B. Curtis Conventional (TF082)
Disinfectant Compliance

System ID **250008-02**
Month of **August 2020**

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	3.2	2.8	3.1	3.1	2.9	3.1
8/2	2.8	3.5	2.9	2.5	2.8	3.2
8/3	3.5	2.7	2.9	2.6	3.3	3.0
8/4	3.6	3.6	3.7	2.8	3.5	2.7
8/5	3.2	3.7	3.2	3.2	3.7	3.6
8/6	3.6	3.6	1.9	1.5	1.9	3.1
8/7	3.0	3.0	2.9	3.5	2.8	2.7
8/8	2.8	3.5	3.5	3.0	2.5	2.5
8/9	2.7	2.7	2.4	2.3	2.6	2.8
8/10	3.0	2.8	2.1	2.7	2.8	3.4
8/11	2.6	3.4	2.5	2.8	2.7	2.8
8/12	2.7	2.9	2.9	3.4	2.9	3.0
8/13	3.0	3.1	3.1	3.0	3.5	3.7
8/14	2.9	3.4	3.0	2.7	2.6	2.4
8/15	2.6	2.6	3.4	2.6	2.0	2.4
8/16	1.1	1.2	1.0	2.2	2.9	3.1
8/17	3.5	2.3	3.0	2.4	2.8	3.2
8/18	4.0	3.3	3.2	2.9	3.2	3.5
8/19	3.6	3.5	3.4	3.4	3.5	3.6
8/20	4.0	3.9	2.6	2.5	3.2	4.3
8/21	3.6	3.8	2.1	1.3	1.0	1.0
8/22	OFF	OFF	0.7	4.0	3.2	4.3
8/23	4.5	4.5	1.7	0.7	0.6	2.0
8/24	2.2	2.1	2.4	2.5	2.1	2.1
8/25	2.0	2.2	3.1	3.2	3.6	3.3
8/26	3.5	3.2	4.0	3.5	3.8	3.2
8/27	3.1	3.2	3.6	3.1	3.0	3.6
8/28	3.3	3.2	3.3	3.0	3.7	3.0
8/29	3.0	3.2	3.1	3.8	3.3	2.8
8/30	3.1	3.0	3.0	3.6	3.5	4.0
8/31	3.1	3.2	3.5	3.4	3.5	3.3
MIN	1.1	1.2	0.7	0.7	0.6	1.0
MAX	4.5	4.5	4.0	4.0	3.8	4.3
AVG	3.1	3.1	2.8	2.8	2.9	3.0

O.B. Curtis Conventional (TF082) Filter Turbidity Compliance Report

		FILTERS (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
08/01/20	12:00 AM	0.0413	OFF	0.0330	0.0693	OFF	0.0447
	4:00 AM	0.0406	OFF	0.0274	0.0691	OFF	0.0446
	8:00 AM	0.0391	OFF	0.0245	0.0689	OFF	0.0431
	12:00 PM	0.0400	OFF	0.0285	0.0731	OFF	0.0460
	4:00 PM	OFF	OFF	0.0310	0.0730	OFF	0.0565
	8:00 PM	0.0850	OFF	0.0710	0.0870	OFF	0.0850
	AVG	0.0492	OFF	0.0289	0.0707	OFF	0.0470
08/02/20	12:00 AM	0.0433	OFF	0.0312	0.0714	OFF	0.0567
	4:00 AM	0.0402	OFF	0.0257	0.0685	OFF	0.0533
	8:00 AM	0.0421	OFF	0.0306	0.0718	OFF	0.0556
	12:00 PM	0.0450	OFF	0.0197	0.0735	OFF	0.0552
	4:00 PM	0.0558	OFF	0.0195	0.0791	OFF	0.0584
	8:00 PM	0.0502	OFF	0.0268	0.0786	OFF	0.0573
	AVG	0.0461	OFF	0.0256	0.0738	OFF	0.0561
08/03/20	12:00 AM	0.0464	OFF	0.0309	0.0756	OFF	0.0547
	4:00 AM	0.0413	OFF	0.0313	0.0709	OFF	0.0520
	8:00 AM	0.0401	OFF	0.0267	0.0713	OFF	0.0530
	12:00 PM	0.0397	OFF	0.0202	0.0717	OFF	0.0530
	4:00 PM	0.0443	OFF	0.0224	0.0760	OFF	0.0578
	8:00 PM	0.0481	OFF	0.0292	0.0812	OFF	0.0633
	AVG	0.0433	OFF	0.0268	0.0744	OFF	0.0556
08/04/20	12:00 AM	0.0455	OFF	0.0226	0.0774	OFF	0.0536
	4:00 AM	0.0438	OFF	0.0232	0.0738	OFF	0.0539
	8:00 AM	0.0412	OFF	0.0212	0.0718	OFF	0.0522
	12:00 PM	0.0412	OFF	0.0172	0.0698	OFF	0.0510
	4:00 PM	0.0401	OFF	0.0143	0.0706	OFF	0.0507
	8:00 PM	0.0410	OFF	0.0143	0.0701	OFF	0.0516
	AVG	0.0421	OFF	0.0188	0.0723	OFF	0.0522
08/05/20	12:00 AM	0.0418	OFF	0.0163	0.0700	OFF	0.0503
	4:00 AM	0.0469	OFF	0.0174	0.0744	OFF	0.0532
	8:00 AM	0.0468	OFF	0.0157	0.0770	OFF	0.0551
	12:00 PM	0.0452	OFF	0.0129	0.0740	OFF	0.0520
	4:00 PM	0.0471	OFF	0.0167	0.0751	OFF	0.0538
	8:00 PM	0.0477	OFF	0.0157	0.0761	OFF	0.0550
	AVG	0.0459	OFF	0.0158	0.0745	OFF	0.0533
08/06/20	12:00 AM	0.0487	OFF	0.0156	0.0772	OFF	0.0571
	4:00 AM	0.0503	OFF	0.0110	0.0774	OFF	0.0569
	8:00 AM	0.0503	OFF	0.0113	0.0786	OFF	0.0586
	12:00 PM	0.0478	OFF	0.0190	0.0797	OFF	0.0719
	4:00 PM	0.0490	OFF	0.0273	0.0937	OFF	0.0629
	8:00 PM	0.0663	OFF	0.0172	0.0838	OFF	0.0708
	AVG	0.0521	OFF	0.0169	0.0817	OFF	0.0630
08/07/20	12:00 AM	0.0528	OFF	0.0156	0.0827	OFF	0.0682
	4:00 AM	0.0512	OFF	0.0244	0.0802	OFF	0.0660
	8:00 AM	0.0488	OFF	0.0190	0.0798	OFF	0.0641
	12:00 PM	0.0479	OFF	0.0190	0.0806	OFF	0.0627
	4:00 PM	0.0470	OFF	0.0158	0.0792	OFF	0.0616
	8:00 PM	0.0472	OFF	0.0176	0.0796	OFF	0.0628
	AVG	0.0492	OFF	0.0186	0.0804	OFF	0.0642
08/08/20	12:00 AM	0.0440	OFF	0.0230	0.0796	OFF	0.0621
	4:00 AM	0.0477	OFF	0.0137	0.0841	OFF	0.0659
	8:00 AM	0.0475	OFF	0.0221	0.0846	OFF	0.0663
	12:00 PM	0.0445	OFF	0.0272	0.0783	OFF	0.0592
	4:00 PM	0.0427	OFF	0.0206	0.0783	OFF	0.0590
	8:00 PM	0.0430	OFF	0.0224	0.0716	OFF	0.0618
	AVG	0.0449	OFF	0.0215	0.0794	OFF	0.0624

O.B. Curtis Conventional (TF082) Filter Turbidity Compliance Report

Date	Hour	FILTERS (NTU)					
		#1	#2	#3	#4	#5	#6
08/09/20	12:00 AM	0.0422	OFF	0.0177	0.0696	OFF	0.0599
	4:00 AM	OFF	OFF	0.0182	0.0686	OFF	0.0595
	8:00 AM	0.0384	OFF	0.0131	0.0681	OFF	0.0479
	12:00 PM	0.0344	OFF	0.0179	0.0666	OFF	0.0464
	4:00 PM	0.0317	OFF	0.0144	0.0648	OFF	0.0458
	8:00 PM	0.0365	OFF	0.0168	0.0659	OFF	0.0472
	AVG	0.0398	OFF	0.0164	0.0673	OFF	0.0511
08/10/20	12:00 AM	0.0363	OFF	0.0197	0.0654	OFF	0.0476
	4:00 AM	0.0357	OFF	0.0170	0.0647	OFF	0.0468
	8:00 AM	0.0352	OFF	0.0171	0.0652	OFF	0.0467
	12:00 PM	0.0339	OFF	0.0177	0.0659	OFF	0.0470
	4:00 PM	0.0365	OFF	0.0155	0.0658	OFF	0.0472
	8:00 PM	0.0348	OFF	0.0216	0.0670	OFF	0.0486
	AVG	0.0354	OFF	0.0181	0.0657	OFF	0.0473
08/11/20	12:00 AM	0.0346	OFF	0.0197	0.0669	OFF	0.0484
	4:00 AM	0.0364	OFF	0.0187	0.0673	OFF	0.0493
	8:00 AM	0.0369	OFF	0.0148	0.0682	OFF	0.0500
	12:00 PM	0.0377	OFF	0.0226	0.0697	OFF	0.0524
	4:00 PM	0.0358	OFF	0.0189	0.0685	OFF	0.0507
	8:00 PM	0.0377	OFF	0.0171	0.0703	OFF	0.0530
	AVG	0.0365	OFF	0.0186	0.0685	OFF	0.0506
08/12/20	12:00 AM	0.0378	OFF	0.0118	0.0698	OFF	0.0516
	4:00 AM	0.0368	OFF	0.0134	0.0691	OFF	0.0506
	8:00 AM	0.0370	OFF	0.0124	0.0718	OFF	0.0497
	12:00 PM	0.0366	OFF	0.0632	OFF	OFF	0.0498
	4:00 PM	0.0356	OFF	0.0136	0.0625	OFF	0.0493
	8:00 PM	0.0373	OFF	OFF	OFF	OFF	0.0492
	AVG	0.0369	OFF	0.0229	0.0683	OFF	0.0500
08/13/20	12:00 AM	0.0401	OFF	0.0194	0.0764	OFF	0.0500
	4:00 AM	0.0420	OFF	0.0162	OFF	OFF	0.0524
	8:00 AM	0.0426	OFF	0.0185	OFF	OFF	0.0549
	12:00 PM	0.0441	OFF	0.0199	OFF	OFF	0.0555
	4:00 PM	0.0438	OFF	0.0166	OFF	OFF	0.0571
	8:00 PM	0.0443	OFF	0.0145	OFF	OFF	0.0585
	AVG	0.0428	OFF	0.0175	0.0764	OFF	0.0547
08/14/20	12:00 AM	0.0460	OFF	0.0180	OFF	OFF	0.0578
	4:00 AM	0.0628	OFF	0.0212	OFF	OFF	0.0585
	8:00 AM	0.0460	OFF	0.0162	0.0735	OFF	0.0587
	12:00 PM	0.0495	OFF	0.0180	0.0731	OFF	0.0600
	4:00 PM	0.0431	OFF	0.0160	0.0718	OFF	0.0567
	8:00 PM	0.0485	OFF	0.0210	0.0725	OFF	OFF
	AVG	0.0493	OFF	0.0184	0.0743	OFF	0.0583
08/15/20	12:00 AM	0.0431	OFF	0.0206	0.0759	OFF	0.0519
	4:00 AM	0.0426	OFF	0.0163	0.0791	OFF	0.0497
	8:00 AM	0.0407	OFF	0.0175	0.0790	OFF	0.0499
	12:00 PM	0.0375	OFF	0.0143	0.0802	OFF	0.0486
	4:00 PM	0.0393	OFF	0.0161	0.0804	OFF	0.0503
	8:00 PM	0.0430	OFF	0.0140	0.0836	OFF	0.0552
	AVG	0.0410	OFF	0.0165	0.0797	OFF	0.0509
08/16/20	12:00 AM	0.0445	OFF	0.0138	0.0791	OFF	0.0587
	4:00 AM	0.0451	OFF	0.0173	0.0790	OFF	0.0591
	8:00 AM	0.0448	OFF	0.0113	0.0802	OFF	0.0605
	12:00 PM	0.0474	OFF	0.0158	0.0804	OFF	0.0603
	4:00 PM	0.0530	OFF	OFF	0.0836	OFF	0.0629
	8:00 PM	0.0539	OFF	0.0141	0.0900	OFF	0.0725
	AVG	0.0481	OFF	0.0146	0.0821	OFF	0.0623

O.B. Curtis Conventional (TF082) Filter Turbidity Compliance Report

		FILTERS (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
08/17/20	12:00 AM	0.0637	OFF	0.0180	0.0899	OFF	0.0676
	4:00 AM	0.0563	OFF	0.0161	0.0888	OFF	0.0729
	8:00 AM	0.0509	OFF	0.0165	0.0828	OFF	0.0631
	12:00 PM	0.0501	OFF	0.0126	0.0837	OFF	0.0622
	4:00 PM	0.0579	OFF	0.0135	0.0879	OFF	0.0665
	8:00 PM	0.0577	OFF	0.0145	0.0905	OFF	0.0717
	AVG	0.0561	OFF	0.0152	0.0873	OFF	0.0673
08/18/20	12:00 AM	0.0545	OFF	0.0133	0.0879	OFF	0.0677
	4:00 AM	0.0609	OFF	0.0216	0.0944	OFF	0.0747
	8:00 AM	0.0583	OFF	0.0266	0.0934	OFF	0.0753
	12:00 PM	0.0525	OFF	0.0161	0.0897	OFF	0.0699
	4:00 PM	0.0529	OFF	0.0213	0.0895	OFF	0.0708
	8:00 PM	0.0509	OFF	0.0125	0.0863	OFF	0.0666
	AVG	0.0550	OFF	0.0186	0.0902	OFF	0.0708
08/19/20	12:00 AM	0.0534	OFF	0.0102	0.0907	OFF	0.0685
	4:00 AM	0.0553	OFF	0.0096	0.0924	OFF	0.0719
	8:00 AM	0.0566	OFF	0.0970	0.0915	OFF	0.0659
	12:00 PM	0.0511	OFF	0.1350	0.0897	OFF	0.0664
	4:00 PM	0.0541	OFF	0.1400	0.0929	OFF	0.0698
	8:00 PM	0.1262	OFF	0.2660	0.1709	OFF	0.0872
	AVG	0.0661	OFF	0.1096	0.1047	OFF	0.0716
08/20/20	12:00 AM	0.0791	OFF	0.1240	0.1217	OFF	0.0937
	4:00 AM	0.0776	OFF	0.1170	0.1187	OFF	0.0887
	8:00 AM	0.0703	OFF	0.1280	0.1097	OFF	0.0819
	12:00 PM	0.0623	OFF	0.0671	0.1030	OFF	0.0763
	4:00 PM	0.0633	OFF	0.1057	0.1052	OFF	0.0776
	8:00 PM	0.0643	OFF	0.1082	0.1074	OFF	0.0814
	AVG	0.0695	OFF	0.1083	0.1110	OFF	0.0833
08/21/20	12:00 AM	0.0638	OFF	0.1010	0.1021	OFF	0.0756
	4:00 AM	0.0775	OFF	0.0949	0.0985	OFF	0.0700
	8:00 AM	0.0708	OFF	0.0936	0.0990	OFF	0.0701
	12:00 PM	0.0666	OFF	0.0923	0.0974	OFF	0.0689
	4:00 PM	0.0675	OFF	0.0927	0.0968	OFF	0.0689
	8:00 PM	0.0721	OFF	0.0960	0.0988	OFF	0.0714
	AVG	0.0697	OFF	0.0951	0.0988	OFF	0.0708
08/22/20	12:00 AM	0.0768	OFF	0.1003	0.1017	OFF	0.0755
	4:00 AM	0.0771	OFF	0.1026	0.1035	OFF	0.0744
	8:00 AM	0.0640	OFF	0.0919	0.0957	OFF	0.0689
	12:00 PM	0.0581	OFF	0.0862	0.0912	OFF	0.0655
	4:00 PM	0.0610	OFF	0.0893	0.0932	OFF	0.0693
	8:00 PM	0.0677	OFF	0.0952	0.0974	OFF	0.0716
	AVG	0.0674	OFF	0.0942	0.0971	OFF	0.0708
08/23/20	12:00 AM	0.0687	OFF	0.0957	0.0978	OFF	0.0723
	4:00 AM	0.0659	OFF	0.0922	0.0956	OFF	0.0713
	8:00 AM	0.0622	OFF	0.0870	0.0928	OFF	0.0694
	12:00 PM	0.0564	OFF	0.0828	0.0889	OFF	0.0690
	4:00 PM	0.0701	OFF	0.1045	0.1034	OFF	0.0778
	8:00 PM	0.0861	OFF	0.1191	0.1126	OFF	0.1009
	AVG	0.0682	OFF	0.0969	0.0985	OFF	0.0768
08/24/20	12:00 AM	0.1146	OFF	0.1216	0.1119	OFF	0.1115
	4:00 AM	0.0958	OFF	0.1094	0.1091	OFF	0.1003
	8:00 AM	0.0934	OFF	0.1085	0.1097	OFF	0.0983
	12:00 PM	0.0903	OFF	0.1050	0.1070	OFF	0.0983
	4:00 PM	0.0974	OFF	0.1087	0.1087	OFF	0.1078
	8:00 PM	0.0943	OFF	0.1076	0.1084	OFF	0.1040
	AVG	0.0976	OFF	0.1101	0.1091	OFF	0.1034

O.B. Curtis Conventional (TF082) Filter Turbidity Compliance Report

Date	Hour	FILTERS (NTU)					
		#1	#2	#3	#4	#5	#6
08/25/20	12:00 AM	0.0939	OFF	0.1083	0.1078	OFF	0.0996
	4:00 AM	0.0880	OFF	0.1081	0.1088	OFF	0.0960
	8:00 AM	0.0849	OFF	0.1070	0.1077	OFF	0.0885
	12:00 PM	0.0827	OFF	0.1030	0.1041	OFF	0.0896
	4:00 PM	0.0830	OFF	0.1026	0.1166	OFF	0.0901
	8:00 PM	0.0775	OFF	0.0998	OFF	OFF	0.0856
	AVG	0.0850	OFF	0.1048	0.1097	OFF	0.0916
08/26/20	12:00 AM	0.0768	OFF	0.1003	0.1090	OFF	0.0801
	4:00 AM	0.0792	OFF	0.1096	0.1116	OFF	0.0791
	8:00 AM	0.0747	OFF	0.1025	0.1037	OFF	0.0717
	12:00 PM	0.0678	OFF	0.0933	0.0977	OFF	0.0661
	4:00 PM	0.0672	OFF	0.0911	0.0952	OFF	0.0666
	8:00 PM	0.0677	OFF	0.0912	0.0946	OFF	0.0681
	AVG	0.0722	OFF	0.0980	0.1020	OFF	0.0719
08/27/20	12:00 AM	0.0712	OFF	0.1009	0.1008	OFF	0.0725
	4:00 AM	0.0732	OFF	0.0996	0.1003	OFF	0.0707
	8:00 AM	0.0889	OFF	0.0992	0.1019	OFF	0.0749
	12:00 PM	0.0821	OFF	0.0997	0.1006	OFF	0.0744
	4:00 PM	0.0837	OFF	0.1011	0.1009	OFF	0.0753
	8:00 PM	0.0827	OFF	0.1000	0.1002	OFF	OFF
	AVG	0.0803	OFF	0.1001	0.1008	OFF	0.0778
08/28/20	12:00 AM	0.0800	OFF	0.0968	0.0982	OFF	0.0779
	4:00 AM	0.0794	OFF	0.0965	0.0980	OFF	0.0767
	8:00 AM	0.0705	OFF	0.0888	0.0931	OFF	0.0660
	12:00 PM	0.0699	OFF	0.0880	0.0921	OFF	0.0683
	4:00 PM	0.0680	OFF	0.0871	0.0913	OFF	0.0651
	8:00 PM	0.0663	OFF	0.0853	0.0896	OFF	0.0663
	AVG	0.0724	OFF	0.0904	0.0937	OFF	0.0701
08/29/20	12:00 AM	0.0663	OFF	0.0839	0.0886	OFF	0.0590
	4:00 AM	0.0639	OFF	0.0810	0.0872	OFF	0.0621
	8:00 AM	0.0629	OFF	0.0800	0.0869	OFF	0.0611
	12:00 PM	0.0616	OFF	0.0816	0.0877	OFF	0.0627
	4:00 PM	0.0642	OFF	0.0843	OFF	OFF	0.0658
	8:00 PM	0.0675	OFF	0.0857	0.0926	OFF	0.0687
	AVG	0.0644	OFF	0.0827	0.0903	OFF	0.0632
08/30/20	12:00 AM	0.0686	OFF	0.0858	0.0928	OFF	0.0668
	4:00 AM	0.0690	OFF	0.0975	0.0926	OFF	0.0690
	8:00 AM	0.0686	OFF	0.0857	0.0899	OFF	0.0657
	12:00 PM	0.0796	OFF	0.0828	0.0897	OFF	0.0715
	4:00 PM	0.0708	OFF	0.0879	0.0932	OFF	OFF
	8:00 PM	0.0703	OFF	0.0884	0.0929	OFF	0.0689
	AVG	0.0712	OFF	0.0880	0.0918	OFF	0.0684
08/31/20	12:00 AM	0.0712	OFF	0.0905	0.0942	OFF	0.0704
	4:00 AM	0.0693	OFF	0.0896	0.0938	OFF	0.0694
	8:00 AM	0.0622	OFF	0.0823	0.0874	OFF	0.0630
	12:00 PM	0.0625	OFF	0.0812	0.0865	OFF	0.0621
	4:00 PM	0.0631	OFF	0.0820	0.0869	OFF	0.0635
	8:00 PM	0.0615	OFF	0.0796	0.0850	OFF	0.0619
	AVG	0.0650	OFF	0.0842	0.0890	OFF	0.0651

OB Curtis Conventional (TF082) UV Compliance

System ID	250008-02	Month of August 2020					Total Off-Specification Volume (MG) = 0								
Date	UV Reactor #1					UV Reactor #2					UV Reactor #3				
	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)
8/1/2020	22.5	2620968	26	3	85	OFFLINE	OFFLINE	OFFLINE	OFFLINE	OFFLINE	24.0	2609331	29	3	89
8/2/2020	24.0	3050757	24	3	85						24.0	2829900	27	3	89
8/3/2020	24.0	3053409	24	3	85						24.0	2832286	26	3	89
8/4/2020	24.0	3089197	24	3	85						22.4	2687400	218	3	89
8/5/2020	24	2813403	26	3	85						24	2624454	28	3	89
8/6/2020	22.6	1977323	32	2	85						24	3337481	25	3	89
8/7/2020	24	3038538	24	3	85						24	2818119	27	3	89
8/8/2020	24	2879897	25	3	85						22.8	2579345	132	3	89
8/9/2020	22.9	2680930	26	3	85						24	2637543	29	3	89
8/10/2020	23.8	2796648	26	3	85						23.8	2584136	29	3	89
8/11/2020	24	2786047	26	3	85						23.1	2488842	120	3	89
8/12/2020	24	2843608	27	3	85						24	2875359	28	3	89
8/13/2020	24	2328701	30	2	85						24	3841628	23	4	89
8/14/2020	23.2	2570836	28	3	85						24	2892394	27	3	89
8/15/2020	24	3044107	24	3	85						24	2826437	27	3	89
8/16/2020	24	3078857	24	3	85						22.7	2705168	152	3	89
8/17/2020	22.8	2939114	24	3	85						24	2916548	26	3	89
8/18/2020	24	3059667	24	3	85						24	2840840	26	3	89
8/19/2020	24	3075320	24	3	85						22.7	2726738	140	3	89
8/20/2020	24	2224000	30	2	85						24	3309205	23	3	89
8/21/2020	22.9	2527882	27	3	85						24	3102221	25	3	89
8/22/2020	24	3099254	23	3	85						24	2878119	26	3	89
8/23/2020	23.3	2679984	25	3	85						24	4279177	25	4	89
8/24/2020	24	3523963	21	4	85						24	3246702	23	3	89
8/25/2020	24	3391097	24	3	85						24	2321586	30	2	89
8/26/2020	24	1969632	33	2	85						22.8	2954992	185	3	89
8/27/2020	22.2	2616289	27	3	85						24	3676803	24	4	89
8/28/2020	24	3161320	23	3	85						24	2937453	25	3	89
8/29/2020	24	3147409	24	3	85						24	3054517	25	3	89
8/30/2020	22.7	2654996	26	3	85						22.8	3048352	160	3	89
8/31/2020	24.0	3158681	24	3	85						24.0	2939064	26	3	89

OB Curtis Conventional (TF082) UV Compliance

System ID	250008-02	Month of August 2020					Total Off-Specification Volume (MG) = 0													
Date	UV Reactor #4					UV Reactor #5					UV Reactor #6									
	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)	Run Time (Hrs)	Total Production (Gals)	Calculated Min Dose (mJ/cm2)	Min Flow Rate (MGD)	Min UVT (%)					
8/1/2020	22.5	2716441	27	3	95	OFFLINE	OFFLINE	OFFLINE	OFFLINE	OFFLINE	24.0	2835431	39	3	85					
8/2/2020	24.0	3094559	25	3	95						24.0	3067487	37	3	85					
8/3/2020	24.0	3102820	25	3	95						24.0	3069738	36	3	85					
8/4/2020	24.0	3141315	25	3	95						24.0	3106366	37	3	85					
8/5/2020	24	2881925	26	3	95						24	2853026	38	3	85					
8/6/2020	23.1	3438625	24	3	95						22.4	3294262	69	3	85					
8/7/2020	24	3082303	25	3	95						24	3053489	36	3	85					
8/8/2020	22.6	2774800	26	3	95						24	2895891	38	3	85					
8/9/2020	24	2892134	27	3	95						23.1	2743530	86	3	85					
8/10/2020	23.8	2841102	27	3	95						23.8	2808533	40	3	85					
8/11/2020	24	2835383	27	3	95						24	2801501	40	3	85					
8/12/2020	10.3	1876283	18	2	95						24.0	3112749	38	3	85					
8/13/2020	OFFLINE										24.0	4127669	29	4	85					
8/14/2020	24	3157846	25	3	95						22.3	2880185	73	3	85					
8/15/2020	24	3091467	25	3	95						24.0	3052900	36	3	85					
8/16/2020	24	3130965	25	3	95						24.0	3091560	36	3	85					
8/17/2020	23.2	3080224	25	3	95						22.8	3004643	36	3	85					
8/18/2020	24	3106404	25	3	95						24.0	3076556	36	3	85					
8/19/2020	24	3122791	25	3	95						24	3090242	36	3	85					
8/20/2020	24	3598317	22	4	95						24	3566120	31	4	85					
8/21/2020	24	3382802	23	3	95						24	3345606	34	3	85					
8/22/2020	24	3146243	24	3	95						24	3115835	35	3	85					
8/23/2020	24	3403769	23	3	95						23.3	2501509	42	3	85					
8/24/2020	24	1972309	33	2	95						24	3547220	31	4	85					
8/25/2020	17.8	1601110	50	2	95						24	4938900	25	5	85					
8/26/2020	10.8	4187847	28	4	95						24	4010599	29	4	85					
8/27/2020	24	3995189	23	4	95						22.3	2479869	64	3	85					
8/28/2020	24	3208252	24	3	95						24	3178988	34	3	85					
8/29/2020	22.5	2969726	25	3	95						24	3310799	34	3	85					
8/30/2020	24.0	3528337	23	4	95						22.8	3348726	33	3	85					
8/31/2020	24.0	3206294	24	3	95						24.0	3170821	36	3	85					

CITY OF JACKSON
O. B. Curtis Membrane (TF083)
Monthly Report For HS# 2 Based on Finished Water

System ID **250008-02**
Month of **August 2020**

1. Total number of turbidity measurements taken during the month. CONTINUOUS
2. Percentage of turbidity that were equal to or less than the turbidity limit of 0.3 NTU. 100.0%
3. Number of filters that exceeded 0.5 NTU in 2 consecutive readings taken 15 min. apart after first four hours of operation. NONE
4. Number of filters that exceeded 1.0 NTU in 2 consecutive readings taken 15 min. apart in 3 consecutive months. NONE
5. Lowest daily disinfectant concentration entering the distribution system in mg/l.

1	3.6	7	2.5	13	3.4	19	2.8	25	1.5
2	3.3	8	3.0	14	3.5	20	4.1	26	3.0
3	3.1	9	3.1	15	3.1	21	2.8	27	3.3
4	3.0	10	3.2	16	2.2	22	1.3	28	2.8
5	3.6	11	3.3	17	4.4	23	1.6	29	3.4
6	2.3	12	3.1	18	4.2	24	1.5	30	3.6
								31	3.2

6. Date and duration of each period the disinfectant fell below 0.2 mg/l for more than an hour while entering the distribution system. NONE
7. Total number of disinfectant residual measured in the distribution system where total coliform samples were collected. 135
8. Number of instances where disinfectant was not measured in the distribution system where total coliform samples were collected. NONE
9. Number of instances where disinfectant was measured in the distributed system but not detected. NONE
10. Date of last calibration for online monitoring equipment. 8/23/2020

City Of Jackson, MS
O. B. Curtis Membrane (TF083)
Turbidity Compliance Report Based on Finished Water

System ID **250008-02**
Month of **August 2020**

Aug 2020	TURBIDITIES (NTU)		
	RAW	TRAINS	FINISHED
8/1	3.3250	0.0760	0.1060
8/2	3.2000	0.1086	0.0781
8/3	3.0812	0.1394	0.0697
8/4	3.0437	0.1336	0.1050
8/5	3.1562	0.1298	0.1260
8/6	3.1188	0.1231	0.0847
8/7	3.0938	0.1360	0.1110
8/8	2.8875	0.1070	0.1470
8/9	2.7500	0.1388	0.0534
8/10	2.5750	0.5600	0.0778
8/11	2.8500	0.1356	0.1369
8/12	2.5938	0.1368	0.1353
8/13	2.2125	0.1391	0.0494
8/14	2.0375	0.1400	0.0350
8/15	2.0188	0.1199	0.0222
8/16	2.2438	0.0925	0.0434
8/17	2.2062	0.1323	0.0316
8/18	2.0750	0.1166	0.0381
8/19	2.3312	0.1066	0.0447
8/20	2.9313	0.1348	0.1441
8/21	3.2313	0.1347	0.1616
8/22	3.0625	0.1284	0.1766
8/23	2.7875	0.1276	0.1631
8/24	2.2812	0.1349	0.1184
8/25	2.2750	0.1101	0.1522
8/26	2.3688	0.0996	0.0900
8/27	2.3500	0.1266	0.0831
8/28	2.0000	0.0857	0.0884
8/29	1.5437	0.1159	0.0681
8/30	1.5500	0.1449	0.0719
8/31	1.6562	0.1484	0.2422
MIN	1.5437	0.0760	0.0222
MAX	3.3250	0.5600	0.2422
AVG	2.5431	0.1375	0.0985

City Of Jackson, MS
O. B. Curtis Membrane (TF083)
Turbidity Compliance Based on Finished Water

System ID 250008-02
Month of August 2020

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	0.1060	0.0294	0.0288	0.0250	0.0275	0.0247
8/2	0.0253	0.0266	0.0781	0.0563	0.0278	0.0266
8/3	0.0697	0.0334	0.0259	0.0241	0.0237	0.0250
8/4	0.0306	0.0306	0.1050	0.0347	0.0300	0.0278
8/5	0.0288	0.0790	0.0256	0.0266	0.0303	0.1260
8/6	0.0847	0.0437	0.0297	0.0266	0.0281	0.0306
8/7	0.0297	0.0338	0.0362	0.1110	0.0288	0.0288
8/8	0.1130	0.0563	0.0306	0.0312	0.1470	0.0288
8/9	0.0331	0.0328	0.0534	0.0400	0.0500	0.0434
8/10	0.0441	0.0431	0.0400	0.0625	0.0778	0.0778
8/11	0.0712	0.0659	0.0600	0.1156	0.0913	0.1369
8/12	0.1353	0.1041	0.0941	0.0591	0.0500	0.0694
8/13	0.0494	0.0372	0.0491	0.0347	0.0297	0.0350
8/14	0.0350	0.0219	0.0231	0.0219	0.0231	0.0200
8/15	0.0213	0.0222	0.0194	0.0206	0.0213	0.0194
8/16	0.0228	0.0197	0.0434	0.0209	0.0194	0.0187
8/17	0.0316	0.0162	0.0172	0.0172	0.0175	0.0191
8/18	0.0231	0.0237	0.0269	0.0253	0.0319	0.0381
8/19	0.0381	0.0294	0.0281	0.0306	0.0397	0.0447
8/20	0.0450	0.0388	0.1369	0.1206	0.1353	0.1441
8/21	0.1587	0.1616	0.1497	0.1328	0.1284	0.1319
8/22	0.1300	0.1603	0.1219	0.1484	0.1766	0.1609
8/23	0.1631	0.1603	0.1434	0.1388	0.1394	0.1175
8/24	0.1006	0.1091	0.1184	0.0953	0.0988	0.0988
8/25	0.1216	0.1216	0.1153	0.1522	0.1000	0.0838
8/26	0.0900	0.0862	0.0859	0.0853	0.0794	0.0778
8/27	0.0797	0.0831	0.0831	0.0678	0.0684	0.0803
8/28	0.0806	0.0884	0.0694	0.0691	0.0728	0.0625
8/29	0.0659	0.0681	0.0672	0.0634	0.0628	0.0634
8/30	0.0622	0.0688	0.0678	0.0669	0.0662	0.0719
8/31	0.0725	0.2422	0.0747	0.0766	0.0744	0.0769
MIN	0.0213	0.0162	0.0172	0.0172	0.0175	0.0187
MAX	0.1631	0.2422	0.1497	0.1522	0.1766	0.1609
AVG	0.0698	0.0690	0.0661	0.0646	0.0644	0.0649

City Of Jackson, MS
O. B. Curtis Membrane (TF083)
Disinfectant Compliance

System ID 250008-02
Month of August 2020

Aug 2020	TIME					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
8/1	3.8	3.7	3.8	4.0	4.2	3.6
8/2	4.2	3.9	3.5	3.3	3.3	3.6
8/3	3.8	3.6	3.6	3.4	3.2	3.1
8/4	3.1	3.5	3.6	3.6	3.5	3.0
8/5	3.7	3.7	3.6	4.1	4.3	3.9
8/6	3.5	3.3	2.3	2.3	2.4	2.5
8/7	2.9	3.1	3.2	3.2	2.5	2.7
8/8	3.0	3.3	3.3	3.3	3.2	3.2
8/9	3.2	3.1	3.1	3.3	3.4	3.4
8/10	3.5	3.4	3.2	3.4	3.3	3.3
8/11	3.3	3.4	3.4	3.4	3.4	3.3
8/12	3.7	3.5	3.5	3.1	3.2	3.3
8/13	3.4	3.5	3.4	4.0	3.8	3.7
8/14	3.8	3.8	3.7	3.8	3.7	3.5
8/15	3.7	4.1	4.2	3.7	3.5	3.1
8/16	2.7	2.4	2.2	3.6	4.3	4.6
8/17	4.6	4.9	4.6	4.4	4.5	4.5
8/18	4.2	4.6	4.6	4.6	4.4	4.3
8/19	3.0	2.8	2.9	3.4	3.5	3.8
8/20	4.2	4.1	4.1	4.4	4.8	4.5
8/21	4.2	3.7	4.1	3.3	3.9	2.8
8/22	1.8	1.3	1.4	3.0	3.0	2.7
8/23	2.7	2.4	2.0	1.6	1.9	1.8
8/24	1.7	1.9	1.9	1.9	1.7	1.5
8/25	1.6	1.8	1.8	1.5	2.0	2.6
8/26	3.0	3.3	3.5	4.0	3.5	3.8
8/27	3.3	3.5	3.7	3.9	4.0	3.9
8/28	3.5	2.8	2.9	3.7	3.7	4.7
8/29	4.0	4.0	4.1	4.0	3.8	3.4
8/30	4.0	3.7	4.1	4.2	3.6	3.7
8/31	3.5	3.2	4.0	4.1	3.9	3.4
MN	1.6	1.3	1.4	1.5	1.7	1.5
MAX	4.6	4.9	4.6	4.6	4.8	4.7
AVG	3.4	3.3	3.3	3.5	3.5	3.4

O.B. Curtis Membrane (TF083) Train Turbidity Compliance Report

		TRAIN(S) (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
8/1/2020	12:00 AM	OFF	OFF	0.0760	0.0541	OFF	0.0628
	04:00 AM	OFF	OFF	OFF	0.0431	OFF	OFF
	08:00 AM	OFF	OFF	0.0620	0.0380	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0297	OFF	OFF
	04:00 PM	OFF	OFF	0.0660	OFF	OFF	OFF
	08:00 PM	OFF	OFF	0.0670	OFF	OFF	OFF
	AVG	OFF	OFF	0.0678	0.0412	OFF	OFF
8/2/2020	12:00 AM	OFF	OFF	0.0710	0.0680	OFF	OFF
	04:00 AM	OFF	OFF	0.0780	0.0930	OFF	OFF
	08:00 AM	OFF	OFF	0.0970	0.0980	OFF	0.0938
	12:00 PM	OFF	OFF	OFF	0.1086	OFF	OFF
	04:00 PM	OFF	OFF	0.0930	0.1062	OFF	OFF
	08:00 PM	OFF	OFF	OFF	OFF	OFF	0.0617
	AVG	OFF	OFF	0.0848	0.0948	OFF	0.0778
8/3/2020	12:00 AM	OFF	OFF	0.0427	0.0909	OFF	OFF
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.1003
	08:00 AM	OFF	OFF	0.0630	0.0560	OFF	0.0994
	12:00 PM	OFF	OFF	OFF	0.0590	OFF	0.1075
	04:00 PM	OFF	OFF	0.0604	OFF	OFF	0.1394
	08:00 PM	OFF	OFF	0.0604	0.1120	OFF	0.0818
	AVG	OFF	OFF	0.0566	0.0795	OFF	0.1057
8/4/2020	12:00 AM	OFF	OFF	0.0604	0.1140	OFF	OFF
	04:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	08:00 AM	OFF	OFF	0.0760	0.1258	OFF	0.1169
	12:00 PM	OFF	OFF	0.1114	0.0550	OFF	0.1336
	04:00 PM	OFF	OFF	0.0209	0.1209	OFF	0.1157
	08:00 PM	OFF	OFF	0.0209	0.0557	OFF	OFF
	AVG	OFF	OFF	0.0579	0.0943	OFF	0.1221
8/5/2020	12:00 AM	OFF	OFF	0.0209	0.1146	OFF	0.1298
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.0740
	08:00 AM	OFF	OFF	0.0640	OFF	OFF	OFF
	12:00 PM	OFF	OFF	OFF	OFF	OFF	0.0620
	04:00 PM	OFF	OFF	0.0550	OFF	OFF	0.1231
	08:00 PM	OFF	OFF	0.0800	0.0590	OFF	OFF
	AVG	OFF	OFF	0.0550	0.0868	OFF	0.0972
8/6/2020	12:00 AM	OFF	OFF	0.0890	0.0670	OFF	OFF
	04:00 AM	OFF	OFF	0.1160	0.0980	OFF	0.0740
	08:00 AM	OFF	OFF	0.0670	0.0680	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0930	OFF	0.0680
	04:00 PM	OFF	OFF	OFF	OFF	OFF	0.1231
	08:00 PM	OFF	OFF	0.0780	0.0940	OFF	0.0681
	AVG	OFF	OFF	0.0875	0.0840	OFF	0.0833
8/7/2020	12:00 AM	OFF	OFF	OFF	0.0650	OFF	OFF
	04:00 AM	OFF	OFF	OFF	0.0560	OFF	0.1273
	08:00 AM	OFF	OFF	OFF	0.0820	OFF	0.1360
	12:00 PM	OFF	OFF	OFF	OFF	OFF	0.0690
	04:00 PM	OFF	OFF	OFF	OFF	OFF	OFF
	08:00 PM	OFF	OFF	OFF	0.1040	OFF	0.0679
	AVG	OFF	OFF	OFF	0.0930	OFF	0.1001
8/8/2020	12:00 AM	OFF	OFF	OFF	OFF	OFF	0.0990
	04:00 AM	OFF	OFF	OFF	0.1070	OFF	0.0892
	08:00 AM	OFF	OFF	OFF	0.0820	OFF	0.0870
	12:00 PM	OFF	OFF	OFF	0.0670	OFF	OFF
	04:00 PM	OFF	OFF	0.0850	OFF	OFF	0.0960
	08:00 PM	OFF	OFF	0.0810	OFF	OFF	OFF
	AVG	OFF	OFF	0.0830	0.0853	OFF	0.0928

O.B. Curtis Membrane (TF083) Train Turbidity Compliance Report

		TRAIN(S) (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
8/9/2020	12:00 AM	OFF	OFF	0.0510	0.0570	OFF	0.1030
	04:00 AM	OFF	OFF	OFF	0.0560	OFF	0.0981
	08:00 AM	OFF	OFF	OFF	0.0500	OFF	0.1071
	12:00 PM	OFF	OFF	OFF	0.0610	OFF	0.0650
	04:00 PM	OFF	OFF	0.1070	0.1270	OFF	0.1388
	08:00 PM	OFF	OFF	OFF	0.1040	OFF	OFF
	AVG	OFF	OFF	0.0790	0.0758	OFF	0.1024
8/10/2020	12:00 AM	OFF	OFF	OFF	0.0860	OFF	OFF
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.0476
	08:00 AM	OFF	OFF	OFF	0.1350	OFF	0.1308
	12:00 PM	OFF	OFF	OFF	0.0540	OFF	0.1242
	04:00 PM	OFF	OFF	OFF	0.0770	OFF	0.0570
	08:00 PM	OFF	OFF	0.5600	OFF	OFF	OFF
	AVG	OFF	OFF	0.5600	0.0880	OFF	0.0899
8/11/2020	12:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	04:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	08:00 AM	OFF	OFF	0.0770	0.0520	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0750	OFF	0.0630
	04:00 PM	OFF	OFF	OFF	OFF	OFF	0.1356
	08:00 PM	OFF	OFF	OFF	0.0830	OFF	OFF
	AVG	OFF	OFF	0.0770	0.0700	OFF	0.0993
8/12/2020	12:00 AM	OFF	OFF	0.0840	0.0970	OFF	OFF
	04:00 AM	OFF	OFF	0.0640	0.1060	OFF	0.1076
	08:00 AM	OFF	OFF	0.0700	0.0580	OFF	0.1368
	12:00 PM	OFF	OFF	OFF	0.0530	OFF	0.1352
	04:00 PM	OFF	OFF	OFF	0.0860	OFF	0.0940
	08:00 PM	OFF	OFF	0.0960	0.1040	OFF	OFF
	AVG	OFF	OFF	0.0785	0.0840	OFF	0.1184
8/13/2020	12:00 AM	OFF	OFF	OFF	0.0970	OFF	0.1043
	04:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	08:00 AM	OFF	OFF	OFF	0.0680	OFF	0.1144
	12:00 PM	OFF	OFF	OFF	0.0259	OFF	0.1391
	04:00 PM	OFF	OFF	OFF	0.0311	OFF	0.1029
	08:00 PM	OFF	OFF	0.0777	0.0173	OFF	OFF
	AVG	OFF	OFF	0.0777	0.0479	OFF	0.1152
8/14/2020	12:00 AM	OFF	OFF	0.1031	OFF	OFF	0.1400
	04:00 AM	OFF	OFF	OFF	0.0181	OFF	OFF
	08:00 AM	OFF	OFF	0.0972	0.0184	OFF	0.0650
	12:00 PM	OFF	OFF	OFF	OFF	OFF	0.1296
	04:00 PM	OFF	OFF	OFF	0.0280	OFF	0.1231
	08:00 PM	OFF	OFF	0.0675	0.0294	OFF	OFF
	AVG	OFF	OFF	0.0893	0.0235	OFF	0.1144
8/15/2020	12:00 AM	OFF	OFF	OFF	0.0409	OFF	0.1038
	04:00 AM	OFF	OFF	0.1197	OFF	OFF	0.0746
	08:00 AM	OFF	OFF	0.1199	0.0188	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0164	OFF	0.0804
	04:00 PM	OFF	OFF	0.0719	OFF	OFF	OFF
	08:00 PM	OFF	OFF	OFF	0.0301	OFF	0.0547
	AVG	OFF	OFF	0.1038	0.0266	OFF	0.0784
8/16/2020	12:00 AM	OFF	OFF	OFF	0.0184	OFF	0.0780
	04:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	08:00 AM	OFF	OFF	OFF	OFF	OFF	0.0925
	12:00 PM	OFF	OFF	OFF	OFF	OFF	0.0713
	04:00 PM	OFF	OFF	0.0716	OFF	OFF	0.0701
	08:00 PM	OFF	OFF	0.0743	0.0173	OFF	0.0541
	AVG	OFF	OFF	0.0730	0.0179	OFF	0.0732

O.B. Curtis Membrane (TF083) Train Turbidity Compliance Report

		TRAIN(S) (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
8/17/2020	12:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	04:00 AM	OFF	OFF	0.1220	0.0215	OFF	0.0539
	08:00 AM	OFF	OFF	0.1323	OFF	OFF	0.0676
	12:00 PM	OFF	OFF	OFF	0.0194	OFF	0.0649
	04:00 PM	OFF	OFF	OFF	OFF	OFF	0.0622
	08:00 PM	OFF	OFF	0.0814	0.0180	OFF	0.0557
	AVG	OFF	OFF	0.1119	0.0196	OFF	0.0609
8/18/2020	12:00 AM	OFF	OFF	0.0830	OFF	OFF	0.0612
	04:00 AM	OFF	OFF	OFF	0.0214	OFF	OFF
	08:00 AM	OFF	OFF	0.1166	0.0187	OFF	0.0755
	12:00 PM	OFF	OFF	OFF	0.0168	OFF	OFF
	04:00 PM	OFF	OFF	0.1025	0.0247	OFF	0.0622
	08:00 PM	OFF	OFF	0.0875	OFF	OFF	OFF
	AVG	OFF	OFF	0.0974	0.0204	OFF	0.0663
8/19/2020	12:00 AM	OFF	OFF	0.1066	0.0388	OFF	OFF
	04:00 AM	OFF	OFF	OFF	0.0264	OFF	0.0590
	08:00 AM	OFF	OFF	0.0790	0.0163	OFF	0.0657
	12:00 PM	OFF	OFF	OFF	OFF	OFF	0.0779
	04:00 PM	OFF	OFF	OFF	0.0232	OFF	OFF
	08:00 PM	OFF	OFF	OFF	0.0202	OFF	0.0518
	AVG	OFF	OFF	0.0928	0.0250	OFF	0.0636
8/20/2020	12:00 AM	OFF	OFF	0.1112	OFF	OFF	0.0585
	04:00 AM	OFF	OFF	OFF	0.0299	OFF	0.0724
	08:00 AM	OFF	OFF	OFF	OFF	OFF	0.0585
	12:00 PM	OFF	OFF	OFF	0.1332	OFF	0.0663
	04:00 PM	OFF	OFF	0.0856	0.1348	OFF	OFF
	08:00 PM	OFF	OFF	0.0996	0.1330	OFF	OFF
	AVG	OFF	OFF	0.0988	0.1077	OFF	0.0639
8/21/2020	12:00 AM	OFF	OFF	OFF	0.1347	OFF	0.0880
	04:00 AM	OFF	OFF	0.0890	0.1340	OFF	OFF
	08:00 AM	OFF	OFF	0.0500	0.0701	OFF	0.1130
	12:00 PM	OFF	OFF	OFF	0.0228	OFF	OFF
	04:00 PM	OFF	OFF	0.0870	0.0337	OFF	0.0595
	08:00 PM	OFF	OFF	OFF	0.0222	OFF	0.0613
	AVG	OFF	OFF	0.0753	0.0696	OFF	0.0805
8/22/2020	12:00 AM	OFF	OFF	OFF	0.0276	OFF	0.0583
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.0555
	08:00 AM	OFF	OFF	0.0610	0.1038	OFF	0.0566
	12:00 PM	OFF	OFF	OFF	0.0283	OFF	0.0584
	04:00 PM	OFF	OFF	OFF	0.0375	OFF	0.0643
	08:00 PM	OFF	OFF	0.1284	OFF	OFF	OFF
	AVG	OFF	OFF	0.0947	0.0493	OFF	0.0586
8/23/2020	12:00 AM	OFF	OFF	0.1210	OFF	OFF	0.0524
	04:00 AM	OFF	OFF	0.0890	OFF	OFF	OFF
	08:00 AM	OFF	OFF	OFF	OFF	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0200	OFF	0.0602
	04:00 PM	OFF	OFF	0.1276	OFF	OFF	0.0498
	08:00 PM	OFF	OFF	0.1251	0.0351	OFF	OFF
	AVG	OFF	OFF	0.1157	0.0276	OFF	0.0541
8/24/2020	12:00 AM	OFF	OFF	0.1202	0.0410	OFF	OFF
	04:00 AM	OFF	OFF	0.1316	OFF	OFF	OFF
	08:00 AM	OFF	OFF	0.1110	0.0443	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0481	OFF	0.1349
	04:00 PM	OFF	OFF	0.1212	OFF	OFF	OFF
	08:00 PM	OFF	OFF	0.1070	0.0934	OFF	OFF
	AVG	OFF	OFF	0.1182	0.0567	OFF	0.1349

O.B. Curtis Membrane (TF083) Train Turbidity Compliance Report

		TRAIN(S) (NTU)					
Date	Hour	#1	#2	#3	#4	#5	#6
8/25/2020	12:00 AM	OFF	OFF	OFF	OFF	OFF	0.1060
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.1101
	08:00 AM	OFF	OFF	OFF	0.0520	OFF	0.1005
	12:00 PM	OFF	OFF	OFF	0.0970	OFF	0.0977
	04:00 PM	OFF	OFF	0.0980	0.0740	OFF	0.1071
	08:00 PM	OFF	OFF	0.1040	0.0860	OFF	0.1031
	AVG	OFF	OFF	0.1010	0.0773	OFF	0.1041
8/26/2020	12:00 AM	OFF	OFF	0.0545	OFF	OFF	0.0996
	04:00 AM	OFF	OFF	OFF	0.0600	OFF	OFF
	08:00 AM	OFF	OFF	OFF	0.0570	OFF	0.0988
	12:00 PM	OFF	OFF	OFF	0.0934	OFF	0.0960
	04:00 PM	OFF	OFF	OFF	0.0579	OFF	0.0869
	08:00 PM	OFF	OFF	0.0775	0.0461	OFF	0.0925
	AVG	OFF	OFF	0.0660	0.0629	OFF	0.0948
8/27/2020	12:00 AM	OFF	OFF	OFF	OFF	OFF	0.0805
	04:00 AM	OFF	OFF	0.1266	OFF	OFF	0.0766
	08:00 AM	OFF	OFF	OFF	0.0349	OFF	0.0749
	12:00 PM	OFF	OFF	0.0591	0.0243	OFF	0.0729
	04:00 PM	OFF	OFF	0.0584	OFF	OFF	0.0504
	08:00 PM	OFF	OFF	0.0630	OFF	OFF	OFF
	AVG	OFF	OFF	0.0768	0.0296	OFF	0.0711
8/28/2020	12:00 AM	OFF	OFF	OFF	0.0331	OFF	0.0857
	04:00 AM	OFF	OFF	OFF	0.0158	OFF	0.0740
	08:00 AM	OFF	OFF	0.0530	0.0150	OFF	0.0726
	12:00 PM	OFF	OFF	OFF	0.0204	OFF	0.0710
	04:00 PM	OFF	OFF	OFF	OFF	OFF	0.0627
	08:00 PM	OFF	OFF	0.0844	0.0414	OFF	OFF
	AVG	OFF	OFF	0.0687	0.0251	OFF	0.0732
8/29/2020	12:00 AM	OFF	OFF	OFF	0.0445	OFF	0.0622
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.0537
	08:00 AM	OFF	OFF	0.1159	0.0179	OFF	0.0825
	12:00 PM	OFF	OFF	OFF	0.0167	OFF	0.0787
	04:00 PM	OFF	OFF	0.0873	OFF	OFF	0.0692
	08:00 PM	OFF	OFF	OFF	0.0173	OFF	0.0438
	AVG	OFF	OFF	0.1016	0.0241	OFF	0.0650
8/30/2020	12:00 AM	OFF	OFF	0.1449	0.0198	OFF	OFF
	04:00 AM	OFF	OFF	0.1194	0.0223	OFF	0.0702
	08:00 AM	OFF	OFF	0.1224	0.0191	OFF	0.1073
	12:00 PM	OFF	OFF	OFF	0.0279	OFF	0.0844
	04:00 PM	OFF	OFF	0.0761	OFF	OFF	0.0691
	08:00 PM	OFF	OFF	OFF	0.0194	OFF	OFF
	AVG	OFF	OFF	0.1157	0.0217	OFF	0.0828
8/31/2020	12:00 AM	OFF	OFF	OFF	0.0680	OFF	OFF
	04:00 AM	OFF	OFF	OFF	OFF	OFF	0.0530
	08:00 AM	OFF	OFF	0.1484	0.0242	OFF	OFF
	12:00 PM	OFF	OFF	OFF	0.0249	OFF	0.1060
	04:00 PM	OFF	OFF	0.0777	0.0263	OFF	0.0678
	08:00 PM	OFF	OFF	0.0821	0.0361	OFF	0.0329
	AVG	OFF	OFF	0.1027	0.0359	OFF	0.0649

O.B. Curtis Membrane (TF083) Trains Daily MIT Results

Date Time	Train 1 LRV	Date Time	Train 2 LRV	Date Time	Train 3 LRV	Date Time	Train 4 LRV
	OFF		OFF	8/1/20 4:40 AM	4.0	8/1/20 2:35 AM	4.0
				8/2/20 11:45 PM	4.2	8/2/20 3:40 AM	4.2
				8/3/20 5:50 AM	4.0	8/3/20 2:45 AM	4.2
				8/4/20 11:40 PM	4.1	8/4/20 8:10 AM	4.0
				8/5/20 12:20 AM	4.1	8/5/20 2:40 AM	4.0
				8/6/20 12:50 AM	4.3	8/6/20 3:05 AM	4.0
				8/7/20 8:25 AM	4.2	8/7/20 2:50 AM	4.0
				8/8/20 11:50 AM	4.0	8/8/20 2:30 AM	4.1
				8/9/20 12:15 AM	4.4	8/9/20 2:30 AM	4.0
				8/10/20 8:05 AM	4.2	8/10/20 2:30 AM	4.1
				8/11/20 5:45 AM	4.2	8/11/20 2:30 AM	4.1
				8/12/20 1:50 PM	4.0	8/12/20 2:30 AM	4.1
				8/13/20 8:35 AM	4.0	8/13/20 3:00 AM	4.1
				8/14/20 12:45 AM	4.4	8/14/20 2:45 AM	4.1
				8/15/20 12:50 AM	4.4	8/15/20 2:45 AM	4.1
				8/16/20 12:20 AM	4.1	8/16/20 2:30 AM	4.1
				8/17/20 11:35 PM	4.2	8/17/20 2:55 AM	4.0
				8/18/20 12:10 AM	4.3	8/18/20 2:30 AM	4.0
				8/19/20 12:35 AM	4.1	8/19/20 3:15 AM	4.1
				8/20/20 6:20 AM	4.3	8/20/20 2:40 AM	4.1
				8/21/20 11:40 PM	4.0	8/21/20 5:55 AM	4.1
				8/22/20 11:30 PM	4.0	8/22/20 2:30 AM	4.1
				8/28/20 12:15 AM	4.2	8/28/20 3:10 AM	4.1
				8/29/20 12:10 AM	4.2	8/29/20 2:35 AM	4.1
				8/30/20 11:45 PM	4.1	8/30/20 3:00 AM	4.1
				8/31/20 11:30 PM	4.1	8/31/20 2:35 AM	4.1
Date Time	Train 5 LRV	Date Time	Train 6 LRV				
	OFF	8/1/20 3:40 AM	4.1				
		8/2/20 4:15 AM	4.6				
		8/3/20 3:35 AM	4.6				
		8/4/20 4:00 AM	4.6				
		8/5/20 3:30 AM	4.6				
		8/6/20 3:50 AM	4.4				
		8/7/20 3:35 AM	4.4				
		8/8/20 3:55 AM	4.4				
		8/9/20 4:00 AM	4.3				
		8/10/20 3:20 AM	4.3				
		8/11/20 4:00 AM	4.3				
		8/12/20 3:40 AM	4.3				
		8/13/20 4:50 AM	4.4				
		8/14/20 3:30 AM	4.4				
		8/15/20 3:30 AM	4.2				
		8/16/20 3:40 AM	4.3				
		8/17/20 10:30 PM	4.3				
		8/18/20 3:35 AM	4.3				
		8/19/20 4:05 AM	4.4				
		8/20/20 3:45 AM	4.4				
		8/21/20 10:15 AM	4.3				
		8/22/20 3:50 AM	4.3				
		8/28/20 4:00 AM	4.6				
		8/29/20 3:40 AM	4.6				
		8/30/20 4:05 AM	4.5				
		8/31/20 3:25 AM	4.5				

CITY OF JACKSON
DISTRIBUTION SYSTEM DISINFECTANT DATA

System ID 250008
Month of August 2020

Aug-20	No. of sites, disinfectant residual measured (a)	No. of sites, no disinfectant measured, HPC measured (b)	No. of sites, disinfectant residual not detected, no HPC measured (c)	No. of sites, disinfectant residual not detected. HPC> 500/ml (d)	No. of sites, disinfectant residual not measured. HPC > 500/ml (e)
DATE	COL 2	COL 3	COL 4	COL 5	COL 6
8/1					
8/2					
8/3	10				
8/4	30				
8/5	52				
8/6	42				
8/7	1				
8/8					
8/9					
8/10					
8/11					
8/12					
8/13					
8/14					
8/15					
8/16					
8/17					
8/18					
8/19					
8/20					
8/21					
8/22					
8/23					
8/24					
8/25					
8/26					
8/27					
8/28					
8/29					
8/30					
8/31					
Total	135	0	0	0	0

$$V = \frac{(c+d+e)}{(a+b)} * 100$$

$$V = 0$$

CITY OF JACKSON
CHLORINE DIOXIDE COMPLIANCE

August	SYSTEM ID: 250008-02		SYSTEM ID: 250008-01	
	O.B. CURTIS (TF082)		J. H. FEWELL (TF081)	
	ClO ₂	ClO ⁻	ClO ₂	ClO ⁻
8/1	OFF	OFF	OFF	OFF
8/2	OFF	OFF	OFF	OFF
7/3	OFF	OFF	OFF	OFF
8/4	OFF	OFF	OFF	OFF
8/5	OFF	OFF	OFF	OFF
8/6	OFF	OFF	OFF	OFF
8/7	OFF	OFF	OFF	OFF
8/8	OFF	OFF	OFF	OFF
8/9	OFF	OFF	OFF	OFF
8/10	OFF	OFF	OFF	OFF
8/11	OFF	OFF	OFF	OFF
8/12	OFF	OFF	OFF	OFF
8/13	OFF	OFF	OFF	OFF
8/14	OFF	OFF	OFF	OFF
8/15	OFF	OFF	OFF	OFF
8/16	OFF	OFF	OFF	OFF
8/17	OFF	OFF	OFF	OFF
8/18	OFF	OFF	OFF	OFF
8/19	OFF	OFF	OFF	OFF
8/20	OFF	OFF	OFF	OFF
8/21	OFF	OFF	OFF	OFF
8/22	OFF	OFF	OFF	OFF
8/23	OFF	OFF	OFF	OFF
8/24	OFF	OFF	OFF	OFF
8/25	OFF	OFF	OFF	OFF
8/26	OFF	OFF	OFF	OFF
8/27	OFF	OFF	OFF	OFF
8/28	OFF	OFF	OFF	OFF
8/29	OFF	OFF	OFF	OFF
8/30	OFF	OFF	OFF	OFF
8/31	OFF	OFF	OFF	OFF

DISTRIBUTION SITES			
DATE	SITE	ClO ₂	ClO ⁻
	Olympia		
	Boling St		
	John Hopkins		

CITY OF JACKSON TOC REMOVAL SUMMARY

2020

TOC Table- Required % Removal of TOC			
Source Water TOC (ppm)	Source Water Alkalinity, ppm as CaCO ₃		
	0-60	>60-120	>120
>2.0 to 4.0	35.0%	25.0%	15.0%
>4.0 to 8.0	45.0%	35.0%	25.0%
>8.0	50.0%	40.0%	30.0%

$$\% \text{ ACTUAL TOC REMOVED} = \frac{\text{RAW TOC} - \text{FINISHED TOC}}{\text{RAW TOC}} \times 100\%$$

$$\text{TOC REMOVAL RATIO} = \frac{\% \text{ ACTUAL TOC REMOVED}}{\text{REQUIRED TOC REMOVAL}}$$

Date	Water Treatment Plant	TOC Summary		TOC % Removal Summary			TOC Removal Ratio
		Source Water Alkalinity (ppm)	Source Water TOC (ppm)	Treated Water TOC (ppm)	Actual TOC Removed (%)	Required TOC Removal (%)	
1/6/2020	OBC HS1	8	11.9	2.6	78.2	50.0	1.56
	OBC HS2	8	11.9	3.5	70.6	50.0	1.41
	JHF HS1	10	11.3	3.2	71.7	50.0	1.43
1/15/2020	OBC HS1	8	9.1	2.1	76.9	50.0	1.54
	OBC HS2	8	9.1	1.2	86.8	50.0	1.74
	JHF HS1	9	10.3	1.6	84.5	50.0	1.69
1/23/2020	OBC HS1	8	10.9	4.5	58.7	50.0	1.17
	OBC HS2	8	10.9	3.4	68.8	50.0	1.38
	JHF HS1	8	10.8	3.3	69.4	50.0	1.39
1/29/2020	OBC HS1	9	5.7	2.0	64.9	45.0	1.44
	OBC HS2	9	5.7	1.4	75.4	45.0	1.68
	JHF HS1	10	6.0	2.2	63.3	45.0	1.41
2/7/2020	OBC HS1	11	6.2	2.4	61.3	45.0	1.36
	OBC HS2	11	6.2	1.3	79.0	45.0	1.76
	JHF HS1	11	6.6	2.5	62.1	45.0	1.38
2/12/2020	OBC HS1	12	7.7	1.9	75.3	50.0	1.51
	OBC HS2	12	7.7	2.2	71.4	50.0	1.43
	JHF HS1	12	3.8	1.5	60.5	50.0	1.21
2/18/2020	OBC HS1	10	6.0	1.7	71.7	45.0	1.59
	OBC HS2	10	6.3	2.0	68.3	45.0	1.52
	JHF HS1	7	7.0	1.0	85.7	45.0	1.90
2/26/2020	OBC HS1	14	9.4	1.9	79.8	50.0	1.60
	OBC HS2	14	9.4	3.0	68.1	50.0	1.36
	JHF HS1	8	9.2	2.9	68.5	50.0	1.37
3/5/2020	OBC HS1	12	9.1	2.2	75.8	50.0	1.52
	OBC HS2	12	9.1	2.7	70.3	50.0	1.41
	JHF HS1	10	8.7	2.3	73.6	50.0	1.47
3/12/2020	OBC HS1	10	10.1	3.3	67.3	50.0	1.35
	OBC HS2	10	10.1	2.8	72.3	50.0	1.45
	JHF HS1	11	9.5	2.5	73.7	50.0	1.47
3/17/2020	OBC HS1	10	6.7	1.6	76.1	50.0	1.52
	OBC HS2	10	6.7	1.9	71.6	50.0	1.43
	JHF HS1	8	6.2	0.4	93.5	45.0	2.08
3/25/2020	OBC HS1	10	6.7	2.1	68.7	50.0	1.37
	OBC HS2	10	6.7	2.5	62.7	50.0	1.25
	JHF HS1	11	7.8	1.6	79.5	50.0	1.59
RUNNING ANNUAL AVERAGE	OBC HS1					1.46	
	OBC HS2						
	JHF HS1						
TOTAL COMBINED RUNNING ANNUAL AVERAGE							1.49

CITY OF JACKSON TOC REMOVAL SUMMARY

2020

TOC Table- Required % Removal of TOC			
Source Water TOC (ppm)	Source Water Alkalinity, ppm as CaCO ₃		
	0-60	>60-120	>120
>2.0 to 4.0	35.0%	25.0%	15.0%
>4.0 to 8.0	45.0%	35.0%	25.0%
>8.0	50.0%	40.0%	30.0%

$$\% \text{ ACTUAL TOC REMOVED} = \frac{\text{RAW TOC} - \text{FINISHED TOC}}{\text{RAW TOC}} \times 100\%$$

$$\text{TOC REMOVAL RATIO} = \frac{\% \text{ ACTUAL TOC REMOVED}}{\text{REQUIRED TOC REMOVAL}}$$

Date	Water Treatment Plant	TOC Summary		TOC % Removal Summary			TOC Removal Ratio
		Source Water Alkalinity (ppm)	Source Water TOC (ppm)	Treated Water TOC (ppm)	Actual TOC Removed (%)	Required TOC Removal (%)	
4/1/2020	OBC HS1	13	6.7	3.1	53.7	45.0	1.19
	OBC HS2	13	6.7	2.7	59.7	45.0	1.33
	JHF HS1	13	8.9	1.9	78.7	50.0	1.57
4/10/2020	OBC HS1	11	8.4	3.1	63.1	50.0	1.26
	OBC HS2	11	8.4	2.5	70.2	50.0	1.40
	JHF HS1	14	7.5	2.5	66.7	45.0	1.48
4/14/2020	OBC HS1	12	8.7	2.4	72.4	50.0	1.45
	OBC HS2	12	8.7	1.7	80.5	50.0	1.61
	JHF HS1	12	7.3	1.9	74.0	45.0	1.64
4/20/2020	OBC HS1	12	7.1	2.8	60.6	45.0	1.35
	OBC HS2	12	7.1	2.0	71.8	45.0	1.60
	JHF HS1	13	8.6	1.6	81.4	50.0	1.63
4/28/2020	OBC HS1	10	9.8	3.7	62.2	50.0	1.24
	OBC HS2	10	9.8	4.9	50.0	50.0	1.00
	JHF HS1	12	10.0	3.2	68.0	50.0	1.36
5/6/2020	OBC HS1	9	7.9	2.8	64.6	45.0	1.43
	OBC HS2	9	7.9	3.5	55.7	45.0	1.24
	JHF HS1	16	6.6	2.5	62.1	45.0	1.38
5/11/2020	OBC HS1	10	5.2	3.0	42.3	45.0	0.94
	OBC HS2	10	5.2	2.7	48.1	45.0	1.07
	JHF HS1	14	6.1	2.2	63.9	45.0	1.42
5/18/2020	OBC HS1	12	7.6	5.2	31.6	45.0	0.70
	OBC HS2	12	7.6	3.8	50.0	45.0	1.11
	JHF HS1	15	7.1	5.9	16.9	45.0	0.38
5/27/2020	OBC HS1	12	5.8	1.8	69.0	45.0	1.53
	OBC HS2	12	5.8	2.4	58.6	45.0	1.30
	JHF HS1	12	5.5	2.8	49.1	45.0	1.09
6/3/2020	OBC HS1	12	6.2	3.0	51.6	50.0	1.03
	OBC HS2	12	6.2	3.0	51.6	50.0	1.03
	JHF HS1	20	7.4	3.4	54.1	50.0	1.08
6/11/2020	OBC HS1	10	4.5	1.7	62.2	45.0	1.38
	OBC HS2	10	4.5	2.3	48.9	45.0	1.09
	JHF HS1	11	5.8	2.2	62.1	45.0	1.38
6/18/2020	OBC HS1	11	5.9	2.4	59.3	45.0	1.32
	OBC HS2	11	5.9	1.9	67.8	45.0	1.51
	JHF HS1	17	6.0	2.0	66.7	45.0	1.48
RUNNING ANNUAL AVERAGE	OBC HS1					1.35	
	OBC HS2	1.38					
	JHF HS1	1.40					
TOTAL COMBINED RUNNING ANNUAL AVERAGE					1.39		

CITY OF JACKSON TOC REMOVAL SUMMARY

2020

TOC Table- Required % Removal of TOC			
Source Water TOC (ppm)	Source Water Alkalinity, ppm as CaCO ₃		
	0-60	>60-120	>120
>2.0 to 4.0	35.0%	25.0%	15.0%
>4.0 to 8.0	45.0%	35.0%	25.0%
>8.0	50.0%	40.0%	30.0%

$$\% \text{ ACTUAL TOC REMOVED} = \frac{\text{RAW TOC} - \text{FINISHED TOC}}{\text{RAW TOC}} \times 100\%$$

$$\text{TOC REMOVAL RATIO} = \frac{\% \text{ ACTUAL TOC REMOVED}}{\text{REQUIRED TOC REMOVAL}}$$

Date	Water Treatment Plant	TOC Summary		TOC % Removal Summary			TOC Removal Ratio
		Source Water Alkalinity (ppm)	Source Water TOC (ppm)	Treated Water TOC (ppm)	Actual TOC Removed (%)	Required TOC Removal (%)	
6/25/2020	OBC HS1	12	5.7	2.0	64.9	45.0	1.44
	OBC HS2	12	5.7	1.6	71.9	45.0	1.60
	JHF HS1	12	6.4	1.6	75.0	45.0	1.67
7/2/2020	OBC HS1	15	6.9	3.2	53.6	45.0	1.19
	OBC HS2	15	6.9	2.7	60.9	45.0	1.35
	JHF HS1	16	5.6	1.8	67.9	45.0	1.51
7/8/2020	OBC HS1	13	9.1	4.5	50.5	50.0	1.01
	OBC HS2	13	9.1	4.9	46.2	50.0	0.92
	JHF HS1	15	8.7	4.6	47.1	50.0	0.94
7/14/2020	OBC HS1	13	8.6	3.0	65.1	50.0	1.30
	OBC HS2	13	8.6	4.1	52.3	50.0	1.05
	JHF HS1	14	6.9	4.8	51.0	50.0	1.02
7/21/2020	OBC HS1	15	9.7	4.6	52.6	50.0	1.05
	OBC HS2	15	9.7	5.2	46.4	50.0	0.93
	JHF HS1	15	9.8	4.8	51.0	50.0	1.02
7/27/2020	OBC HS1	19	8.9	4.1	53.9	50.0	1.08
	OBC HS2	19	8.9	4.8	46.1	50.0	0.92
	JHF HS1	20	8.0	3.0	62.5	45.0	1.39
8/3/2020	OBC HS1	13	8.4	1.6	81.0	50.0	1.62
	OBC HS2	13	8.4	1.2	85.7	50.0	1.71
	JHF HS1	17	9.8	3.6	63.3	45.0	1.41
8/12/2020	OBC HS1	14	10.2	5.0	51.0	45.0	1.13
	OBC HS2	14	10.2	4.0	60.8	45.0	1.35
	JHF HS1	22	10.3	5.8	43.7	45.0	0.97
8/17/2020	OBC HS1	14	21	5.5	73.8	50.0	1.48
	OBC HS2	14	21	3.6	82.9	50.0	1.66
	JHF HS1	15	20	3.2	84.0	50.0	1.68
8/25/2020	OBC HS1	17	7.6	2.5	67.1	45.0	1.49
	OBC HS2	17	7.6	2.3	69.7	45.0	1.55
	JHF HS1	23	8.2	2.7	67.1	50.0	1.34
	OBC HS1						
	OBC HS2						
	JHF HS1						
	OBC HS1						
	OBC HS2						
	JHF HS1						
	OBC HS1						
	OBC HS2						
	JHF HS1						
RUNNING ANNUAL AVERAGE	OBC HS1						1.33
	OBC HS2						1.36
	JHF HS1						1.39
TOTAL COMBINED RUNNING ANNUAL AVERAGE							1.36

CITY OF JACKSON
CORROSION CONTROL DATA

August 2020 DATE / SHIFT		SYSTEM ID: 250008-02			SYSTEM ID: 250008-01		
		OBC COMBINED HIGH SERVICE			JHF (TF081)		
		pH	Alkalinity	Hardness	pH	Alkalinity	Hardness
8/1	0700 - 1500	9.3	55	14	9.0	21	56
	1500 - 2300	9.5	49	15	9.4	25	53
	2300 - 0700	9.6	50	14	9.4	24	63
8/2	0700 - 1500	9.7	55	14	9.7	32	68
	1500 - 2300	9.6	49	21	9.3	24	62
	2300 - 0700	9.7	50	23	9.4	26	55
8/3	0700 - 1500	9.4	54	13	9.3	16	55
	1500 - 2300	9.6	56	13	9.2	20	59
	2300 - 0700	9.5	51	21	9.2	20	53
8/4	0700 - 1500	9.7	54	14	9.6	24	71
	1500 - 2300	9.6	51	20	9.6	20	57
	2300 - 0700	9.7	49	17	9.4	25	73
8/5	0700 - 1500	9.8	56	18	9.7	29	77
	1500 - 2300	9.9	69	12	9.2	23	55
	2300 - 0700	9.8	64	18	9.1	27	72
8/6	0700 - 1500	9.6	47	16	9.6	28	79
	1500 - 2300	9.4	46	18	9.3	24	61
	2300 - 0700	9.3	37	14	9.4	32	69
8/7	0700 - 1500	9.2	33	13	9.1	26	73
	1500 - 2300	9.1	27	16	9.6	27	69
	2300 - 0700	9.3	44	18	9.5	29	72
8/8	0700 - 1500	9.3	36	12	9.4	33	67
	1500 - 2300	9.4	31	14	9.1	29	61
	2300 - 0700	9.3	38	13	9.2	30	69
8/9	0700 - 1500	9.2	50	14	9.4	28	65
	1500 - 2300	9.2	47	20	9.7	25	65
	2300 - 0700	9.2	44	21	9.2	29	55
8/10	0700 - 1500	9.0	49	14	9.4	31	62
	1500 - 2300	9.0	51	14	9.3	32	70
	2300 - 0700	9.1	55	16	9.5	33	70
8/11	0700 - 1500	9.2	48	16	9.2	27	67
	1500 - 2300	9.2	38	13	9.4	29	57
	2300 - 0700	9.3	44	15	9.3	30	68

CITY OF JACKSON
CORROSION CONTROL DATA

August 2020 DATE / SHIFT		SYSTEM ID: 250008-02			SYSTEM ID: 250008-01		
		OBC COMBINED HIGH SERVICE			JHF (TF081)		
		pH	Alkalinity	Hardness	pH	Alkalinity	Hardness
8/12	0700 - 1500	9.3	57	19	9.2	29	65
	1500 - 2300	9.5	48	18	9.3	24	54
	2300 - 0700	9.4	46	19	9.5	30	66
8/13	0700 - 1500	9.3	45	14	9.6	31	73
	1500 - 2300	9.4	49	19	9.6	33	57
	2300 - 0700	9.5	51	20	9.7	31	68
8/14	0700 - 1500	9.3	57	14	9.5	30	69
	1500 - 2300	9.4	57	16	9.6	32	70
	2300 - 0700	9.3	52	13	9.3	34	67
8/15	0700 - 1500	9.2	38	20	9.7	30	64
	1500 - 2300	8.4	28	16	9.5	31	55
	2300 - 0700	9.1	31	14	9.3	24	62
8/16	0700 - 1500	9.1	37	14	9.3	20	60
	1500 - 2300	9.2	33	16	9.5	27	63
	2300 - 0700	9.2	37	17	9.4	26	56
8/17	0700 - 1500	8.9	33	15	9.3	23	62
	1500 - 2300	8.8	37	13	9.4	24	65
	2300 - 0700	9.1	36	18	9.5	21	56
8/18	0700 - 1500	9.4	58	13	9.6	21	64
	1500 - 2300	9.4	51	17	9.6	27	50
	2300 - 0700	9.6	55	17	9.3	21	64
8/19	0700 - 1500	9.6	59	14	9.4	21	66
	1500 - 2300	9.5	41	13	9.1	26	46
	2300 - 0700	9.3	45	14	9.2	21	58
8/20	0700 - 1500	9.4	43	17	9.1	21	69
	1500 - 2300	9.3	41	20	9.1	25	49
	2300 - 0700	9.3	45	20	9.5	24	65
8/21	0700 - 1500	9.3	46	13	9.5	23	69
	1500 - 2300	9.6	48	17	9.7	26	72
	2300 - 0700	9.4	53	14	9.0	20	63
8/22	0700 - 1500	9.5	57	15	9.4	27	52
	1500 - 2300	9.4	52	18	9.1	23	60
	2300 - 0700	9.3	54	17	9.1	23	62

CITY OF JACKSON
CORROSION CONTROL DATA

August 2020 DATE / SHIFT		SYSTEM ID: 250008-02			SYSTEM ID: 250008-01		
		OBC COMBINED HIGH SERVICE			JHF (TF081)		
		pH	Alkalinity	Hardness	pH	Alkalinity	Hardness
8/23	0700 - 1500	9.2	53	14	9.1	20	61
	1500 - 2300	9.6	65	15	9.3	19	59
	2300 - 0700	9.6	54	17	9.2	27	51
8/24	0700 - 1500	9.7	64	17	9.3	20	59
	1500 - 2300	9.5	52	17	9.0	24	65
	2300 - 0700	9.5	53	18	9.3	22	61
8/25	0700 - 1500	9.5	39	15	9.5	22	69
	1500 - 2300	9.4	50	18	9.6	22	49
	2300 - 0700	9.5	51	19	9.4	23	62
8/26	0700 - 1500	9.4	35	16	9.2	21	68
	1500 - 2300	9.3	56	19	9.2	20	52
	2300 - 0700	9.6	43	21	9.6	23	61
8/27	0700 - 1500	9.4	55	13	9.1	21	62
	1500 - 2300	9.4	44	19	9.3	30	56
	2300 - 0700	9.3	46	18	9.5	21	59
8/28	0700 - 1500	9.6	48	12	9.6	25	74
	1500 - 2300	9.6	37	18	9.5	26	65
	2300 - 0700	9.3	44	16	9.3	25	64
8/29	0700 - 1500	9.2	35	13	9.2	26	49
	1500 - 2300	9.4	37	14	9.0	23	50
	2300 - 0700	9.4	52	20	9.0	21	66
8/30	0700 - 1500	9.5	51	16	9.1	19	56
	1500 - 2300	9.5	52	18	9.7	22	56
	2300 - 0700	9.5	55	20	9.4	26	46
8/31	0700 - 1500	9.2	63	17	9.5	20	58
	1500 - 2300	9.1	66	20	9.2	21	8
	2300 - 0700	9.3	64	22	9.5	23	62
MONTHLY MIN		8.4	27	12	9.0	16	8
MONTHLY MAX		9.9	69	23	9.7	34	79
MONTHLY AVG		9.4	48	16	9.4	25	61

Comments

JH Fewell (TF081)

Wash-out and inspection of #1 Ground Storage Tank at Fewell (1 of 2).
Cleaned stream and current detector.-8/24
Siwell Rd well back in service.-8/25
Raw and Basin #3 & #4 Turbidity meters (Front End, Mid-Point, and Settled) cleaned.-8/28

Online Monitoring Last Date of Calibration for JH Fewell

Cleaned and Calibrated following turbidity meters: Raw, Settled Basin #3, Settled Basin #4, Filter #17, 18, 19, 20, 21, 22, 23, 25, 27, and 28-8/11
All CL17s-8/7; 8/14; 8/21; 8/28

OB Curtis Conventional (TF082)

Grab data was replaced online data on the following dates listed below:

Settled water turbidity-Grab data was replaced on 8/24; 8/31. Spikes in turbidity.
Chlorine-Grab data was replaced on 8/23-12PM-4PM; 8/26-4PM; 8/27-8AM; 8/28-8PM.
Filter #3 - 8/19-8AM-8/20-8AM-Replaced turbidimeter.

OB Curtis Membrane (TF083)

Cleaned train #3 and #6 turbidimeter-8/31

Grab data was replaced online data on the following dates listed below:

Finished water turbidities were replaced on 8/7-12PM; 8/8-12AM, 4PM.
Cholrine-Grab data was replaced on 8/26-4PM; 8/27-8AM; 8/29; 8/30-8/31-8AM; 8/31-8PM.
Train #3-Grab data was replaced on 8/2; 8/5-8/8; 8/9-8/13-8AM-Reading .0209, in hold. 8/10-8PM-Spike in turbidity, turned off. 8/19-8AM; 8/21-4AM-4PM; 8/22-8AM; 8/23-12AM-4AM; 8/24-8AM, 8PM; 8/25-4PM-8PM; 8/28-8AM. Spikes in turbidity.
Train #4-Grab data was replaced on 8/2-12-4AM; 8/3; 8/6-8/8; 8/9-8/13-8AM-Reading .1147, in hold. 8/25-8AM-8/26-8AM. In hold, reading .933. 8/31-12AM.Spike in turbidity.
Train #6-Grab data was replaced on 8/8; 8/9-12PM; 8/10-4PM; 8/11-12PM; 8/12-4PM; 8/14-8AM; 8/21-8AM-Spikes in turbidity.

Online Monitoring Last Date of Calibration for O.B. Curtis

All CL17s-8/15, 8/23
Membrane turbidimeters-8/4
pH meters on basin #2, basin #3-8/10
Calibrated Raw, HS1, and Settled water turbidimeters-8/18
Calibrated Filter #1, Filter #4, and Filter #6 turbidimeters-8/19
Calibrated HS2 and Filter #3 turbidimeters-8/20


Upgrades and Repairs at O.B. Curtis


1. Basin #3 Clar-Trac sensors repair and replacement Aug 1.
2. Replaced broken P.V.C. drain valve on Aug. 4.
3. Replaced belt on polymer pump on Aug. 5.
4. Repaired air leak on train #3 cassette F and replaced sodium pump p-51 B in membrane plant on Aug. 6.
5. Replaced plunger 3421 on train #2 on Aug. 8.
6. Replaced rapid mixer at membrane plan, replaced water pump on basin #3 and reset turbidity meter on on Aug. 11.
7. Replaced ballast 2 on UV light fault on Aug. 12.
8. Replaced Filter #3 turbidimeter on Aug. 20.
9. Replaced belt on polymer pump on Aug. 25.
10. Replaced solenoid in train #2 and #4 on Aug. 27.
11. Replaced fluoride pump #2 on Aug. 30.

Upgrades and Repairs at JH Fewell

1. Replaced pump on stream and current detector on Aug. 24.

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."


Dr. Charles Williams, PE


Date